

## Nina Ruiz

---

**From:** Kelsey C. Traxinger <ktraxinger@jvajva.com>  
**Sent:** Friday, March 15, 2019 10:41 AM  
**To:** Nina Ruiz  
**Subject:** RE: Pike Peak 1041 Exemption

**CAUTION: This email originated from outside the El Paso County technology network. Do not click links or open attachments unless you recognize the sender and know the content is safe. Please call IT Customer Support at 520-6355 if you are unsure of the integrity of this message.**

---

Nina,

The wastewater system would have a peak flow of 10,000 gallons per day (gpd). Under Regulation 43, Table 6-2 a single-family home produces 75 gpd, so 250 single-family homes would produce 18,750 gpd. I can confirm that our system will not serve more than the equivalent of 250 single-family homes. Please let me know if you have any other questions.

Thank you,



**KELSEY C. TRAXINGER** | Design Engineer

JVA, Incorporated  
1512 Larimer Street, Suite 710, Denver, CO 80202  
Direct: 303.951.1035 | Phone: 303.444.1951  
[www.jvajva.com](http://www.jvajva.com)

Boulder | Fort Collins | Winter Park | Glenwood Springs | Denver

---

**From:** Nina Ruiz <[NinaRuiz@elpasoco.com](mailto:NinaRuiz@elpasoco.com)>  
**Sent:** Friday, March 15, 2019 10:14 AM  
**To:** Kelsey C. Traxinger <[ktraxinger@jvajva.com](mailto:ktraxinger@jvajva.com)>  
**Subject:** Pike Peak 1041 Exemption

Hello,

Can you please confirm that the new water treatment system will not serve more than the equivalent of 250 single-family homes? I need this information in order to exempt you from Article 4 as well as Article 1. Thank you!

### Nina Ruiz

Planner II  
El Paso Planning & Community Development  
2880 International Circle  
Colorado Springs, CO 80910  
(719) 520-6300 (Main)  
(719) 520-6313 (Direct)

To review all El Paso County projects go to: <https://epcdevplanreview.com/>

To review the El Paso County Land Development Code go to:

[https://library.municode.com/co/el\\_paso\\_county/codes/land\\_development\\_code](https://library.municode.com/co/el_paso_county/codes/land_development_code)

### PERSONAL WORK SCHEDULE

Monday - Thursday, 7:00 am to 5:30 pm

DEPARTMENT HOURS

Monday - Friday, 7:30 am to 4:30 pm