



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**8615 W. Hwy 24 Hobby Shop, PPR-22-51**

Please accept the following comments from El Paso County Public Health for the project referenced above:

- This development appears to be for private use only based on the Letter of Intent. If the Hobby Shop is for commercial use the comments below will require revision.
- Water will be provided by a private well (not shown on the Site Development Plan).
- Wastewater is provided by an onsite wastewater treatment system (OWTS) permitted, installed, and approved in 1975 for the Knotty Pines Restaurant. A map of the OWTS component locations is available on the El Paso County Assessor's Office website.
- The soil treatment area (2-12' deep seepage pits) must be located and protected from vehicle traffic/parking before and after the construction of the shop. The use of construction area type fencing is encouraged.

Mike McCarthy  
El Paso County Public Health  
719-332-5771  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
11November2022