



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

El Paso County School District 49 Transportation Center, PPR-22-36

Please accept the following comments from El Paso County Public Health for the project referenced above:

- **Water and wastewater services will be provided by Woodmen Hills Metropolitan District (WHMD). Will-Serve letters from WHMD dated 14March2022 have been submitted and reviewed for water and wastewater services. There is a finding for sufficiency in terms of water quality for the Colorado Department of Public Health and Environment regulated water system. Woodmen Hills Metropolitan District has been assigned PWSID #CO0121930 by the Colorado Department of Public Health and Environment.**
- **The owner must comply with all federal, state, and local regulations regarding the proper storage and disposal/recycling of batteries, or any automotive waste fluids generated as part of the maintenance operation.**
- **Earthmoving activities greater than 25 acres require a Construction Activity Permit from the Colorado Department of Public Health and Environment, Air Pollution Control Division. Go to: <https://www.colorado.gov/pacific/cdphe/general-air-permits>**
- **The water quality basins must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.**
- **Radon resistant construction building techniques/practices are encouraged in this area. The EPA has determined that Colorado, and specifically the El Paso County area, have higher radon levels than other areas of the country.**

Mike McCarthy
El Paso County Public Health
719.332.5771
mikemccarthy@elpasoco.com
07Sept2022