



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Glenarm Site Development Plan, PPR-20-26

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- The centralized water treatment facility for Stratmoor Hills Water District must meet the design criteria and the rules and regulations of the Colorado Department of Public Health and Environment (CDPHE), Water Quality Control Division (WQCD), for water system construction and materials.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- The water quality basin must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
11Oct2020