

**PRELIMINARY DRAINAGE REPORT
FLYING HORSE NORTH PRELIMINARY PLAN AND
FINAL DRAINAGE REPORT FOR FLYING HORSE NORTH FILING NO. 1**

CCES COMMENT RESPONSES

TABLE OF CONTENTS:

| | |
|---|---------|
| PURPOSE | Page 1 |
| GENERAL DESCRIPTION | Page 1 |
| EXISTING DRAINAGE CONDITIONS | Page 1 |
| PROPOSED DRAINAGE CHARACTERISTICS | Page 3 |
| FILING NO. 1 (BLACK SQUIRREL CREEK) | Page 4 |
| FILING NO. 1 (EAST CHERRY CREEK) | Page 10 |
| Review 2: This is also a FDR for Filing No. 1; therefore hydraulic analysis for filing 1 is required. Road side ditch analysis for the other areas may be deferred with to the future FDR for subsequent filings. | Page 12 |
| FLOODPLAIN STATEMENT | Page 15 |
| DRAINAGE AND BRIDGE FEES | Page 15 |
| SUMMARY | Page 16 |
| REFERENCES | Page 16 |
| | Page 17 |
| | Page 18 |

APPENDICES

| |
|----------------------------------|
| VICINITY MAP |
| SOILS MAP (WEB SOIL SURVEY) |
| F.E.M.A. MAP |
| HYDROLOGY/HYDRAULIC CALCULATIONS |
| DETENTION FACILITY CALCULATIONS |
| DRAINAGE MAPS |

Unresolved
05/09/2018

Resolved
05/09/2018

Resolved
05/09/2018

Include an existing drainage map and
provide the narrative for the sub-basin

1. Provide road side ditch analysis with
recommendations for ditch lining. Given the
steep slopes on sections of the proposed
road network, additional erosion protection.

2. Provide riprap sizing calculations for the
proposed outlet protections.

*Will provide
with final
subm.*



Design Point 1 ($Q_2 = 2$ cfs $Q_5 = 3$ cfs, $Q_{100} = 11$ cfs) represents the existing off-site and on-site developed flows from Basins OS-1A and BS-2B. The combined flow from these basins travel to a low point just east of Stagecoach Road where a proposed 24" RCP culvert will be installed to convey these flows under the road. (See Appendix for culvert design)

Design Point 2 ($Q_2 = 3$ cfs $Q_5 = 9$ cfs, $Q_{100} = 35$ cfs) represents flows from DP 1 and Basin BS-4. These combined flows are collected at a low point where a proposed 30" RCP culvert will be installed to replace the temporary sediment basin installed with early grading. (See Appendix for culvert design)

The total developed flows entering **Detention Facility 1** including Basin BS-1A equals ($Q_2 = 3$ cfs $Q_5 = 9$ cfs, $Q_{100} = 38$ cfs). These combined flows will travel in the natural drainage corridor across lot 1 and enter the detention facility. The following describes the design of this facility (See Appendix for UD Detention pond design sheets):

Resolved

05/09/2018

6.6 per UD Detention Worksheet

Detention Pond 1 (Full Spectrum – see multiple storm release)

0.43 Ac.-ft. EURV required

0.50 Ac.-ft. EURV design with 3:1 max. slopes

0.99 Ac.-ft. 100-yr. Storage

Total In-flow:

$Q_2 = 3$ cfs, $Q_5 = 9$ cfs, $Q_{100} = 38$ cfs

Pond Design Release:

$Q_2 = 0.1$ cfs, $Q_5 = 0.2$ cfs, $Q_{100} = 25$ cfs

Pre-development Release:

$Q_2 = 0.2$ cfs, $Q_5 = 0.4$ cfs, $Q_{100} = 23$ cfs

(Ownership and maintenance by the Flying Horse North HOA)

Design Point 4 ($Q_2 = 3$ cfs $Q_5 = 4$ cfs, $Q_{100} = 8$ cfs) represents existing and developed flows from Basin BS-2 (north side of Stagecoach Rd.) These flows will travel in a side road ditch towards Hwy. 83. A temporary sediment basin will be installed during construction of this portion of the roadway. This development will be required to provide improvements to this intersection and Hwy. 83 per the site traffic study. Upon review/approval from CDOT, these improvements will be constructed along with final design of drainage at this intersection which will include the relocation of the dual 18" ERCP culverts.

BS-2B

Identify the trigger for removal of the TSB.


Resolved

05/09/2018

BS-2
updated on map

Resolved

05/09/2018



Design Point 5 ($Q_2 = 2$ cfs $Q_5 = 4$ cfs, $Q_{100} = 13$ cfs) represents existing and developed flows from Basins OS-1B and BS-2A (south side of Stagecoach Rd.) These flows will travel in a side road ditch towards Hwy. 83. A temporary sediment basin will be installed during construction of this portion of the roadway. Upon review/approval from CDOT, these improvements will be constructed along with final design of drainage at this intersection. ← Identify the trigger for removal of the TSB

Resolved
05/09/2018

Design Point 6 ($Q_2 = 1$ cfs $Q_5 = 3$ cfs, $Q_{100} = 15$ cfs) represents flows from Basins OS-2 and BS-3. These combined flows are collected at a low point where proposed dual 18" RCP culverts will be installed to replace the temporary sediment basin installed with early grading. (See Appendix for culvert design) These flows then combine with Basin BS-1B and travel in the existing natural channel towards the existing downstream 48" CMP culvert. **Design Point 3** ($Q_2 = 1$ cfs $Q_5 = 6$ cfs, $Q_{100} = 39$ cfs) then represents the total flow from this site leaving the property at this location. The pre-development on-site flow at this location equals $Q_2 = 1$ cfs $Q_5 = 5$ cfs, $Q_{100} = 41$ cfs. Thus, the downstream facilities will not see a significant change in flows.

Design Point 7 ($Q_2 = 2$ cfs $Q_5 = 8$ cfs, $Q_{100} = 38$ cfs) represents existing and developed flows from Basins OS-3 and BS-5. These flows will travel as sheet flow towards the low point where dual 30" RCP culverts will be installed under Stagecoach Road to replace the temporary sediment basin installed with early grading. (See Appendix for culvert design)

High Forest Ranch Detention Pond 16 outfalls onto the property just upstream of Design Point 8. These existing flows will continue to enter the site and travel through proposed triple 42" RCP culverts under Stagecoach Road. (See Appendix for culvert design) **Design Point 8** ($Q_2 = 21$ cfs $Q_5 = 70$ cfs, $Q_{100} = 284$ cfs) represents the existing and developed flows exiting the property and continuing south within the natural channel on the Shamrock Ranch property. These flows remain consistent with the historic flows at this location.

Design Point 9 ($Q_2 = 1$ cfs $Q_5 = 5$ cfs, $Q_{100} = 23$ cfs) represents existing flows from Basins OS-7 and BS-12. These combined flows are collected at a low point where proposed dual 24" RCP culverts will be installed to replace the temporary sediment basin installed with early grading. (See Appendix for culvert design)



Design Point 10 ($Q_2 = 11$ cfs $Q_5 = 32$ cfs, $Q_{100} = 143$ cfs) represents existing and developed flows from Basins OS-8, OS-10, OS-11, BS-13 and BS-14. These flows will travel to the low point at this location where dual 42" RCP culverts will be installed for the crossing of Stagecoach Road. (See Appendix for culvert design)

Design Point 11 ($Q_2 = 5$ cfs $Q_5 = 12$ cfs, $Q_{100} = 36$ cfs) represents developed flow from Basin BS-16. These flows will travel to the low point at this location where dual 24" RCP culverts will be installed for the crossing of the road. (See Appendix for culvert design)

Design Point 12 ($Q_2 = 4$ cfs $Q_5 = 11$ cfs, $Q_{100} = 44$ cfs) represents developed flow from Basins BS-16 and BS-15. These flows will travel to the low point at this location where a 30" RCP culvert will be installed and directly enter Detention Pond 4 at the south end. (See Appendix for culvert design)

The total developed flows entering **Detention Facility 4**, including **Design Point 12** ($Q_2 = 3$ cfs $Q_5 = 52$ cfs, $Q_{100} = 217$ cfs). The major flows enter the facility at the north end through a rock chute. (See Appendix for rock chute and pond design) The following describes the design of this facility: (See Appendix for UD Detention pond design sheets):

Detention Pond 4 (Full Spectrum – see multiple storm release data below)

0.99 Ac.-ft. EURV required

1.05 Ac.-ft. EURV design with 4:1 max. slopes

5.06 Ac.-ft. 100-yr. Storage

Total In-flow: $Q_2 = 18$ cfs, $Q_5 = 52$ cfs, $Q_{100} = 217$ cfs

Pond Design Release: $Q_2 = 0.3$ cfs, $Q_5 = 0.3$ cfs, $Q_{100} = 142$ cfs

Pre-development Release: $Q_2 = 1.5$ cfs, $Q_5 = 2.5$ cfs, $Q_{100} = 152$ cfs

(Ownership and maintenance by the Flying Horse North HOA)

Resolved
05/09/2018

Explain why the construction plans show a bend & manhole. Is there a future extension of the storm system?

Yes, 36" RCP will route these flows directly into Pond 4.

Update the 2yr and 5yr to match the UD-detention worksheet.

equal ($Q_2 = 3$ cfs)



Basin BS-24 ($Q_2 = 0.6$ cfs $Q_5 = 3$ cfs, $Q_{100} = 18$ cfs) represents sheet flow from three residential lots within Filing No. 1 that will continue to direct release off-site. However, portions of this historic basin area will be routed into Flying Horse North Pond 8, therefore the developed flows from this basin do not significantly change from the pre-development condition. The pre-development flows from the historic basin area equal $Q_2 = 0.2$ cfs $Q_5 = 2$ cfs, $Q_{100} = 18$ cfs. Also, given the lot size, no water quality is required.

FLYING HORSE NORTH FILING NO. 1

East Cherry Creek Drainage Basin

The following basins are still tributary to the Filing No. 1 platting area but are within the East Chery Creek Drainage Basin:

Design Point 24 ($Q_2 = 2$ cfs $Q_5 = 8$ cfs, $Q_{100} = 45$ cfs) represents developed flows from Basins CC-4C and CC-5. Basin CC-4C represents the flow from the future pond. If this design is approved, a site specific detention/SWQ facility will be required at this design point. If the concentrated flow from the future pond is directed to the residential lots, there will likely be drainage impacts. Provide additional guidance in the narrative regarding the release location (consider the 100yr and emergency overflow path). Specific drainage easements may be required if draining through residential lots. (See Appendix for culvert design)

✓ See revised

Resolved
05/09/2018

The total developed flows entering **Detention Facility 12**, including Basin CC-6 equals ($Q_2 = 4$ cfs $Q_5 = 17$ cfs, $Q_{100} = 86$ cfs). The following describes the design of this facility:
(See Appendix for UD Detention pond design sheets):

Detention Pond 12 (Full Spectrum – see multiple storm release data below)

0.66 Ac.-ft. EURV required

0.75 Ac.-ft. EURV design with 4:1 max. slopes

2.69 Ac.-ft. 100-yr. Storage

Total In-flow: $Q_2 = 4$ cfs, $Q_5 = 17$ cfs, $Q_{100} = 86$ cfs

Pond Design Release: $Q_2 = 0.2$ cfs, $Q_5 = 0.3$ cfs, $Q_{100} = 45$ cfs

Pre-development Release: $Q_2 = 0.5$ cfs, $Q_5 = 0.9$ cfs, $Q_{100} = 55$ cfs

(Ownership and maintenance by the Flying Horse North HOA)



the low-point where a 24" RCP culvert is sized to handle the fully developed flows at this location. (See Appendix for culvert design) A downstream sediment basin will be installed to provide sediment control for the small developed roadway area.

Missing. Include the culvert design in the Appendix and the construction plans.

Resolved

05/09/2018

Now included

Design Point 31 ($Q_2 = 0.7$ cfs $Q_5 = 3$ cfs, $Q_{100} = 40$ cfs) represents the full build-out developed flows from Basin CC-19 and the upstream release from Basin CC-17. Basin CC-17 represents future residential 5 ac. lots. These flows will continue to sheet flow towards the low-point where a 24" CMP culvert will be installed to handle the fully developed flows at this location. (See Appendix for culvert design) A downstream sediment basin will be installed to provide sediment control for the small developed roadway area.

Culvert report is missing for DP 31

Include the supporting calculation. Verify there is sufficient drainage easement that covers the natural swale.

Unresolved

05/09/2018

Added info. and errat.

Design Point 32 ($Q_2 = 2$ cfs $Q_5 = 8$ cfs, $Q_{100} = 40$ cfs) represents the full build-out developed flows from Basins OS-16 and CC-17. Basin CC-17 represents future residential lots and OS-16 unplatted, 5-ac. zoned residential property. These flows will continue to sheet flow towards the low-point where a 36" RCP culvert is sized to handle the fully developed flows at this location. (See Appendix for culvert design) A downstream sediment basin will be installed to provide sediment control for the small developed roadway area.

FLYING HORSE NORTH PRELIMINARY PLAN (Future Platting)

Black Squirrel Creek Drainage Basin

The following basins are in the Black Squirrel Creek Drainage Basin but are not a part of Filing 1 lot development. These areas will require future final drainage report(s) upon future lot development.

Design Point 18 ($Q_2 = 5$ cfs $Q_5 = 22$ cfs, $Q_{100} = 115$ cfs) represents developed flows from Basins BS-28, BS-29, BS-30 and OS-18. Portions of basins BS-28 and BS-29 include golf course development taking place with Filing No. 1. However, the majority of these basins include forested future residential lots with basin OS-18 being existing 2.5 ac. minimum lots. Future developed flows will be routed to this location where a future detention facility will be installed. This facility will be sized to meet EURV requirements and release pre-development flow quantities. In the interim, with only the golf course construction, a temporary sediment basin located within the developed golf course will be installed to provide sediment control from the developed golf course.

Resolved

05/09/2018

Elaborate on where this drains to. From the drainage map it seems to drain into the future detention facility at DP 19. If this is the case then identify that ponds DP18 and DP19 must be designed/analyzed as ponds in a series.

Identify and discuss the emergency overflow path for Pond 18. It appears that it would cross over residential lots and into Pond DP19

see additional text in report



The following calculations are based on the 2017 drainage/bridge fees for the Black Squirrel Creek Drainage Basin:

FILING 1 FEE TOTALS:

Bridge Fees

$$\$ 465.00 \times 20.96 \text{ Impervious Ac.} = \$ 9,746.40$$

Drainage Fees

$$\$ 7,387.00 \times 20.96 \text{ Impervious Ac.} = \$ 154,831.52$$

Add a section listing the 4 step process (ECM Appendix I Section I.7.2) with narrative on how each step was considered and/or incorporated in the drainage design.

Resolved
05/09/2018

SUMMARY

This proposed development remains consistent with the previously approved Flying Horse North MDDP and Preliminary Drainage Report for Flying Horse North (Golf Course grading and private access roads). The proposed storm facilities have been sized to adequately handle the 100-yr. developed flows. All proposed detention facilities meet current criteria and provide full spectrum design. Upon future development outside of Filing No. 1, final drainage reports will be required finalizing final design of the proposed future drainage facilities. The proposed development will not adversely impact surrounding developments.

PREPARED BY:

Classic Consulting Engineers & Surveyors, LLC

Marc A. Whorton, P.E.
Project Manager

Maw/109611/reports/109611PDR.doc




Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Project: Flying Horse North Filing No. 1

Basin ID: Pond 1



Example Zone Configuration (Retention Pond)

| | Stage (ft) | Zone Volume (ac-ft) | Outlet Type |
|-------------------|------------|---------------------|------------------------|
| Zone 1 (WQCV) | 1.85 | 0.210 | Orifice Plate |
| Zone 2 (EURV) | 2.74 | 0.223 | Orifice Plate |
| Zone 3 (100-year) | 5.04 | 0.710 | Weir & Pipe (Restrict) |
| Total | | 1.143 | |

User Input: Orifice at Underdrain Outlet (typically used to drain WQCV in a Filtration BMP)

Underdrain Orifice Invert Depth = ft (distance below the filtration media surface)
Underdrain Orifice Diameter = inches

Calculated Parameters for Underdrain

Underdrain Orifice Area = ft²
Underdrain Orifice Centroid = feet

User Input: Orifice Plate with one or more orifices or Elliptical Slot Weir (typically used to drain WQCV and/or EURV in a sedimentation BMP)

Invert of Lowest Orifice = ft (relative to basin bottom at Stage = 0 ft)
Depth at top of Zone using Orifice Plate = ft (relative to basin bottom at Stage = 0 ft)
Orifice Plate: Orifice Vertical Spacing = inches
Orifice Plate: Orifice Area per Row = inches

Calculated Parameters for Plate

WQ Orifice Area per Row = ft²
Elliptical Half-Width = feet
Elliptical Slot Centroid = feet
Elliptical Slot Area = ft²

User Input: Stage and Total Area of Each Orifice Row (numbered from lowest to highest)

| | Row 1 (required) | Row 2 (optional) | Row 3 (optional) | Row 4 (optional) | Row 5 (optional) | Row 6 (optional) | Row 7 (optional) | Row 8 (optional) |
|--------------------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Stage of Orifice Centroid (ft) | 0.00 | 0.90 | 1.80 | 2.70 | | | | |
| Orifice Area (sq. inches) | 0.99 | 1.43 | 1.43 | 1.43 | | | | |

| | Row 9 (optional) | Row 10 (optional) | Row 11 (optional) | Row 12 (optional) | Row 13 (optional) | Row 14 (optional) | Row 15 (optional) | Row 16 (optional) |
|--------------------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Stage of Orifice Centroid (ft) | | | | | | | | |
| Orifice Area (sq. inches) | | | | | | | | |

User Input: Vertical Orifice (Circular or Rectangular)

| | Not Selected | Not Selected | |
|---|--------------|--------------|---|
| Invert of Vertical Orifice = | N/A | N/A | ft (relative to basin bottom at Stage = 0 ft) |
| Depth at top of Zone using Vertical Orifice = | N/A | N/A | ft (relative to basin bottom at Stage = 0 ft) |
| Vertical Orifice Diameter = | N/A | N/A | inches |

Calculated Parameters for Vertical Orifice

| | Not Selected | Not Selected | |
|-----------------------------|--------------|--------------|-----------------|
| Vertical Orifice Area = | N/A | N/A | ft ² |
| Vertical Orifice Centroid = | N/A | N/A | feet |

User Input: Overflow Weir (Dropbox) and Grate (Flat or Sloped)

| | Zone 3 Weir | Not Selected | |
|---|-------------|--------------|---|
| Overflow Weir Front Edge Height, H _o = | 2.75 | N/A | ft (relative to basin bottom at Stage = 0 ft) |
| Overflow Weir Front Edge Length = | 4.00 | N/A | feet |
| Overflow Weir Slope = | 3.00 | N/A | H:V (enter zero for flat grate) |
| Horiz. Length of Weir Sides = | 4.00 | N/A | feet |
| Overflow Grate Open Area % = | 75% | N/A | % grate open area/total area |
| Debris Clogging % = | 50% | N/A | % |

Calculated Parameters for Overflow Weir

| | Zone 3 Weir | Not Selected | |
|--|-------------|--------------|-----------------|
| Height of Grate Upper Edge, H _u = | 4.08 | N/A | feet |
| Over Flow Weir Slope Length = | 4.22 | N/A | feet |
| Grate Open Area / 100-yr Orifice Area = | 5.00 | N/A | should be ≥ 4 |
| Overflow Grate Open Area w/o Debris = | 12.65 | N/A | ft ² |
| Overflow Grate Open Area w/ Debris = | 6.32 | N/A | ft ² |

User Input: Outlet Pipe w/ Flow Restriction Plate (Circular Orifice, Restrictor Plate, or Rectangular Orifice)

| | Zone 3 Restrictor | Not Selected | |
|---|-------------------|--------------|--|
| Depth to Invert of Outlet Pipe = | 0.33 | N/A | ft (distance below basin bottom at Stage = 0 ft) |
| Outlet Pipe Diameter = | 24.00 | N/A | inches |
| Restrictor Plate Height Above Pipe Invert = | 18.00 | | inches |

Calculated Parameters for Outlet Pipe w/ Flow Restriction Plate

| | Zone 3 Restrictor | Not Selected | |
|--|-------------------|--------------|-----------------|
| Outlet Orifice Area = | 2.53 | N/A | ft ² |
| Outlet Orifice Centroid = | 0.83 | N/A | feet |
| Half-Central Angle of Restrictor Plate on Pipe = | 2.09 | N/A | radians |

User Input: Emergency Spillway (Rectangular or Trapezoidal)

| Spillway Invert Stage = | 5.00 | ft (relative to basin bottom at Stage = 0 ft) |
|-------------------------------------|-------|---|
| Spillway Crest Length = | 25.00 | feet |
| Spillway End Slopes = | 3.00 | H:V |
| Freeboard above Max Water Surface = | 1.00 | feet |

Calculated Parameters for Spillway

| Spillway Design Flow Depth = | 0.69 | feet |
|----------------------------------|------|-------|
| Stage at Top of Freeboard = | 6.69 | feet |
| Basin Area at Top of Freeboard = | 0.39 | acres |

Routed Hydrograph Results

| | WQCV | EURV | 2 Year | 5 Year | 10 Year | 25 Year | 50 Year | 100 Year | 500 Year |
|---|-------|-------|--------|------------------|------------------|------------------|------------------|------------------|----------|
| Design Storm Return Period = | | | | | | | | | |
| One-Hour Rainfall Depth (in) = | 0.53 | 1.07 | 1.19 | 1.50 | 1.75 | 2.00 | 2.25 | 2.52 | 3.39 |
| Calculated Runoff Volume (acre-ft) = | 0.210 | 0.433 | 0.319 | 0.469 | 0.809 | 1.596 | 2.099 | 2.758 | 4.375 |
| OPTIONAL Override Runoff Volume (acre-ft) = | | | | | | | | | |
| Inflow Hydrograph Volume (acre-ft) = | 0.210 | 0.432 | 0.319 | 0.469 | 0.809 | 1.596 | 2.099 | 2.757 | 4.375 |
| Predevelopment Unit Peak Flow, q (cfs/acre) = | 0.00 | 0.00 | 0.01 | 0.02 | 0.16 | 0.55 | 0.77 | 1.04 | 1.66 |
| Predevelopment Peak Q (cfs) = | 0.0 | 0.0 | 0.2 | 0.4 | 3.5 | 12.0 | 16.7 | 22.6 | 36.2 |
| Peak Inflow Q (cfs) = | 3.0 | 6.1 | 4.5 | 6.6 | 11.4 | 22.3 | 29.2 | 38.2 | 60.2 |
| Peak Outflow Q (cfs) = | 0.1 | 0.2 | 0.1 | 0.2 | 3.8 | 13.7 | 20.2 | 24.6 | 49.8 |
| Ratio Peak Outflow to Predevelopment Q = | N/A | N/A | N/A | 0.5 | 1.1 | 1.1 | 1.2 | 1.1 | 1.4 |
| Structure Controlling Flow = | Plate | Plate | Plate | Overflow Grate 1 | Overflow Grate 1 | Overflow Grate 1 | Overflow Grate 1 | Overflow Grate 1 | Spillway |
| Max Velocity through Grate 1 (fps) = | N/A | N/A | N/A | 0.0 | 0.3 | 1.1 | 1.6 | 1.9 | 2.1 |
| Max Velocity through Grate 2 (fps) = | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Time to Drain 97% of Inflow Volume (hours) = | 50 | 66 | 59 | 67 | 64 | 54 | 49 | 45 | 37 |
| Time to Drain 99% of Inflow Volume (hours) = | 53 | 71 | 63 | 73 | 72 | 68 | 66 | 63 | 56 |
| Maximum Ponding Depth (ft) = | 1.78 | 2.63 | 2.21 | 2.76 | 3.28 | 3.84 | 4.10 | 4.59 | 5.44 |
| Area at Maximum Ponding Depth (acres) = | 0.21 | 0.26 | 0.25 | 0.27 | 0.29 | 0.31 | 0.31 | 0.33 | 0.37 |
| Maximum Volume Stored (acre-ft) = | 0.194 | 0.403 | 0.295 | 0.438 | 0.582 | 0.750 | 0.831 | 0.986 | 1.283 |

0.9 for full spectrum detention.
Comment applies for all Full Spectrum Pond design

Resolved

05/09/2018

revised

Resolved
05/09/2018

Runoff is now concentrated flow. Analyze and discuss the results/recommendations in the narrative. It is noted that erosion will occur, a swale may be required within a drainage easement. For this particular location the swale would connect to the pond with a rundown and a trickle channel to the outlet structure.
Review all other culvert locations regarding the above comment.

Resolved
05/09/2018

Show the 100yr spread from DP3. Is the natural swale sufficient to keep the runoff from draining into Pond 17?


Resolved
05/09/2018

BASIN SUMMARY - DEVELOPED CONDITIONS

| BASIN (label) | AREA (acres) | COMPOSITE CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|-------------------|--------------|--------------|------------------------|---------------|---------------|-----------------|
| OS-1A | 4.40 | 61.0 | 0.20 | 0.4 | 1.6 | 7.7 |
| OS-1B | 5.60 | 61.0 | 0.21 | 0.5 | 1.9 | 9.4 |
| EX-DP-3 (Pre-Dev) | 36.00 | 60.0 | 0.25 | 0.5 | 4.8 | 41.3 |
| OS-2 | 2.90 | 61.0 | 0.20 | 0.1 | 0.6 | 4.0 |
| OS-3 | 10.20 | 65.0 | 0.19 | 1.0 | 3.8 | 17.9 |
| OS-4 | 32.90 | 65.0 | 0.23 | 2.8 | 11.2 | 53.6 |
| OS-5 | 29.70 | 65.0 | 0.39 | 1.9 | 7.1 | 37.0 |
| OS-6 | 9.20 | 65.0 | 0.21 | 0.9 | 3.2 | 15.5 |
| OS-7 | 5.00 | 65.0 | 0.18 | 0.5 | 2.0 | 9.0 |
| BS-1A | 3.50 | 65.0 | 0.17 | 0.4 | 1.4 | 6.3 |
| BS-1B | 8.90 | 65.0 | 0.20 | 0.4 | 2.4 | 13.8 |
| BS-2 | 1.90 | 89.0 | 0.35 | 2.9 | 4.2 | 8.4 |
| BS-2A | 0.80 | 89.0 | 0.13 | 1.2 | 1.8 | 3.5 |
| BS-2B | 0.90 | 89.0 | 0.12 | 1.4 | 2.0 | 4.0 |
| BS-3 | 6.20 | 65.0 | 0.20 | 0.6 | 2.3 | 10.8 |
| BS-4 | 13.00 | 67.0 | 0.23 | 1.9 | 5.5 | 23.6 |
| BS-5 | 11.20 | 65.0 | 0.18 | 1.1 | 4.4 | 20.1 |
| BS-6 | 1.20 | 89.0 | 0.09 | 1.9 | 2.8 | 5.4 |
| BS-7 | 2.90 | 65.0 | 0.13 | 4.4 | 6.4 | 12.8 |
| BS-8 | 1.00 | 89.0 | 0.12 | 1.6 | 2.2 | 4.5 |
| BS-9 | 1.50 | 89.0 | 0.13 | 2.3 | 3.3 | 6.6 |
| BS-10 | 4.50 | 65.0 | 0.24 | 6.0 | 8.7 | 17.5 |
| BS-11 | 0.90 | 89.0 | 0.08 | 1.5 | 2.1 | 4.1 |
| BS-12 | 7.70 | 65.0 | 0.19 | 0.8 | 3.0 | 13.8 |

DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS

| Design Point (label) | Contributing Basins | Q 2 Yr. Q (cfs) | Q 5 Yr. Q (cfs) | Q 100 Yr. Q (cfs) |
|----------------------------|--|-----------------|-----------------|-------------------|
| DP-1 DEV | OS-1A, BS-2B | 1.6 | 3.4 | 11 |
| DP-2 DEV | DP-1, BS-4 | 3.2 | 8.8 | 35 |
| TOTAL INFLOW TO FHN POND 1 | DP-1, DP-2, BS-1A | 3 | 9 | 38 |
| DP-3 DEV | OS-2, BS-3, BS-1B, Release from FHN Pond 1 | 1 | 6 | 39 |
| DP-4 DEV | BS-2 | 2.9 | 4.2 | 8 |
| DP-5 DEV | OS-1B, BS-2A | 1.5 | 3.5 | 13 |
| DP-6 DEV | OS-2, BS-3 | 0.6 | 2.8 | 15 |
| DP-7 DEV | OS-3, BS-5 | 2.1 | 8.2 | 38 |
| DP-8 DEV | OS-4, OS-5, OS-6, BS-7, BS-10, Release from Exist. HFR Pond 16 | 20.9 | 70.4 | 284 |
| DP-9 DEV | OS-7, BS-12 | 1.3 | 5.0 | 23 |



CLASSIC
CONSULTING
ENGINEERS & SURVEYORS

FLYING HORSE NORTH
PRELIMINARY/FINAL DRAINAGE REPORT
FLUNG NO. 1 DRAINAGE MAP

DESIGNED BY: MAA SCALE: DATE: 1C-20-17
DRAWN BY: MAA (H): 1" = 200' SHEET: 1 OF 4
CHECKED BY: (V): 1" = N/A JOB NO: 1096.11

Added report
Resolved
05/09/2018
See channel calcs.

BASIN SUMMARY - DEVELOPED CONDITIONS

| BASIN (label) | AREA (acres) | COMPOSITE CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|-----------------|--------------|--------------|------------------------|---------------|---------------|-----------------|
| OS-8 | 14.2 | 65.0 | 0.21 | 2.1 | 8.2 | 24.7 |
| OS-9 | 9.8 | 60.0 | 0.37 | 0.1 | 1.0 | 9.1 |
| OS-10 | 4.1 | 65.0 | 0.17 | 0.7 | 2.1 | 8.2 |
| OS-11 | 28.0 | 65.0 | 0.38 | 2.4 | 8.2 | 24.7 |
| OS-12 | 68.1 | 62.7 | 0.37 | 2.2 | 11.9 | 75.8 |
| OS-13 | 36.9 | 63.0 | 0.33 | 1.4 | 7.4 | 45.0 |
| OS-14 | 26.4 | 62.0 | 0.31 | 0.7 | 4.6 | 31.0 |
| OS-15 | 70.8 | 63.9 | 0.38 | 3.3 | 14.8 | 94.2 |
| OS-16 | 4.8 | 65.0 | 0.24 | 0.4 | 1.5 | 7.2 |
| OS-17 | 15.8 | 65.0 | 0.19 | 1.6 | 5.9 | 27.7 |
| OS-18 | 13.0 | 65.0 | 0.20 | 1.3 | 4.7 | 22.6 |
| BS-13 | 25.6 | 65.0 | 0.23 | 3.7 | 10.2 | 40.7 |
| BS-14 | 13.4 | 65.0 | 0.23 | 2.6 | 6.8 | 26.5 |
| BS-15 | 6.3 | 65.0 | 0.18 | 1.6 | 3.7 | 12.2 |
| BS-16 | 21.6 | 65.0 | 0.34 | 4.6 | 11.9 | 44.1 |
| BS-17 | 12.1 | 65.0 | 0.21 | 3.1 | 7.7 | 26.7 |
| BS-18 | 33.8 | 63.6 | 0.41 | 3.5 | 12.4 | 56.0 |
| BS-19 | 6.3 | 65.0 | 0.18 | 2.1 | 4.8 | 15.0 |
| BS-20 | 73.9 | 63.4 | 0.31 | 7.4 | 24.6 | 112.4 |
| BS-21 | 69.5 | 64.3 | 0.35 | 7.8 | 23.9 | 103.0 |
| BS-22 | 18.1 | 64.4 | 0.22 | 3.7 | 8.6 | 36.5 |
| BS-23 | 37.1 | 63.3 | 0.33 | 4.5 | 13.5 | 58.2 |
| BS-23A | 16.3 | 64.4 | 0.26 | 5.5 | 12.0 | 36.3 |
| BS-24 | 10.9 | 63.0 | 0.17 | 0.6 | 3.3 | 17.6 |
| EX-24 (Pre-Dev) | 13.2 | 60.0 | 0.18 | 0.9 | 3.2 | 17.6 |
| BS-25 | 12.7 | 63.0 | 0.23 | 0.4 | 2.7 | 17.3 |
| BS-26 | 2.5 | 60.0 | 0.18 | 0.0 | 0.4 | 3.4 |
| BS-27 | 23.3 | 65.0 | 0.22 | 2.1 | 6.0 | 38.8 |
| BS-28 | 36.9 | 64.4 | 0.32 | 2.2 | 9.3 | 49.4 |
| BS-29 | 27.7 | 64.0 | 0.33 | 1.4 | 8.5 | 35.9 |
| BS-30 | 6.7 | 65.0 | 0.20 | 0.7 | 2.4 | 11.7 |
| BS-31 | 8.4 | 63.6 | 0.23 | 0.3 | 1.9 | 11.8 |
| BS-32 | 6.2 | 62.8 | 0.20 | 0.3 | 1.6 | 9.4 |
| BS-33 | 8.9 | 64.7 | 0.19 | 0.8 | 3.2 | 15.3 |
| CC-1A | 8.8 | 65.0 | 0.23 | 0.8 | 3.3 | 16.0 |
| CC-1B | 12.6 | 64.8 | 0.26 | 1.0 | 4.0 | 19.4 |
| CC-2A | 11.0 | 65.0 | 0.22 | 1.0 | 3.8 | 16.3 |
| CC-2B | 20.8 | 65.0 | 0.22 | 1.9 | 7.1 | 34.6 |
| CC-2C | 6.4 | 65.0 | 0.18 | 0.7 | 2.5 | 11.5 |
| CC-3 | 52.8 | 63.1 | 0.43 | 1.8 | 8.8 | 54.6 |
| CC-4A | 108.7 | 62.6 | 0.44 | 15.4 | 39.0 | 156.0 |
| CC-4B | 8.1 | 64.3 | 0.26 | 4.0 | 7.3 | 20.6 |
| CC-4C (Pre-Dev) | 7.4 | 61.0 | 0.13 | 0.2 | 1.8 | 11.2 |
| CC-5 | 22.4 | 65.0 | 0.26 | 1.8 | 7.1 | 34.3 |
| CC-6 | 27.2 | 65.0 | 0.28 | 2.3 | 8.1 | 33.2 |
| CC-7 | 18.4 | 65.0 | 0.29 | 1.4 | 5.4 | 27.0 |

DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS

| Design Point (label) | Contributing Basins | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|---|--|---------------|---------------|-----------------|
| DP-10 DEV | OS-8, OS-10, OS-11, BS-13, BS-14 | 10.7 | 32.0 | 143 |
| DP-11 DEV | BS-16 | 4.6 | 11.8 | 36 |
| DP-12 DEV | DP-11, BS-15 | 4.0 | 11.0 | 44 |
| TOTAL INFLOW TO FHN POND 4 | DP-10, DP-12, BS-17, OS-9 | 18 | 52 | 217 |
| DP-13 DEV | Release from FHN Pond 4 | 0.3 | 0.3 | 142 |
| DP-14 DEV | BS-18 | 3.5 | 12.4 | 56 |
| DP-15 DEV | BS-19 | 2.1 | 4.6 | 15 |
| DP-16 DEV | DP-14, DP-15, BS-20, BS-21, BS-22, BS-23 | 25.0 | 78.0 | 362 |
| TOTAL INFLOW TO FHN POND 8 (Full Build-out) | DP-16, DP-12, BS-17, OS-9 | 26 | 85 | 383 |
| DP-17 DEV (Full Build-out) | Release from FHN Pond 8 | 0.8 | 1.0 | 233 |
| TOTAL INFLOW TO FHN POND 8 (Filling 1 Only) | DP-16, DP-12, BS-17, OS-9 | 12 | 50 | 267 |
| DP-17 DEV (Filling 1 Only) | Release from FHN Pond 8 | 0.4 | 0.5 | 228 |
| DP-18 DEV | BS-28, BS-29, BS-30, OS-18 | 5.0 | 21.6 | 115 |
| DP-19 DEV | BS-27, OS-17, Release from DP-18 | 3.8 | 16.8 | 126 |
| DP-20 DEV | CC-1A, OS-12 | 3.2 | 14.3 | 88 |
| DP-21 DEV | CC-2A, OS-13 | 2.1 | 10.5 | 62 |
| DP-22 DEV | CC-2B, Release from DP-21 | 3.7 | 16.6 | 92 |
| DP-23 DEV | CC-3, OS-14 | 2.5 | 13.0 | 84 |
| DP-24 DEV | CC-4C (Pre-Dev), CC-5 | 1.9 | 8.4 | 45 |
| TOTAL INFLOW TO FHN POND 12 | CC-4C, CC-5, CC-6 | 4 | 17 | 86 |
| DP-25 DEV | Release from FHN Pond 12 | 0.2 | 0.3 | 45 |

LEGEND

DESCRIPTION SYMBOL

EXISTING GROUND CONTOUR 6910

PROPOSED FINISHED CONTOUR 6910

BASIN BOUNDARY EAST CHERRY CREEK

MAJOR BASIN BOUNDARY

BASIN BOUNDARY BLACK SQUIRREL

DESIGN POINT

BASIN IDENTIFIER AREA IN ACRES

EXISTING DIRECTION OF FLOW

PROPOSED DIRECTION OF FLOW

STORM SEWER

FLUING NO. 1 PLAT AREA

SCALE: 1" = 200'

CLASSIC CONSULTING ENGINEERS & SURVEYORS

619 N. Cascade Avenue, Suite 200
Colorado Springs, Colorado 80903

(719)785-0790
(719)785-0799 (fax)

FLYING HORSE NORTH
PRELIMINARY/FINAL DRAINAGE REPORT
FLUING NO. 1 DRAINAGE MAP

DESIGNED BY: MAW
DRAWN BY: MAW
CHECKED BY: N/A

SCALE: (H) 1" = 200'
(V) 1" = N/A

DATE: 1C-25-17
SHEET: 2 OF 4
JOB NO: 1096-11


Resolved
05/09/2018
See revised narrative.

Unresolved
05/09/2018
See review comment on the channel report for the natural channel through lots 58-59

Which plat note # addresses this comment? Staff did not see a note pertaining to culvert sizing.

Resolved
05/09/2018

Added
Resolved
05/09/2018



| BASIN SUMMARY - DEVELOPED CONDITIONS | | | | | | |
|--------------------------------------|--------|-----------|----------|-------|-------|---------|
| BASIN | AREA | COMPOSITE | TOTAL | Q | Q | Q |
| | (ACRS) | CN | LAG TIME | 2 Yr. | 5 Yr. | 100 Yr. |
| | | | (HRS) | (CFS) | (CFS) | (CFS) |
| OS-8 | 14.20 | 65.0 | 0.37 | 2.1 | 6.2 | 24.7 |
| OS-9 | 9.80 | 60.0 | 0.37 | 0.1 | 1.0 | 9.1 |
| OS-10 | 4.10 | 65.0 | 0.17 | 0.7 | 2.1 | 8.2 |
| OS-11 | 28.00 | 65.0 | 0.35 | 2.4 | 6.2 | 36.7 |
| OS-12 | 68.10 | 62.7 | 0.37 | 2.2 | 11.9 | 75.8 |
| OS-13 | 36.90 | 63.0 | 0.33 | 1.4 | 7.4 | 45.0 |
| OS-14 | 26.40 | 62.0 | 0.31 | 0.7 | 4.6 | 31.0 |
| OS-15 | 70.80 | 63.9 | 0.30 | 3.3 | 14.8 | 94.2 |
| OS-16 | 4.50 | 65.0 | 0.24 | 0.4 | 1.5 | 7.2 |
| OS-17 | 15.80 | 65.0 | 0.19 | 1.8 | 5.9 | 27.1 |
| OS-18 | 13.90 | 65.0 | 0.20 | 1.3 | 4.7 | 22.6 |
| CC-1A | 6.60 | 65.0 | 0.23 | 0.8 | 3.3 | 16.0 |
| CC-1B | 12.60 | 64.8 | 0.25 | 1.0 | 4.0 | 19.4 |
| CC-2A | 11.00 | 65.0 | 0.22 | 1.0 | 3.8 | 18.3 |
| CC-2B | 20.80 | 65.0 | 0.22 | 1.9 | 7.1 | 34.6 |
| CC-2C | 6.40 | 65.0 | 0.18 | 0.7 | 2.5 | 11.5 |
| CC-3 | 52.50 | 63.1 | 0.43 | 1.8 | 8.8 | 54.5 |
| CC-4A | 108.70 | 62.6 | 0.44 | 15.4 | 39.0 | 156.0 |
| CC-4B | 6.10 | 76.1 | 0.26 | 4.0 | 7.3 | 26.6 |
| CC-4C (Pre-Dev) | 7.40 | 61.0 | 0.13 | 0.2 | 1.8 | 11.2 |
| CC-5 | 22.40 | 65.0 | 0.26 | 1.8 | 7.1 | 34.3 |
| CC-6 | 27.65 | 65.0 | 0.25 | 2.3 | 9.1 | 43.2 |
| CC-10 | 18.40 | 65.0 | 0.22 | 1.4 | 5.4 | 27.8 |
| CC-8 | 7.70 | 65.0 | 0.25 | 0.5 | 2.5 | 12.0 |
| CC-9 | 5.60 | 65.0 | 0.18 | 0.6 | 2.1 | 9.8 |
| CC-10 | 85.60 | 62.6 | 0.30 | 2.8 | 14.1 | 91.9 |
| CC-11 | 16.60 | 65.1 | 0.21 | 0.9 | 5.0 | 26.1 |
| CC-12 | 12.20 | 65.0 | 0.26 | 1.0 | 3.9 | 18.7 |
| CC-13A | 19.50 | 65.0 | 0.31 | 1.4 | 5.4 | 27.3 |
| CC-13B | 23.50 | 65.0 | 0.31 | 1.8 | 7.2 | 36.1 |
| CC-13C | 9.90 | 65.0 | 0.22 | 0.9 | 3.4 | 16.5 |
| CC-13D | 18.80 | 65.0 | 0.25 | 1.5 | 6.2 | 29.2 |
| CC-14 | 4.60 | 65.0 | 0.21 | 0.4 | 1.6 | 7.8 |
| CC-15 | 12.60 | 65.0 | 0.24 | 1.1 | 4.3 | 20.4 |
| CC-16 | 18.30 | 65.0 | 0.30 | 1.2 | 4.6 | 23.6 |
| CC-17 | 25.50 | 65.0 | 0.35 | 1.7 | 6.5 | 32.6 |
| CC-18 | 5.80 | 65.0 | 0.20 | 0.4 | 1.7 | 8.4 |
| CC-19 | 3.70 | 65.0 | 0.25 | 0.3 | 1.2 | 5.8 |
| CC-20 | 39.36 | 65.0 | 0.25 | 3.2 | 12.8 | 61.0 |
| CC-21 | 6.20 | 61.0 | 0.20 | 0.1 | 1.2 | 6.5 |
| CC-22 | 13.80 | 65.0 | 0.25 | 1.1 | 4.5 | 21.4 |
| CC-23 | 5.70 | 64.7 | 0.33 | 0.4 | 1.5 | 7.7 |
| CC-24 | 39.60 | 65.0 | 0.25 | 3.3 | 13.0 | 61.6 |
| CC-25 | 3.50 | 65.0 | 0.23 | 0.3 | 1.2 | 5.7 |
| CC-26 | 16.70 | 65.0 | 0.26 | 1.4 | 5.3 | 25.6 |
| CC-27 | 18.90 | 64.4 | 0.31 | 1.2 | 4.9 | 25.8 |
| CC-28 | 154.60 | 64.4 | 0.63 | 6.5 | 24.7 | 136.3 |

| DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS | | | | |
|--|--|-----------------|-----------------|-------------------|
| Design Point (Ave) | Contributing Basins | Q 2 Yr. Q (cfs) | Q 5 Yr. Q (cfs) | Q 100 Yr. Q (cfs) |
| DP-20 DEV | CC-1A, OS-12 | 3.2 | 14.3 | 88 |
| DP-21 DEV | CC-2A, OS-13 | 2.1 | 10.5 | 62 |
| DP-22 DEV | CC-2B, Release from DP-21 | 3.7 | 16.6 | 92 |
| DP-23 DEV | CC-3, OS-14 | 2.5 | 13.0 | 84 |
| DP-24 DEV | CC-4C (Pre-Dev), CC-5 | 1.9 | 8.4 | 45 |
| TOTAL INFLOW TO FHN POND 12 | CC-4C, CC-8, CC-6 | 4 | 17 | 86 |
| DP-25 DEV | Release from FHN Pond 12 | 0.2 | 0.3 | 45 |
| DP-26 DEV | CC-8, CC-10 | 3.0 | 15.9 | 102 |
| DP-27 DEV | CC-15, CC-20 | 4.3 | 17.2 | 81 |
| DP-28 DEV | CC-13A, OS-15 | 4.6 | 19.9 | 110 |
| DP-29 DEV | CC-13B, CC-13C, Release from DP-28 | 5.8 | 26.6 | 155 |
| DP-30 DEV | CC 18 | 0.4 | 1.7 | 8 |
| DP-31 DEV | CC-19, Release from DP-30 | 0.7 | 2.7 | 14 |
| DP-32 DEV | CC-17, OS-16 | 2.0 | 7.8 | 40 |
| DP-33 DEV | CC-23, CC-24 | 3.6 | 14.4 | 89 |
| DP-34 DEV | CC-16, CC-26, CC-27, CC-28, Release from DP-32 | 8.0 | 23.5 | 168 |

LEGEND

DESCRIPTION

SYMBOL

EXISTING GROUND CONTOUR

6910

PROPOSED FINISHED CONTOUR

6910

BASIN BOUNDARY EAST CHERRY CREEK

MAJOR BASIN BOUNDARY

DESIGN POINT

BASIN IDENTIFIER

AREA IN ACRES

EXISTING DIRECTION OF FLOW

PROPOSED DIRECTION OF FLOW

STORM SEWER

FILING NO. 1 PLAT AREA

CLASSIC CONSULTING ENGINEERS & SURVEYORS

119 N. Cascade Avenue, Suite 200
Colorado Springs, Colorado 80903

FLYING HORSE NORTH PRELIMINARY/FINAL DRAINAGE REPORT

FILING NO. 1 AND PRELIMINARY PLAN DRAINAGE MAP

DESIGNED BY

MAW

SCALE

DATE

10-25-17

DRAWN BY

MAW

(H) 1" = 200'

SHEET

3

OF


4

CHECKED BY

(V) 1" = N/A

JDS NO.

1096-1



Added text
05/09/2018


BASIN SUMMARY - DEVELOPED CONDITIONS

| BASIN (label) | AREA (acres) | COMPOSITE CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|---------------|--------------|--------------|------------------------|---------------|---------------|-----------------|
| OS-16 | 4.50 | 65.0 | 0.24 | 0.4 | 1.5 | 7.2 |
| OS-17 | 15.80 | 65.0 | 0.19 | 1.6 | 5.9 | 27.7 |
| OS-18 | 13.00 | 65.0 | 0.20 | 1.3 | 4.7 | 22.6 |
| CC-11 | 18.60 | 63.1 | 0.21 | 0.9 | 5.0 | 28.1 |
| CC-12 | 12.20 | 65.0 | 0.26 | 1.0 | 3.9 | 18.7 |
| CC-13A | 19.30 | 65.0 | 0.31 | 1.4 | 5.4 | 27.3 |
| CC-13B | 25.50 | 65.0 | 0.31 | 1.8 | 7.2 | 36.1 |
| CC-13C | 9.90 | 65.0 | 0.22 | 0.9 | 3.4 | 16.5 |
| CC-13D | 18.80 | 65.0 | 0.25 | 1.5 | 6.2 | 29.2 |
| CC-14 | 4.60 | 65.0 | 0.21 | 0.4 | 1.6 | 7.8 |
| CC-15 | 12.80 | 65.0 | 0.24 | 1.1 | 4.3 | 20.4 |
| CC-16 | 16.30 | 65.0 | 0.30 | 1.2 | 4.6 | 23.6 |
| CC-17 | 25.00 | 65.0 | 0.35 | 1.7 | 6.5 | 32.8 |
| CC-18 | 5.80 | 65.0 | 0.30 | 0.4 | 1.7 | 8.4 |
| CC-19 | 3.70 | 65.0 | 0.25 | 0.3 | 1.2 | 5.8 |
| CC-20 | 39.30 | 65.0 | 0.25 | 3.2 | 12.9 | 61.0 |
| CC-21 | 6.20 | 61.0 | 0.20 | 0.1 | 1.2 | 8.5 |
| CC-22 | 13.80 | 65.0 | 0.25 | 1.1 | 4.5 | 21.4 |
| CC-23 | 5.70 | 64.7 | 0.33 | 0.4 | 1.5 | 7.7 |
| CC-24 | 39.60 | 65.0 | 0.25 | 3.3 | 13.0 | 61.5 |
| CC-25 | 3.50 | 65.0 | 0.23 | 0.3 | 1.2 | 5.7 |
| CC-26 | 16.70 | 65.0 | 0.26 | 1.4 | 5.3 | 25.6 |
| CC-27 | 18.90 | 64.4 | 0.31 | 1.2 | 4.9 | 25.8 |
| CC-28 | 154.80 | 64.4 | 0.63 | 6.5 | 24.7 | 136.3 |

DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS

| Design Point (label) | Contributing Basins | Q 2 Yr. Q (cfs) | Q 5 Yr. Q (cfs) | Q 100 Yr. Q (cfs) |
|----------------------|--|-----------------|-----------------|-------------------|
| DP-27 DEV | CC-15, CC-20 | 4.3 | 17.2 | 81 |
| DP-28 DEV | CC-13A, OS-15 | 4.6 | 19.8 | 110 |
| DP-29 DEV | CC-13B, CC-13C, Release from DP-28 | 5.8 | 26.6 | 155 |
| DP-30 DEV | CC-18 | 0.4 | 1.7 | 8 |
| DP-31 DEV | CC-19, Release from DP-30 | 0.7 | 2.7 | 14 |
| DP-32 DEV | CC-17, OS-16 | 2.0 | 7.8 | 40 |
| DP-33 DEV | CC-23, CC-24 | 3.6 | 14.4 | 69 |
| DP-34 DEV | CC-16, CC-26, CC-27, CC-28, Release from DP-32 | 6.0 | 23.5 | 168 |

Resolved
05/09/2018



CLASSIC
CONSULTING
ENGINEERS & SURVEYORS

619 N. Cascade Avenue, Suite 200
Colorado Springs, Colorado 80903

FLYING HORSE NORTH
PRELIMINARY/FINAL DRAINAGE REPORT
FLING NO. 1 AND
PRELIMINARY PLAN DRAINAGE MAP

DESIGNED BY: MAA
DRAWN BY: MAA
CHECKED BY: (V) 1" = N/A

SCALE: 1" = 200'
DATE: 10-17-17
SHEET: 4 OF 4
JOB NO: 109611

From the grading plan it looks like the roadside ditch is directed to DP30 culvert. Update subbasin CC-18 to include flows from the western half of Black Forest Rd.

**PRELIMINARY DRAINAGE REPORT
FOR
FLYING HORSE NORTH PRELIMINARY PLAN
AND
FINAL DRAINAGE REPORT
FOR
FLYING HORSE NORTH FILING NO. 1**

**NOVEMBER 2017
Revised April 2018**

Prepared for:
PRI #2 LLC
6385 CORPORATE DRIVE SUITE 200
COLORADO SPRINGS CO 80919
(719) 592-9333

Prepared by:
**CLASSIC CONSULTING ENGINEERS &
SURVEYORS**
619 N. CASCADE AVE SUITE 200
COLORADO SPRINGS CO 80903
(719) 785-0790

Job no. 1096.11
PCD File No. SF-18-001



**PRELIMINARY DRAINAGE REPORT
FLYING HORSE NORTH PRELIMINARY PLAN AND
FINAL DRAINAGE REPORT FOR FLYING HORSE NORTH FILING NO. 1**

DRAINAGE REPORT STATEMENT

ENGINEER'S STATEMENT:

The attached drainage plan and report were prepared under my direction and supervision and are correct to the best of my knowledge and belief. Said drainage report has been prepared according to the criteria established by the County for drainage reports and said report is in conformity with the applicable master plan of the drainage basin. I accept responsibility for any liability caused by any negligent acts, errors, or omissions on my part in preparing this report.

Marc A. Whorton, P.E. Colorado P.E. #37155

Date

OWNER/DEVELOPER'S STATEMENT:

I, the owner/developer, have read and will comply with all of the requirements specified in this drainage report and plan.

Business Name: PRI #2 LLC

By: _____

Title: _____

Address: 6385 Corporate Drive, Suite 200

Colorado Springs, CO 80919

EL PASO COUNTY:

Filed in accordance with the requirements of the Drainage Criteria Manual, Volumes 1 and 2, El Paso County Engineering Criteria Manual and Land Development Code as amended.

Jennifer Irvine, P.E.
County Engineer / ECM Administrator

Date

Conditions:



PRELIMINARY DRAINAGE REPORT FLYING HORSE NORTH PRELIMINARY PLAN AND FINAL DRAINAGE REPORT FOR FLYING HORSE NORTH FILING NO. 1

TABLE OF CONTENTS:

| | |
|-------------------------------------|---------|
| PURPOSE | Page 1 |
| GENERAL DESCRIPTION | Page 1 |
| EXISTING DRAINAGE CONDITIONS | Page 1 |
| PROPOSED DRAINAGE CHARACTERISTICS | Page 3 |
| FILING NO. 1 (BLACK SQUIRREL CREEK) | Page 4 |
| FILING NO. 1 (EAST CHERRY CREEK) | Page 10 |
| PRELIMINARY PLAN | Page 13 |
| FACILITY MAINTENANCE | Page 16 |
| DRAINAGE CRITERIA | Page 16 |
| FLOODPLAIN STATEMENT | Page 18 |
| DRAINAGE AND BRIDGE FEES | Page 18 |
| SUMMARY | Page 20 |
| REFERENCES | Page 21 |

APPENDICES

VICINITY MAP
SOILS MAP (WEB SOIL SURVEY)
F.E.M.A. MAP
HYDROLOGY/HYDRAULIC CALCULATIONS
DETENTION FACILITY CALCULATIONS
DRAINAGE MAPS



PURPOSE

The purpose of this Drainage Report is two-fold: first to identify major drainage corridors within this area and recommend preliminary facilities based on the Preliminary Plan layout and secondly to provide specific final design for the necessary facilities within the Filing No. 1 Final Plat area. These proposed facilities will route all developed storm water runoff to adequate outfall facilities. The drainage improvements proposed in this report that are outside of Filing No. 1 are preliminary in nature and future final drainage reports will be required for these areas. The Filing No. 1 design area within the proposed golf course includes the design of a jurisdictional dam facility. This specific facility design is handled in a separate report and submittal package reviewed and approved by the Colorado Dam Safety Board. However, El Paso County Engineering Staff will have the opportunity to review and approved specific aspects of the facility as well.

GENERAL DESCRIPTION

Flying Horse North is a 1,418 acre site located in all of section 36, township 11 south, range 66 west of the sixth principal meridian, and a portion of sections 30 and 31 township 11 south, range 65 west of the sixth principal meridian. The site is bounded on the north by Hodgen Road and the High Forest Ranch Community, to the south by the Cathedral Pines Subdivision and unplatted county land, to the east by Black Forest Road, and to the west by the State Highway 83 and unplatted county land. The site stretches across 2 existing drainage basins, the Black Squirrel Creek Drainage Basin and East Cherry Creek Drainage Basin. Large lot single family residential and a golf course with a club house are included in the proposed Preliminary Plan for this site. A site specific PUD plan and early grading plan for the golf course and associated private access roads was previously approved in the Fall of 2016. Tree removal, grading and erosion control for the golf course and access roads is currently under construction based on this approval.

The average soil condition reflects Hydrologic Group “B” (Brussett Loam, Elbeth Sandy Loam, Kettle Gravelly Loamy Sand, Peyton Sandy Loam, Peyton Pring Complex, Pring Course Sandy Loam, and Tomah-Crowfoot Loamy Sand) as determined by the “Soil Survey of El Paso County Area,” prepared by the Soil Conservation Service (see map in Appendix).

EXISTING DRAINAGE CONDITIONS

As described in the MDDP for Flying Horse North, this site sits in the upper reaches of both the Black Squirrel Creek and the East Cherry Creek Drainage Basins. There are approximately 540 acres in the Black Squirrel Creek Drainage Basin and 878 acres of area in the East Cherry Creek Drainage Basin. The majority of the Filing No. 1 area will be within the Black Squirrel Creek Basin, however, all required improvements for Filing No. 1 including the golf course within both basins will be discussed below.

Black Squirrel Creek Drainage Basin

The Flying Horse North property is located at the top of the Black Squirrel Creek Drainage Basin. Currently there are corrugated metal culverts within Hwy. 83 to convey flows across the existing roadway. Existing conditions in this basin are largely forested with rolling hills and natural valleys and swales draining offsite to the southwest. This basin has been previously studied in the “Black Squirrel Creek Drainage Basin Planning Study” prepared by URS Consultants, January 1989. All the runoff from the area located in the Black Squirrel Drainage Basin converges at the main channel of the Black Squirrel Creek located on the adjacent property. As a part of the MDDP for Flying Horse North, also prepared by Classic consulting, an existing drainage analysis was performed to confirm allowable release rates at key design points along the project boundary. Offsite flows were recreated from surrounding reports that were previously approved. Drainage Criteria has been updated since these reports have been approved. Flow differences will occur due to the updated drainage criteria. Using these previous reports contributing areas, CN values and time of concentrations, this report along with the MDDP have attempted to recreate offsite flows for use in calculating existing conditions. Currently in the Flying Horse North property boundary within the Black Squirrel Drainage basin there are existing stock ponds with berms that retain existing flows from reaching downstream channels until overtopping. There are no records or design plans for these stock ponds. For this existing condition analysis these ponds were removed from the project model.

Along the northern boundary of the property there are numerous locations where off-site flows come onto the site. The High Forest Ranch development has two detention facilities that release concentrated flows directly onto the property. The on-site downstream corridors from these facilities will remain natural to the greatest extent possible and where required improved to accommodate these existing flows. High Forest Ranch Pond 26 releases flows on-site at the northwest corner of the site that then travel through the site towards an existing 48” CMP at Hwy. 83. High Forest Ranch Pond 16 releases flows on-site approximately 4100 LF east of Hwy. 83. These flows cross the site and continue to travel in a southwest direction through the Shamrock Ranch property. This is the start of the headwaters of the Black Squirrel Creek Drainage Basin with the majority of the existing flows coming from the High Forest Ranch Development.

Section 36 lies approximately 1.5 miles east of Hwy. 83 and this is where the bulk of the Flying Horse North property ownership begins. Several major drainage corridors feeding the Black Squirrel Creek Basin traverse



Section 36 and travel in a southwest direction towards the west edge of the property. The MDDP designates four major design points along this boundary. Multiple detention/storm water quality facilities are planned for these corridors and will be constructed along with future land development. Portions of the Cathedral Pines Development to the south contributes developed flows to this property. These flows will be accommodated in the various on-site facility designs. A smaller on-site basin at the southeast corner of section 36 releases historic flows onto the Cathedral Pines and the Edmonds Subdivision. An on-site detention/storm water quality facility is planned in this corridor to help mitigate development.

East Cherry Creek Drainage Basin

The Palmer Divide traverses the eastern half of section 36 which defines the major basin line between the Black Squirrel Creek and the East Cherry Creek Basins. The vegetation also changes drastically in this area. The majority of the East Cherry Creek Basin contains very little trees and more grazing prairie land and meadows. This area defines the edge of Black Forest. In general, historic flow patterns in this basin travel in a northeasterly direction towards Hodgen Road. The MDDP designates several major design points along the north boundary. Again, multiple detention/storm water quality facilities are planned for these corridors and to be constructed along with future land development. Portions of the Palmer Divide Subdivision and multiple large unplatted properties the south contribute developed flows to this property. These flows will be accommodated in the various on-site facility designs.

PROPOSED DRAINAGE CONDITIONS

The proposed land development within the Flying Horse North Filing No. 1 and future development within the remaining portions of the Preliminary Plan will be 2.5-5 acre large lot residential with associated paved streets and roadside ditches. The 18-hole private Golf Course with a club house site, driving range and maintenance facility is also planned as a part of Filing No. 1. Based on the current El Paso County ECM Section I.7.1.B. and given the size of the lots within this entire development area, stormwater quality is not required to be provided. However, detention/EURV will still be provided in specific locations on-site to limit the on-site development flow release to remain consistent with pre-development conditions within the major drainage corridors. These proposed facilities will aide in limiting any detrimental effects on downstream corridors. At specific areas where the Filing No. 1 development creates concentrated flows into future development areas, temporary sediment basins will be constructed to minimize sediment transfer



downstream and off-site. The Filing No. 1 Final Drainage Report portion of this report will define the permanent facilities providing an Excess Urban Runoff Volume (EURV) in the lower portion of the facility storage volume with an outlet control device. Frequent and infrequent inflows are released at rates approximating undeveloped conditions. This concept provides some mitigation of increased runoff volume by releasing a portion of the increased runoff at a low rate over an extended period of time, up to 72 hours. This means that frequent storms, smaller than the 2 year event, will be reduced to very low flows near or below the sediment carrying threshold value for downstream drainage ways. Also, by incorporating an outlet structure that limits the 100-year runoff to the undeveloped condition rate, the discharge hydrograph for storms between the 2 year and the 100 year event will approximate the hydrograph for the undeveloped conditions and will help effectively mitigate the effects of this development. Again, prior to any land development beyond the Filing No. 1 Final Plat area, additional final drainage reports, final plats and construction plans will be required detailing this criteria.

The following hydrology descriptions will start at the western edge of the Flying Horse North property and move east into the East Cherry Creek Basin, describing the development within the Filing No. 1 area first.

FLYING HORSE NORTH FILING NO. 1

Black Squirrel Creek Drainage Basin

As mentioned previously, Flying Horse North is located in the upper region of the Black Squirrel Creek Drainage Basin. Per the approved DBPS for Black Squirrel Creek, the reaches in this area were proposed to remain as natural as possible. There were no recommendations for detention facilities within the area that is Flying Horse North, but due to current drainage criteria, detention/EURV facilities will be proposed with this development.

High Forest Ranch Detention Pond 26 outfalls onto the property at the very northwest corner of the site. These existing flows will continue to enter the site and travel within the natural channel towards the existing 48" CMP culvert crossing at Hwy. 83. Drainage easements across the proposed lots in this area will be provided on the final plat. The existing stock pond within lots 2 and 3 will be removed with grading of the road in this area. Tract B is platted in order to provide a detention/EURV facility for the lots and public road in this area. This facility will be constructed with Filing No. 1 with ownership and maintenance by the Flying Horse North HOA.



Design Point 1 ($Q_2 = 2$ cfs $Q_5 = 3$ cfs, $Q_{100} = 11$ cfs) represents the existing off-site and on-site developed flows from Basins OS-1A and BS-2B. The combined flow from these basins travel to a low point just east of Stagecoach Road where a proposed 24" RCP culvert will be installed to convey these flows under the road. (See Appendix for culvert design)

Design Point 2 ($Q_2 = 3$ cfs $Q_5 = 9$ cfs, $Q_{100} = 35$ cfs) represents flows from DP 1 and Basin BS-4. These combined flows are collected at a low point where a proposed 30" RCP culvert will be installed to replace the temporary sediment basin installed with early grading. (See Appendix for culvert design)

The total developed flows entering **Detention Facility 1** including Basin BS-1A equal (**$Q_2 = 4$ cfs $Q_5 = 7$ cfs, $Q_{100} = 38$ cfs**). These combined flows will travel in the natural drainage corridor across lot 1 within a drainage easement and enter the detention facility. The following describes the design of this facility (See Appendix for UD Detention pond design sheets):

Detention Pond 1 (Full Spectrum – see multiple storm release data below)

0.43 Ac.-ft. EURV required

0.50 Ac.-ft. EURV design with 3:1 max. slopes

1.1 Ac.-ft. 100-yr. Storage

Total In-flow: $Q_2 = 4$ cfs, $Q_5 = 7$ cfs, $Q_{100} = 38$ cfs

Pond Design Release: $Q_2 = 0.1$ cfs, $Q_5 = 0.2$ cfs, $Q_{100} = 21$ cfs

Pre-development Release: $Q_2 = 0.2$ cfs, $Q_5 = 0.4$ cfs, $Q_{100} = 23$ cfs

(Ownership and maintenance by the Flying Horse North HOA)

The downstream corridor from this proposed facility shows no indication of erosion at this time and is anticipated to continue to adequately handle the detained developed flows from this portion of the subdivision.

Design Point 4 ($Q_2 = 3$ cfs $Q_5 = 4$ cfs, $Q_{100} = 8$ cfs) represents existing and developed flows from Basin BS-2 (north side of Stagecoach Rd.) These flows will travel in a side road ditch towards Hwy. 83. A temporary sediment basin will be installed during construction of this portion of the roadway. This



development will be required to provide improvements to this intersection and Hwy. 83 per the site traffic study. Upon review/approval from CDOT, these improvements will be constructed along with final design of drainage at this intersection which will include the relocation of the dual 18" ERCP culverts and the removal of the temporary sediment basin.

Design Point 5 ($Q_2 = 2$ cfs $Q_5 = 4$ cfs, $Q_{100} = 13$ cfs) represents existing and developed flows from Basins OS-1B and BS-2A (south side of Stagecoach Rd.) These flows will travel in a side road ditch towards Hwy. 83. A temporary sediment basin will be installed during construction of this portion of the roadway. Upon review/approval from CDOT, these improvements will be constructed along with final design of drainage at this intersection and the removal of the temporary sediment basin at this location.

Design Point 6 ($Q_2 = 1$ cfs $Q_5 = 3$ cfs, $Q_{100} = 15$ cfs) represents flows from Basins OS-2 and BS-3. These combined flows travel via the side road ditch along the east side of the road and then around the cul-de-sac, through lot 3 within a drainage easement towards the existing natural channel to the west. These flows then combine with Basin BS-1B and continue to travel in the existing natural channel towards the existing downstream 48" CMP culvert. **Design Point 3 ($Q_2 = 1$ cfs $Q_5 = 6$ cfs, $Q_{100} = 39$ cfs)** then represents the total flow from this site leaving the property at this location. The pre-development on-site flow at this location equals $Q_2 = 1$ cfs $Q_5 = 5$ cfs, $Q_{100} = 41$ cfs. Thus, the downstream facilities will not see a significant change in flows.

Design Point 7 ($Q_2 = 2$ cfs $Q_5 = 8$ cfs, $Q_{100} = 38$ cfs) represents existing and developed flows from Basins OS-3 and BS-5. These flows will travel as sheet flow towards the low point where dual 30" RCP culverts will be installed under Stagecoach Road to replace the temporary sediment basin installed with early grading. (See Appendix for culvert design)

High Forest Ranch Detention Pond 16 outfalls onto the property just upstream of Design Point 8. These existing flows will continue to enter the site and travel through proposed triple 48" RCP culverts under Stagecoach Road. (See Appendix for culvert design) **Design Point 8 ($Q_2 = 21$ cfs $Q_5 = 70$ cfs, $Q_{100} = 284$ cfs)** represents the existing and developed flows exiting the property and continuing south within the natural channel on the Shamrock Ranch property. These flows remain consistent with the historic flows at this location.



Design Point 9 ($Q_2 = 1$ cfs $Q_5 = 5$ cfs, $Q_{100} = 23$ cfs) represents existing flows from Basins OS-7 and BS-12. These combined flows are collected at a low point where proposed dual 24" RCP culverts will be installed to replace the temporary sediment basin installed with early grading. (See Appendix for culvert design) **Design Point 10 ($Q_2 = 11$ cfs $Q_5 = 32$ cfs, $Q_{100} = 143$ cfs)** represents existing and developed flows from Basins OS-8, OS-10, OS-11, BS-13 and BS-14. These flows will travel to the low point at this location where dual 42" RCP culverts will be installed for the crossing of Stagecoach Road. (See Appendix for culvert design)

Design Point 11 ($Q_2 = 5$ cfs $Q_5 = 12$ cfs, $Q_{100} = 36$ cfs) represents developed flow from Basin BS-16. These flows will travel to the low point at this location where dual 24" RCP culverts will be installed for the crossing of the road. (See Appendix for culvert design) **Design Point 12 ($Q_2 = 4$ cfs $Q_5 = 11$ cfs, $Q_{100} = 44$ cfs)** represents the combined developed flow from Basins BS-16 and BS-15. These flows will travel to the low point at this location where a 36" RCP culvert and storm system will be installed to route the collected flows directly into Detention Pond 4 at the south end. (See Appendix for culvert design)

The total developed flows entering **Detention Facility 4**, including Basins OS-9 and BS-17 equal (**$Q_2 = 10$ cfs $Q_5 = 16$ cfs, $Q_{100} = 217$ cfs**). The major flows enter the facility at the north end through a rock chute. (See Appendix for rock chute and pond design) The following describes the design of this facility: (See Appendix for UD Detention pond design sheets):

Detention Pond 4 (Full Spectrum – see multiple storm release data below)

0.99 Ac.-ft. EURV required

1.05 Ac.-ft. EURV design with 4:1 max. slopes

5.1 Ac.-ft. 100-yr. Storage

Total In-flow: $Q_2 = 10$ cfs, $Q_5 = 16$ cfs, $Q_{100} = 217$ cfs

Pond Design Release: $Q_2 = 0.3$ cfs, $Q_5 = 0.4$ cfs, $Q_{100} = 142$ cfs

Pre-development Release: $Q_2 = 1.5$ cfs, $Q_5 = 2.5$ cfs, $Q_{100} = 152$ cfs

(Ownership and maintenance by the Flying Horse North HOA)

The downstream corridor from this proposed facility shows little indication of erosion at this time and is anticipated to continue to adequately handle the detained developed flows from this portion of the subdivision. In addition, we have been coordinating with the adjacent property owner and his engineering



consultant on this specific corridor and will continue to do so until the on-site detention facility construction is complete and all disturbed areas are re-established.

Design Point 14 ($Q_2 = 4$ cfs $Q_5 = 12$ cfs, $Q_{100} = 56$ cfs) represents the developed flow from Basin BS-18. These flows will travel to the low point at this location where three 24" RCP culverts will be installed to cross under the road. (See Appendix for culvert design) These flows then enter Basin OS-23 through a drainage easement on the rear of lot 65 and continue to travel towards DP-16. **Design Point 15 ($Q_2 = 2$ cfs $Q_5 = 5$ cfs, $Q_{100} = 15$ cfs)** represents the developed flow from Basin BS-19. These flows will travel to the low point at this location where dual 18" RCP culverts will be installed to cross under the road. (See Appendix for culvert design) These flows then enter Basin OS-22 through a drainage easement across lots 60 and 61 and continue to travel towards the golf course.

Basins BS-20, BS-21, BS-22, BS-23 and BS-23A are relatively large basins that contain both Filing 1 lots, much of the golf course but also future lots that will remain undeveloped at this time. However, these basins all ultimately travel in a southwesterly direction towards the proposed Detention Facility 8. This report analyzes both the "Filing 1 Only" condition as well as the "full build-out condition" in the design of this detention facility. With the development of Filing 1, Detention Facility 8 will be sized and graded for the ultimate design accounting for the future lot development. The outlet structure and emergency overflow weir will also be designed for the ultimate condition. However, we will provide two orifice plate designs for the outlet box. The initial plate will be constructed that will handle the proper release for the Filing 1 development only. Upon the next phase of lot development within these basins (BS-20, BS-21, BS-22, BS-23 and BS-23A) the ultimate plate will be installed to replace this initial plate design. No further changes to the outlet structure or pond will need to take place. Thus, the following describes the two scenarios:

Full Build-out Design (accounting for future lot development)

Design Point 16 ($Q_2 = 25$ cfs $Q_5 = 78$ cfs, $Q_{100} = 362$ cfs) represents the total developed flows from Basins BS-18 thru BS-23 with the fully developed golf course and lots in Filing 1 and the future phases. These flows travel to the low point at this location where dual 60" RCP culverts will be installed to cross under the road. (See Appendix for culvert design) These flows represent the major portion of the flows entering Detention Facility 8 with the remaining flows coming from Basin OS-23A.



The total developed flow entering **Detention Facility 4** includes Basin BS-23A. The following describes the design of this facility: (See Appendix for UD Detention pond – **Full Build-out** design sheets):

Detention Pond 8 (Full Spectrum – see multiple storm release data below)

2.40 Ac.-ft. EURV required

2.45 Ac.-ft. EURV design with 4:1 max. slopes

9.32 Ac.-ft. 100-yr. Storage

Total In-flow: $Q_2 = 28$ cfs, $Q_5 = 85$ cfs, $Q_{100} = 383$ cfs

Pond Design Release: $Q_2 = 0.8$ cfs, $Q_5 = 1.0$ cfs, $Q_{100} = 253$ cfs

Pre-development Release: $Q_2 = 2.6$ cfs, $Q_5 = 4.5$ cfs, $Q_{100} = 274$ cfs

(Ownership and maintenance by the Flying Horse North HOA)

Filing 1 Only Design (accounting for golf course and Filing 1 lot development)

Under this scenario, only the golf course and Filing 1 lots are developed and Basins BS-20, BS-21, BS-22, BS-23 and BS-23A have been adjusted to account for only this initial phase of development. The following describes the facility requirements for this design: (See Appendix for UD Detention pond – **Filing 1 Only** design sheets):

****Detention Pond 8 (Full Spectrum – see multiple storm release data below)**

1.13 Ac.-ft. EURV required

2.45 Ac.-ft. EURV design with 4:1 max. slopes

7.76 Ac.-ft. 100-yr. Storage

Total In-flow: $Q_2 = 9$ cfs, $Q_5 = 14$ cfs, $Q_{100} = 301$ cfs

Pond Design Release: $Q_2 = 0.4$ cfs, $Q_5 = 0.5$ cfs, $Q_{100} = 219$ cfs

Pre-development Release: $Q_2 = 2.2$ cfs, $Q_5 = 3.9$ cfs, $Q_{100} = 237$ cfs

(Ownership and maintenance by the Flying Horse North HOA)

**Please note that all facility design remains the same as the Full Build-out scenario except for the different orifice plate.



The downstream corridor from this proposed facility shows little indication of erosion at this time and is anticipated to continue to adequately handle the detained developed flows from this portion of the subdivision. In addition, we have been coordinating with the adjacent property owner and his engineering consultant on this specific corridor and will continue to do so until the on-site detention facility construction is complete and all disturbed areas are re-established.

Basin BS-24 ($Q_2 = 0.6$ cfs $Q_5 = 3$ cfs, $Q_{100} = 18$ cfs) represents sheet flow from three residential lots within Filing No. 1 that will continue to direct release off-site. However, portions of this historic basin area will be routed into Flying Horse North Pond 8, therefore the developed flows from this basin do not significantly change from the pre-development condition. The pre-development flows from the historic basin area equal **$Q_2 = 0.2$ cfs $Q_5 = 2$ cfs, $Q_{100} = 18$ cfs.** Also, given the lot size, no water quality is required.

FLYING HORSE NORTH FILING NO. 1

East Cherry Creek Drainage Basin

The following basins are still tributary to the Filing No. 1 platting area but are within the East Chery Creek Drainage Basin:

Design Point 24 ($Q_2 = 2$ cfs $Q_5 = 8$ cfs, $Q_{100} = 45$ cfs) represents developed flows from Basins CC-4C and CC-5. Basin CC-4C represents the future golf course clubhouse site. Upon future development of this site a site specific detention/SWQ facility will be installed. This future facility will release into the side road ditch on the west side of Allen Ranch Road and travel in a northerly direction. The side road ditch along this stretch of Allen Ranch Road and the south side of Old Stagecoach Road will be sized to handle these flows. The 100-yr. emergency overflow from this future facility will also be into the side road ditch of Allen Ranch Road and not towards any residential lots. For ultimate downstream design purposes this basin is assumed to release pre-development flows. These flows will travel towards Design Point 24 where a 36" RCP culvert is sized to handle the fully developed flows at this location. (See Appendix for culvert design)



The total developed flows entering **Detention Facility 12**, including Basin CC-6 equals (**$Q_2 = 6$ cfs $Q_5 = 9$ cfs, $Q_{100} = 85$ cfs**). The following describes the design of this facility:

(See Appendix for UD Detention pond design sheets):

Detention Pond 12 (Full Spectrum – see multiple storm release data below)

0.66 Ac.-ft. EURV required

0.75 Ac.-ft. EURV design with 4:1 max. slopes

2.69 Ac.-ft. 100-yr. Storage

Total In-flow: $Q_2 = 6$ cfs, $Q_5 = 9$ cfs, $Q_{100} = 85$ cfs

Pond Design Release: $Q_2 = 0.2$ cfs, $Q_5 = 0.3$ cfs, $Q_{100} = 45$ cfs

Pre-development Release: $Q_2 = 0.5$ cfs, $Q_5 = 0.9$ cfs, $Q_{100} = 55$ cfs

(Ownership and maintenance by the Flying Horse North HOA)

The downstream corridor from this proposed facility shows no indication of erosion at this time and is anticipated to continue to adequately handle the detained developed flows from this portion of the subdivision.

Design Point 25 ($Q_2 = 0.2$ cfs $Q_5 = 0.3$ cfs, $Q_{100} = 45$ cfs) then represents the total flow leaving the site at this location. The pre-development flow at this location equals **$Q_2 = 0.5$ cfs $Q_5 = 0.9$ cfs, $Q_{100} = 55$ cfs**. Thus, the downstream facilities will not see a significant change in flows.

Basins OS-12, OS-13, OS-14, CC-1A, CC-1B, CC-2A, CC-2B, CC-2C, CC-3, CC-4A, CC-4B and CC-9 are all tributary to the proposed Flying Horse North Pond 13. Nearly all the proposed residential lots within these basins are part of future development outside of Filing No. 1 platting. The only structure associated with Filing No. 1 development is the pond embankment/outlet structure crossing Stagecoach Road. However, this facility has been classified by the Colorado Dam Safety Branch (DSB) as a low-hazard, jurisdictional facility. As such, a separate Design Report including hydrology/hydraulic design and embankment/structure design has been prepared for DSB and El Paso County review and approval. Please reference this report for the required detention/SWQ design for this facility.

Design Point 26 ($Q_2 = 3$ cfs $Q_5 = 16$ cfs, $Q_{100} = 102$ cfs) represents the full build-out developed flows from Basins CC-8 and CC-10. Basin CC-8 represents future residential lots and CC-10 mostly future



passive park area. These flows will continue to sheet flow towards the low-point where a 48" RCP culvert is sized to handle the fully developed flows at this location. (See Appendix for culvert design) After crossing Stagecoach Road, these flows will continue to flow directly into the existing stock pond just north of the roadway. This facility will provide sediment control for the small developed roadway area. Upon future development and platting of the lots planned within these basins, this stock pond will be formally designed into a detention facility.

Basin CC-15 ($Q_2 = 1$ cfs $Q_5 = 4$ cfs, $Q_{100} = 20$ cfs) represents the full build-out developed flows from the future residential lots tributary to this basin. These flows will continue to sheet flow towards the low-point where a 30" RCP culvert is sized to handle the fully developed flows at this location. (See Appendix for culvert design) A downstream sediment basin will be installed to provide sediment control for the small developed roadway area.

Basin CC-16 ($Q_2 = 1$ cfs $Q_5 = 5$ cfs, $Q_{100} = 24$ cfs) represents the full build-out developed flows from the future residential lots tributary to this basin. These flows will continue to sheet flow towards the low-point at the southwest corner of Old Stagecoach Road and Rubble Drive where a 24" RCP culvert is sized to handle the fully developed flows at this location. (See Appendix for culvert design) A downstream sediment basin will be installed to provide sediment control for the small developed roadway area.

Design Point 30 ($Q_2 = 0.7$ cfs $Q_5 = 2$ cfs, $Q_{100} = 10$ cfs) represents the full build-out developed flows from Basin CC-18. This Basin represents future residential lots. The flows will continue to sheet flow towards the low-point where a 24" RCP culvert is sized to handle the fully developed flows at this location. (See Appendix for culvert design) A downstream sediment basin will be installed to provide sediment control for the small developed roadway area.

Design Point 31 ($Q_2 = 0.9$ cfs $Q_5 = 3$ cfs, $Q_{100} = 15$ cfs) represents the full build-out developed flows from Basin CC-19 and the upstream release from DP-30. This Basin represents future residential 5 ac. lots. The flows will continue to sheet flow within a proposed drainage easement towards the existing low-point where an existing 24" CMP culvert will adequately handle the fully developed flows at this location.



Design Point 32 ($Q_2 = 2$ cfs $Q_5 = 8$ cfs, $Q_{100} = 40$ cfs) represents the full build-out developed flows from Basins OS-16 and CC-17. Basin CC-17 represents future residential lots and OS-16 unplatted, 5-ac. zoned residential property. These flows will continue to sheet flow towards the low-point where a 36" RCP culvert is sized to handle the fully developed flows at this location. (See Appendix for culvert design) A downstream sediment basin will be installed to provide sediment control for the small developed roadway area.

FLYING HORSE NORTH PRELIMINARY PLAN (Future Platting)

Black Squirrel Creek Drainage Basin

The following basins are in the Black Squirrel Creek Drainage Basin but are not a part of Filing 1 lot development. These areas will require future final drainage report(s) upon future lot development.

Design Point 18 ($Q_2 = 5$ cfs $Q_5 = 22$ cfs, $Q_{100} = 115$ cfs) represents developed flows from Basins BS-28, BS-29, BS-30 and OS-18. Portions of basins BS-28 and BS-29 include golf course development taking place with Filing No. 1. However, the majority of these basins include forested future residential lots with basin OS-18 being existing 2.5 ac. minimum lots. Future developed flows will be routed to this location where a future detention facility will be installed. This facility will be sized to meet EURV requirements and release pre-development flow quantities into the future side road ditch and through future drainage easements towards the future detention facility at Design Point 19. These future facilities will be further analyzed as ponds in series and emergency overflow paths well defined with the future final drainage report. In the interim, with only the golf course construction, a temporary sediment basin located within the future roadway in basin BS-28 will be installed to provide sediment control from the developed golf course area.

Design Point 19 ($Q_2 = 4$ cfs $Q_5 = 17$ cfs, $Q_{100} = 126$ cfs) represents developed flows from Basins BS-27 and OS-17. These basins include forested future residential lots with basin OS-17 being existing 2.5 ac. minimum lots. Future developed flows will be routed to this location where a future detention facility will be installed to meet EURV requirements and release pre-development flow quantities. Both of these future facilities will be constructed in tracts with ownership and maintenance by the Flying Horse North HOA.



Basin BS-26 ($Q_2 = 0.04$ cfs $Q_5 = 0.4$ cfs, $Q_{100} = 3$ cfs) represents sheet flow from the extreme rear portion of a future residential lot. This area of the lot will likely not be built upon, therefore not significantly changing the drainage conditions from the pre-development condition. The pre-development flow from the historic basin area equals **$Q_2 = 0.04$ cfs $Q_5 = 0.4$ cfs, $Q_{100} = 3$ cfs**. Also, given the lot size, no water quality is required.

Basins BS-31 ($Q_2 = 0.3$ cfs $Q_5 = 2$ cfs, $Q_{100} = 12$ cfs), BS-32 ($Q_2 = 0.3$ cfs $Q_5 = 2$ cfs, $Q_{100} = 9$ cfs) and BS-33 ($Q_2 = 0.8$ cfs $Q_5 = 3$ cfs, $Q_{100} = 15$ cfs) represent smaller basins that will continue to sheet flow off-site to the south. These basins represent some golf course development and multiple future residential lots. Given the lot size, no water quality is required. However, permanent sediment basins will be installed downstream of the golf course development to provide sediment control. Developed flows released from these basins will not be significantly different than the pre-development flows.

East Cherry Creek Drainage Basin

The following basins are not tributary to the Filing No. 1 platting area but are within the East Chery Creek Drainage Basin and planned for future residential lot development.

Design Point 28 ($Q_2 = 5$ cfs $Q_5 = 20$ cfs, $Q_{100} = 110$ cfs) represents the full build-out developed flows from Basins OS-13 and CC-13A. Basin CC-13A represents future residential lots and OS-13 platted, 5-ac. zoned residential property. These flows will continue to sheet flow towards the low-point where a future culvert will be installed to handle the fully developed flows at this location. The flows are then conveyed in the natural channel towards Design Point 29.

Design Point 29 ($Q_2 = 6$ cfs $Q_5 = 27$ cfs, $Q_{100} = 155$ cfs) represents the full build-out developed flows from Basins CC-13B, CC-13C and release from DP-28. These basins represent future residential lots. At this location, a future detention facility will be installed to meet EURV requirements and release pre-development flow quantities. This future facility will be constructed in a tract with ownership and maintenance by the Flying Horse North HOA.



Basin CC-13D ($Q_2 = 2$ cfs $Q_5 = 6$ cfs, $Q_{100} = 29$ cfs) represents future residential lots that will continue to sheet flow off-site. Given the lot size, no water quality is required. However, a permanent sediment basin will be installed just prior to release off-site to provide sediment control. Developed flows released from this basin will not be significantly different than the pre-development flows.

Basin CC-14 ($Q_2 = 0.4$ cfs $Q_5 = 2$ cfs, $Q_{100} = 8$ cfs) represents sheet flow from the rear portion of two future residential lots. The majority of this area is not anticipated to be developed, therefore not significantly changing the drainage conditions from the pre-development condition. Also, given the lot size, no water quality is required.

Design Point 27 ($Q_2 = 4$ cfs $Q_5 = 17$ cfs, $Q_{100} = 81$ cfs) represents the full build-out developed flows from the previously described basin CC-15 and CC-20. These basins represent future residential lots. At this location, a future detention facility will be installed to meet EURV requirements and release pre-development flow quantities. This future facility will be constructed in a tract with ownership and maintenance by the Flying Horse North HOA.

Basins CC-21 ($Q_2 = 0.1$ cfs $Q_5 = 1$ cfs, $Q_{100} = 9$ cfs) and CC-22 ($Q_2 = 1$ cfs $Q_5 = 5$ cfs, $Q_{100} = 21$ cfs) represent future residential 5 ac. lots and park area that will continue to sheet flow off-site. Given the lot size, no water quality is required. However, a permanent sediment basin will be installed just prior to release off-site to provide sediment control. Developed flows released from this basin will not be significantly different than the pre-development flows.

Basins CC-23 ($Q_2 = 0.4$ cfs $Q_5 = 1$ cfs, $Q_{100} = 8$ cfs) and CC-24 ($Q_2 = 3$ cfs $Q_5 = 13$ cfs, $Q_{100} = 62$ cfs) represent future 5 ac. residential lots that will continue to sheet flow off-site. Given the lot size, no water quality is required. Given that the proposed lots are planned for 5 ac. residential, the developed flows released from this basin will not be significantly different than the pre-development flows. However, multiple permanent sediment basins may be installed just prior to release off-site to provide sediment control. This basin also contains a portion of the adjacent Franktown/Parker Reservoir emergency spillway crossing two proposed lots. This existing facility, which doesn't appear to be within any existing easement, will be further analyzed with a final drainage report for this area. Appropriate drainage easements may be provided at time of final plating.



Basin CC-25 ($Q_2 = 0.3$ cfs $Q_5 = 1$ cfs, $Q_{100} = 6$ cfs) represents a small portion of two future residential 5 ac. lots that will continue to sheet flow off-site. Given that the proposed lots are planned for 5 ac. residential, the developed flows released from this basin will not be significantly different than the pre-development flows.

Design Point 34 ($Q_2 = 6$ cfs $Q_5 = 24$ cfs, $Q_{100} = 168$ cfs) represents the full build-out developed flows from Basins CC-26, CC-27, CC-28, release from CC-16 and release from DP-32. These basins represent future residential lots and park area. At this location, a future detention facility will be installed and likely replace the existing stock pond to meet EURV requirements and release pre-development flow quantities. The downstream existing culvert under Hodgen Road will be further analyzed with future final drainage reports. This future facility will be constructed in a tract with ownership and maintenance by the Flying Horse North HOA.

FACILITY MAINTENANCE

All proposed drainage structures within the platted County ROW will be owned and maintained by El Paso County. All proposed drainage structures within easements or tracts will be owned and maintained by the Flying Horse North HOA of Golf Course owner.

DRAINAGE CRITERIA

Hydrologic calculations were performed using the City of Colorado Springs/El Paso County Drainage Criteria Manual, revised in November 1991 and October 1994 with County adopted Chapter 6 and Section 3.2.1 of Chapter 13 of the City of Colorado Springs/El Paso County Drainage Criteria Manual as revised in May 2014. Detention storage and storm sewer conveyance to Black Squirrel Creek Drainage Basin was established with the Black Squirrel DBPS, previously referenced. The IDF curves from Figure 6-5 of the City of Colorado Springs/El Paso County DCM was used to estimate storm water runoff anticipated from design storms for the 2 year, 5 year and 100 year recurrence interval. (See Appendix)



Revise based on the 4-step process defined in Appendix I Section I.7.2.

Step 1: Employ Runoff Reduction Practices

Step 2: Stabilized Drainageways

Step 3: Provide WQCV

Step 4: Consider Need for Industrial and Commercial BMPs

DCM requires the Four Step Process for receiving water volumes, treating the water quality capture volume (WQCV), long-term source controls. The Four Step Process pertains to storm events, as opposed to larger storms for which drainage implementation of these four steps helps to achieve storm water

permit requirements. This site adheres to this **Four Step Process** as follows:

1. **Employ Runoff Reduction Practices:** Development of project site is proposed large lot single family residential (2.5 ac. min.) with homes and associated landscaping along with a private golf course. Proposed impervious areas (roof tops, patios) will sheet flow across landscaped ground, through open space areas and across the golf course to slow runoff and increase time of concentration prior to being conveyed to the proposed public streets. This will minimize directly connected impervious areas within the project site.
2. **Implement BMP's that provide a Water Quality Capture Volume with slow release:** Runoff from this development will be treated through capture and slow release of the WQCV in multiple permanent Extended Detention Basins designed per current El Paso County drainage criteria.
3. **Stabilize Drainageways:** This site will utilize roadside ditches and culvert crossings throughout the site. These facilities will then direct the on-site development flows to the multiple detention/SWQ ponds mentioned above, designed to release at or below historic rates into Black Squirrel and East Cherry Creek. Based upon the proposed reduction in released flows compared to the pre-developed flows, no impact to downstream drainageways is anticipated.
4. **Implement Site Specific and Other Source Control BMP's:** A site specific storm water quality and erosion control plan and narrative was previously approved for this development in October 2016 (PUD-16-002). Details such as site specific source control construction BMP's as well as permanent BMP's were detailed in this plan and narrative to protect receiving waters. Much of these BMP's are currently constructed and being maintained as the majority of the development has been graded and erosion control methods employed.



FLOODPLAIN STATEMENT

A small portion of the Preliminary Plan (future lots not platted at this time) is located within a floodplain as determined by the Flood Insurance Rate Maps (F.I.R.M.) Map Number 08041C 0295F, 0841C 0315F, 04081C 0325F effective date, March 17, 1997 (See Appendix). However, no portion of property proposed to be platted with Filing No. 1 is within the floodplain.

DRAINAGE AND BRIDGE FEES

FLYING HORSE NORTH FILING NO. 1

The East Cherry Creek Basin does not currently have a Drainage Basin Fee. However, the following fees for the Filing No. 1 platted area within the Black Squirrel Creek Basin are due prior to platting:

The fees are calculated using the following impervious acreage method approved by El Paso County. The acreage for Flying Horse Filing No. 1 within the Black Squirrel Creek Basin is 342.7 acres. This total area is broken into two uses: 2.5 ac. lots (including roads and tracts) and golf course. The 2.5 ac. lot area equals 234.4 acres and the golf course area equals 108.3 acres. Thus, the percent imperviousness for this subdivision is calculated as follows (See Figure 1.1 for Basin Area Exhibit):

2.5 ac. lots (incl. roads and tracts)

(Per El Paso County Percent Impervious Chart: 11%)

234.4 Ac. x 11% = **25.78 Impervious Ac.**

25% reduction for 2.5 ac. lots

25.78 Imp. ac. x .75% = **19.34 Impervious Ac.**

Golf Course Development

(Per El Paso County Percent Impervious Chart for greenbelts: 2%)

108.3 Ac. x 2% = **2.17 Impervious Ac.**

25% reduction for golf course development

2.17 Imp. ac. x .75% = **1.62 Impervious Ac.**

Total Impervious Acreage for Filing 1: 20.96 Imp. Ac.



The following calculations are based on the 2018 drainage/bridge fees for the Black Squirrel Creek Drainage Basin:

Staff will be discussing this request with the County Engineer. The criteria noted "may be reimbursed", not "shall be reimbursed".

FILING 1 FEE TOTALS (prior to reduction):

Bridge Fees

$$\text{\$ 492.00} \times 20.96 \text{ Impervious Ac.} = \text{\$ } \underline{10,312.32}$$

Drainage Fees

$$\text{\$ 7,808.00} \times 20.96 \text{ Impervious Ac.} = \text{\$ } \underline{163,655.68}$$

Per the ECM 3.10.4, this development requests a reduction of drainage fees based on the three on-site full spectrum detention/SWQ facilities proposed to be constructed with Filing 1. The following facilities within the Black Squirrel Creek basin seem to meet the criteria for this reduction:

| | | | |
|------------------|--------------------------|--------------------|----------------------|
| Detention Pond 1 | 1.1 ac-ft. full spectrum | \$ 24,448 x 50% = | \$ 12,224.00 |
| Detention Pond 4 | 4.5 ac-ft. full spectrum | \$ 130,270 x 50% = | \$ 65,135.00 |
| Detention Pond 8 | 9.4 ac-ft. full spectrum | \$ 111,320 x 50% = | \$ 55,660.00 |
| Total Reduction | | | <u>\$ 133,019.00</u> |

FILING 1 FEE TOTALS:

Bridge Fees

$$\text{\$ 492.00} \times 20.96 \text{ Impervious Ac.} = \text{\$ } \underline{10,312.32}$$

Drainage Fees

$$\text{\$ 163,655.68} - 133,019.00 = \text{\$ } \underline{30,636.68}$$



SUMMARY

This proposed development remains consistent with the previously approved Flying Horse North MDDP and Preliminary Drainage Report for Flying Horse North (Golf Course grading and private access roads). The proposed storm facilities have been sized to adequately handle the 100-yr. developed flows. All proposed detention facilities meet current criteria and provide full spectrum design. Upon future development outside of Filing No. 1, final drainage reports will be required finalizing final design of the proposed future drainage facilities. The proposed development will not adversely impact surrounding developments.

PREPARED BY:

Classic Consulting Engineers & Surveyors, LLC



Marc A. Whorton, P.E.
Project Manager

Maw/109611/reports/109611PDR.doc




REFERENCES

1. City of Colorado Springs/County of El Paso Drainage Criteria Manual, as revised in November 1991 and 1994 with County adopted Chapter 6 and Section 3.2.1 of Chapter 13 of the City of Colorado Springs/El Paso County Drainage Criteria Manual as revised in May 2014.
2. “Master Development Drainage Plan for Flying Horse North”, Classic Consulting, dated September 2016.
3. “Preliminary Drainage Report for Flying Horse North (Golf Course Grading and Private Access Roads)”, Classic Consulting, dated September 2016.
4. “Final Drainage Report High Forest Ranch Filing No. 1” JR Engineering, dated March 2001.
5. “Final Drainage Report for High Forest Ranch Filing No. 2 and High Forest Ranch Filing No. 3” Classic Consulting Engineers and Surveyors dated May 2001.
6. “Final Drainage Report and Plan for Cathedral Pines Subdivision Filing No. 2,” Leigh Whitehead & Associates, dated March 2005.
7. “Final Drainage Report and Plan for Cathedral Pines Subdivision Filing No. 3,” Stillwater Engineering, dated July 2006.
8. “Black Squirrel Creek Drainage Basin Planning Study,” URS Corporation, dated August 1987.
9. “Final Drainage Report for Country View Estates” Associated Design Professionals Inc, dated October 1998.
10. “Urban Storm Drainage Criteria Manual Volume 1, 2 & 3” Urban Drainage and Flood Control District, dated January 2016.



APPENDIX

VICINITY MAP




VICINITY MAP


NTS

SOILS MAP (WEB SOIL SURVEY)

Hydrologic Soil Group—El Paso County Area, Colorado



Map Scale: 1:31,300 if printed on A landscape (11" x 8.5") sheet.



Map projection: Web Mercator Corner coordinates: WGS84 Edge tics: UTM Zone 13N WGS84




**Natural Resources
Conservation Service**

Web Soil Survey
National Cooperative Soil Survey

3/21/2016
Page 1 of 4

MAP LEGEND

Area of Interest (AOI)









 Area of Interest (AOI)

Soils

Soil Rating Polygons





 A
 A/D
 B
 B/D
 C
 C/D
 D
 Not rated or not available

Soil Rating Lines


 A
 A/D
 B
 B/D
 C
 C/D
 D
 Not rated or not available

Soil Rating Points



 A
 A/D
 B
 B/D

 C
 C/D
 D
 Not rated or not available


Water Features

 Streams and Canals

Transportation

 Rails
 Interstate Highways
 US Routes
 Major Roads
 Local Roads

Background

 Aerial Photography

MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:24,000.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service
 Web Soil Survey URL: <http://websoilsurvey.nrcs.usda.gov>
 Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: El Paso County Area, Colorado
 Survey Area Data: Version 13, Sep 22, 2015

Soil map units are labeled (as space allows) for map scales 1:50,000 or larger.

Date(s) aerial images were photographed: Apr 15, 2011—Sep 22, 2011

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.

Hydrologic Soil Group

| Hydrologic Soil Group— Summary by Map Unit — El Paso County Area, Colorado (CO625) | | | | |
|--|--|--------|----------------|----------------|
| Map unit symbol | Map unit name | Rating | Acres in AOI | Percent of AOI |
| 14 | Brussett loam, 1 to 3 percent slopes | B | 19.6 | 1.1% |
| 15 | Brussett loam, 3 to 5 percent slopes | B | 7.0 | 0.4% |
| 26 | Elbeth sandy loam, 8 to 15 percent slopes | B | 615.7 | 33.6% |
| 41 | Kettle gravelly loamy sand, 8 to 40 percent slopes | B | 109.3 | 6.0% |
| 66 | Peyton sandy loam, 1 to 5 percent slopes | B | 160.6 | 8.8% |
| 67 | Peyton sandy loam, 5 to 9 percent slopes | B | 198.8 | 10.8% |
| 68 | Peyton-Pring complex, 3 to 8 percent slopes | B | 719.7 | 39.3% |
| 71 | Pring coarse sandy loam, 3 to 8 percent slopes | B | 1.7 | 0.1% |
| 92 | Tomah-Crowfoot loamy sands, 3 to 8 percent slopes | B | 0.8 | 0.0% |
| Totals for Area of Interest | | | 1,833.2 | 100.0% |

Description

Hydrologic soil groups are based on estimates of runoff potential. Soils are assigned to one of four groups according to the rate of water infiltration when the soils are not protected by vegetation, are thoroughly wet, and receive precipitation from long-duration storms.

The soils in the United States are assigned to four groups (A, B, C, and D) and three dual classes (A/D, B/D, and C/D). The groups are defined as follows:

Group A. Soils having a high infiltration rate (low runoff potential) when thoroughly wet. These consist mainly of deep, well drained to excessively drained sands or gravelly sands. These soils have a high rate of water transmission.

Group B. Soils having a moderate infiltration rate when thoroughly wet. These consist chiefly of moderately deep or deep, moderately well drained or well drained soils that have moderately fine texture to moderately coarse texture. These soils have a moderate rate of water transmission.

Group C. Soils having a slow infiltration rate when thoroughly wet. These consist chiefly of soils having a layer that impedes the downward movement of water or soils of moderately fine texture or fine texture. These soils have a slow rate of water transmission.

Group D. Soils having a very slow infiltration rate (high runoff potential) when thoroughly wet. These consist chiefly of clays that have a high shrink-swell potential, soils that have a high water table, soils that have a claypan or clay layer at or near the surface, and soils that are shallow over nearly impervious material. These soils have a very slow rate of water transmission.

If a soil is assigned to a dual hydrologic group (A/D, B/D, or C/D), the first letter is for drained areas and the second is for undrained areas. Only the soils that in their natural condition are in group D are assigned to dual classes.


Rating Options

Aggregation Method: Dominant Condition

Component Percent Cutoff: None Specified

Tie-break Rule: Higher

F.E.M.A. MAP



104°45'00"
39°



APPROXIMATE SCALE IN FEET
1000 0 1000

NATIONAL FLOOD INSURANCE PROGRAM

FIRM FLOOD INSURANCE RATE MAP

EL PASO COUNTY,
COLORADO AND
INCORPORATED AREAS

PANEL 295 OF 1300
(SEE MAP INDEX FOR PANELS NOT PRINTED)

| CONTAINS: COMMUNITY | NUMBER | PANEL | SUFFIX |
|---|--------|-------|--------|
| COLORADO SPRINGS, CITY OF | 080080 | 0295 | F |
| EL PASO COUNTY, UNINCORPORATED AREAS | 080059 | 0295 | F |


MAP NUMBER
08041C0295 F

EFFECTIVE DATE:
MARCH 17, 1997



Federal Emergency Management Agency

This is an official copy of a portion of the above referenced flood map. It was extracted using F-MIT On-Line. This map does not reflect changes or amendments which may have been made subsequent to the date on the title block. For the latest product information about National Flood Insurance Program flood maps check the FEMA Flood Map Store at www.msc.fema.gov



APPROXIMATE SCALE IN FEET
1000 0 1000

NATIONAL FLOOD INSURANCE PROGRAM

**FIRM
FLOOD INSURANCE RATE MAP**

**EL PASO COUNTY,
COLORADO AND
INCORPORATED AREAS**

PANEL 315 OF 1300
(SEE MAP INDEX FOR PANELS NOT PRINTED)

CONTAINS:
COMMUNITY

EL PASO COUNTY,
UNINCORPORATED AREAS 000059 0.2%

**MAP NUMBER
08041C0315 F**

**EFFECTIVE DATE:
MARCH 17, 1997**



Federal Emergency Management Agency

This is an official copy of a portion of the above referenced flood map. It was extracted using F-MIT On-Line. This map does not reflect changes or amendments which may have been made subsequent to the date on the title block. For the latest product information about National Flood Insurance Program flood maps check the FEMA Flood Map Store at www.msc.fema.gov

HYDROLOGY / HYDRAULIC CALCULATIONS

ALL LAND ASSUMED 2 ACRE RESIDENTIAL LOTS, UNDEVELOPED WOODS OR
GOOD CONDITION OPEN SPACE (LAWNS, PARKS GOLF COURSES, CEMETARIES ETC.)

C_N VALUES - DEVELOPED CONDITIONS

| BASIN (label) | BASIN AREA (Ac) | GOLF COURSE / WOODS (B) | | 2 AC. RESIDENTIAL (B) | | COMPOSITE C _N |
|--------------------|-----------------------|-------------------------|---------------|-----------------------|---------------|-----------------------------|
| | | CN | AREA (Ac.) | CN | AREA (Ac.) | |
| OS-1A | 4.4 | 61 | 4.4 | 65 | 0.0 | 61.0 |
| OS-1B | 5.6 | 61 | 5.6 | 65 | 0.0 | 61.0 |
| EX-DP-3 (Pre-Dev.) | 36.0 | 60 | 36.0 | 65 | 0.0 | 60.0 |
| OS-2 | 2.9 | 61 | 2.9 | 65 | 0.0 | 61.0 |
| OS-3 | 10.2 | 61 | 0.0 | 65 | 10.2 | 65.0 |
| OS-4 | 32.9 | 61 | 0.0 | 65 | 32.9 | 65.0 |
| OS-5 | 29.7 | 61 | 0.0 | 65 | 29.7 | 65.0 |
| OS-6 | 9.2 | 61 | 0.0 | 65 | 9.2 | 65.0 |
| OS-7 | 5.0 | 61 | 0.0 | 65 | 5.0 | 65.0 |
| OS-8 | 14.2 | 61 | 0.0 | 65 | 14.2 | 65.0 |
| OS-9 | 9.8 | 60 | 9.8 | 65 | 0.0 | 60.0 |
| OS-10 | 4.1 | 61 | 0.0 | 65 | 4.1 | 65.0 |
| OS-11 | 28.0 | 61 | 0.0 | 65 | 28.0 | 65.0 |
| OS-12 | 68.1 | 61 | 40.0 | 65 | 28.1 | 62.7 |
| OS-13 | 36.9 | 61 | 18.0 | 65 | 18.9 | 63.0 |
| OS-14 | 26.4 | 61 | 20.0 | 65 | 6.4 | 62.0 |
| OS-15 | 70.8 | 61 | 20.0 | 65 | 50.8 | 63.9 |
| OS-16 | 4.5 | 61 | 0.0 | 65 | 4.5 | 65.0 |
| OS-17 | 15.8 | 61 | 0.0 | 65 | 15.8 | 65.0 |
| OS-18 | 13.0 | 61 | 0.0 | 65 | 13.0 | 65.0 |
| | | | | | | |

ALL LAND ASSUMED 2 ACRE RESIDENTIAL LOTS, UNDEVELOPED WOODS OR
GOOD CONDITION OPEN SPACE (LAWNS, PARKS GOLF COURSES, CEMETARIES ETC.)

C_N VALUES - DEVELOPED CONDITIONS

| BASIN (label) | BASIN AREA (Ac) | GOLF COURSE / WOODS (B) | | 2 AC. RESIDENTIAL (B) | | COMPOSITE C _N |
|------------------|-----------------------|-------------------------|---------------|-----------------------|---------------|-----------------------------|
| | | CN | AREA (Ac.) | CN | AREA (Ac.) | |
| BS-1A | 3.5 | 61 | 0.0 | 65 | 3.5 | 65.0 |
| BS-1B | 8.9 | 61 | 0.0 | 65 | 8.9 | 65.0 |
| BS-2 | 1.9 | 61 | 0.0 | 89 | 1.9 | 89.0 |
| BS-2A | 0.8 | 61 | 0.0 | 89 | 0.8 | 89.0 |
| BS-2B | 0.9 | 61 | 0.0 | 89 | 0.9 | 89.0 |
| BS-3 | 6.2 | 61 | 0.0 | 65 | 6.2 | 65.0 |
| BS-4 | 13.0 | 61 | 0.0 | 67 | 13.0 | 67.0 |
| BS-5 | 11.2 | 61 | 0.0 | 65 | 11.2 | 65.0 |
| BS-6 | 1.2 | 61 | 0.0 | 89 | 1.2 | 89.0 |
| BS-7 | 2.9 | 61 | 0.0 | 65 | 2.9 | 65.0 |
| BS-8 | 1.0 | 61 | 0.0 | 89 | 1.0 | 89.0 |
| BS-9 | 1.5 | 61 | 0.0 | 89 | 1.5 | 89.0 |
| BS-10 | 4.5 | 61 | 0.0 | 65 | 4.5 | 65.0 |
| BS-11 | 0.9 | 61 | 0.0 | 89 | 0.9 | 89.0 |
| BS-12 | 7.7 | 61 | 0.0 | 65 | 7.7 | 65.0 |
| BS-13 | 25.6 | 61 | 0.0 | 65 | 25.6 | 65.0 |
| BS-14 | 13.4 | 61 | 0.0 | 65 | 13.4 | 65.0 |
| BS-15 | 5.3 | 61 | 0.0 | 65 | 5.3 | 65.0 |
| BS-16 | 21.6 | 61 | 0.0 | 65 | 21.6 | 65.0 |
| BS-17 | 12.1 | 61 | 0.0 | 65 | 12.1 | 65.0 |
| BS-18 | 33.8 | 61 | 12.1 | 65 | 21.7 | 63.6 |
| BS-19 | 6.3 | 61 | 0.0 | 65 | 6.3 | 65.0 |
| BS-20 | 73.9 | 61 | 30.2 | 65 | 43.7 | 63.4 |
| BS-21 | 69.5 | 61 | 12.1 | 65 | 57.4 | 64.3 |
| BS-22 | 18.1 | 61 | 2.5 | 65 | 15.6 | 64.4 |
| BS-23 | 37.1 | 61 | 15.4 | 65 | 21.7 | 63.3 |
| BS-23A | 16.3 | 61 | 2.5 | 65 | 13.8 | 64.4 |
| BS-24 | 10.9 | 60 | 4.3 | 65 | 6.6 | 63.0 |
| EX-24 (Pre-Dev.) | 13.2 | 60 | 13.2 | 65 | 0.0 | 60.0 |
| BS-25 | 12.7 | 60 | 5.0 | 65 | 7.7 | 63.0 |
| BS-26 | 2.5 | 60 | 2.5 | 65 | 0.0 | 60.0 |
| BS-27 | 23.3 | 61 | 0.0 | 65 | 23.3 | 65.0 |
| BS-28 | 36.9 | 61 | 5.6 | 65 | 31.3 | 64.4 |
| BS-29 | 27.7 | 61 | 7.2 | 65 | 20.5 | 64.0 |
| BS-30 | 6.7 | 61 | 0.0 | 65 | 6.7 | 65.0 |
| BS-31 | 8.4 | 60 | 4.2 | 65 | 4.2 | 62.5 |
| BS-32 | 6.2 | 60 | 3.0 | 65 | 3.2 | 62.6 |
| BS-33 | 8.9 | 60 | 0.6 | 65 | 8.3 | 64.7 |
| | | | | | | |

ALL LAND ASSUMED 2 ACRE RESIDENTIAL LOTS, UNDEVELOPED WOODS OR
GOOD CONDITION OPEN SPACE (LAWNS, PARKS GOLF COURSES, CEMETARIES ETC.)

C_N VALUES - DEVELOPED CONDITIONS

| BASIN (label) | BASIN AREA (Ac) | GOLF COURSE / WOODS (B) | | 2 AC. RESIDENTIAL (B) | | COMPOSITE C _N |
|------------------|-----------------------|-------------------------|---------------|-----------------------|---------------|-----------------------------|
| | | CN | AREA (Ac.) | CN | AREA (Ac.) | |
| CC-1A | 9.8 | 61 | 0.0 | 65 | 9.8 | 65.0 |
| CC-1B | 12.6 | 61 | 0.5 | 65 | 12.1 | 64.8 |
| CC-2A | 11.0 | 61 | 0.0 | 65 | 11.0 | 65.0 |
| CC-2B | 20.8 | 61 | 0.0 | 65 | 20.8 | 65.0 |
| CC-2C | 6.4 | 61 | 0.0 | 65 | 6.4 | 65.0 |
| CC-3 | 52.5 | 61 | 25.0 | 65 | 27.5 | 63.1 |
| CC-4A | 108.7 | 61 | 65.0 | 65 | 43.7 | 62.6 |
| CC-4B | 8.1 | 85 | 4.5 | 65 | 3.6 | 76.1 |
| CC-4C (Pre-Dev.) | 7.4 | 61 | 7.4 | 65 | 0.0 | 61.0 |
| CC-5 | 22.4 | 61 | 0.0 | 65 | 22.4 | 65.0 |
| CC-6 | 27.8 | 61 | 0.0 | 65 | 27.8 | 65.0 |
| CC-7 | 18.4 | 61 | 0.0 | 65 | 18.4 | 65.0 |
| CC-8 | 7.7 | 61 | 0.0 | 65 | 7.7 | 65.0 |
| CC-9 | 5.6 | 61 | 0.0 | 65 | 5.6 | 65.0 |
| CC-10 | 85.6 | 61 | 51.0 | 65 | 34.6 | 62.6 |
| CC-11 | 18.6 | 61 | 9.0 | 65 | 9.6 | 63.1 |
| CC-12 | 12.2 | 61 | 0.0 | 65 | 12.2 | 65.0 |
| CC-13A | 19.3 | 61 | 0.0 | 65 | 19.3 | 65.0 |
| CC-13B | 25.5 | 61 | 0.0 | 65 | 25.5 | 65.0 |
| CC-13C | 9.9 | 61 | 0.0 | 65 | 9.9 | 65.0 |
| CC-13D | 18.8 | 61 | 0.0 | 65 | 18.8 | 65.0 |
| CC-14 | 4.6 | 61 | 0.0 | 65 | 4.6 | 65.0 |
| CC-15 | 12.8 | 61 | 0.0 | 65 | 12.8 | 65.0 |
| CC-16 | 16.3 | 61 | 0.0 | 65 | 16.3 | 65.0 |
| CC-17 | 25.0 | 61 | 0.0 | 65 | 25.0 | 65.0 |
| CC-18 | 6.2 | 65 | 5.8 | 89 | 0.4 | 66.5 |
| CC-19 | 3.7 | 61 | 0.0 | 65 | 3.7 | 65.0 |
| CC-20 | 39.3 | 61 | 0.0 | 65 | 39.3 | 65.0 |
| CC-21 | 6.2 | 61 | 6.2 | 65 | 0.0 | 61.0 |
| CC-22 | 13.8 | 61 | 0.0 | 65 | 13.8 | 65.0 |
| CC-23 | 5.7 | 61 | 0.4 | 65 | 5.3 | 64.7 |
| CC-24 | 39.6 | 61 | 0.0 | 65 | 39.6 | 65.0 |
| CC-25 | 3.5 | 61 | 0.0 | 65 | 3.5 | 65.0 |
| CC-26 | 16.7 | 61 | 0.0 | 65 | 16.7 | 65.0 |
| CC-27 | 18.9 | 61 | 3.0 | 65 | 15.9 | 64.4 |
| CC-28 | 154.8 | 61 | 23.0 | 65 | 131.8 | 64.4 |

TIME OF CONCENTRATION - DEVELOPED

| BASIN | COMPOSITE Cn | C(5) | Length (ft) | OVERLAND Height (ft) | Tc (min) | STREET / CHANNEL FLOW (DCM Vol. 1 Fig. 6-25) | | | | Tc TOTAL (min) | Tc LAG (0.6tc) (min) | Tc LAG (0.6tc) (hr) |
|--------------------|-----------------|------|----------------|----------------------------|-------------|--|--------------|-------------------|-------------|----------------------|----------------------------|---------------------------|
| | | | | | | Length (ft) | Slope (%) | Velocity (fps) | Tc (min) | | | |
| OS-1A | 61.0 | 0.08 | 300 | 20 | 17.1 | 150 | 4.0% | 1.0 | 2.5 | 19.6 | 11.7 | 0.20 |
| OS-1B | 61.0 | 0.08 | 300 | 20 | 17.1 | 300 | 8.0% | 1.4 | 3.6 | 20.6 | 12.4 | 0.21 |
| EX-DP-3 (Pre-Dev.) | 60.0 | 0.08 | 300 | 20 | 17.1 | 900 | 5.0% | 1.9 | 7.9 | 25.0 | 15.0 | 0.25 |
| OS-2 | 61.0 | 0.08 | 300 | 20 | 17.1 | 300 | 6.0% | 2.0 | 2.5 | 19.6 | 11.7 | 0.20 |
| OS-3 | 65.0 | 0.08 | 300 | 22 | 16.5 | 275 | 6.2% | 2.0 | 2.3 | 18.8 | 11.3 | 0.19 |
| OS-4 | 65.0 | 0.08 | 300 | 18 | 17.7 | 420 | 4.3% | 1.3 | 5.4 | 23.0 | 13.8 | 0.23 |
| OS-5 | 65.0 | 0.08 | 300 | 12 | 20.2 | 1200 | 2.5% | 1.1 | 19.0 | 39.2 | 23.5 | 0.39 |
| OS-6 | 65.0 | 0.08 | 300 | 17 | 18.0 | 300 | 5.5% | 1.9 | 2.6 | 20.6 | 12.4 | 0.21 |
| OS-7 | 65.0 | 0.08 | 300 | 20 | 17.1 | 180 | 6.5% | 2.1 | 1.4 | 18.5 | 11.1 | 0.18 |
| OS-8 | 65.0 | 0.08 | 300 | 14 | 19.2 | 260 | 5.5% | 0.6 | 7.5 | 26.7 | 16.0 | 0.27 |
| OS-9 | 60.0 | 0.08 | 300 | 12 | 20.2 | 500 | 3.5% | 0.5 | 16.7 | 36.9 | 22.1 | 0.37 |
| OS-10 | 65.0 | 0.08 | 300 | 19 | 17.3 | | | | | 17.3 | 10.4 | 0.17 |
| OS-11 | 65.0 | 0.08 | 300 | 14 | 19.2 | 600 | 6.5% | 0.7 | 15.4 | 34.6 | 20.7 | 0.35 |
| OS-12 | 62.7 | 0.08 | 300 | 10 | 21.4 | 1400 | 2.5% | 1.5 | 15.6 | 37.0 | 22.2 | 0.37 |
| OS-13 | 63.0 | 0.08 | 300 | 10 | 21.4 | 1000 | 3.0% | 1.5 | 11.1 | 32.6 | 19.5 | 0.33 |
| OS-14 | 62.0 | 0.08 | 300 | 8 | 23.1 | 1000 | 5.0% | 2.1 | 7.9 | 31.0 | 18.6 | 0.31 |
| OS-15 | 63.9 | 0.08 | 300 | 16 | 18.4 | 2200 | 4.0% | 1.9 | 19.3 | 37.7 | 22.6 | 0.38 |
| OS-16 | 65.0 | 0.08 | 300 | 7 | 24.1 | | | | | 24.1 | 14.5 | 0.24 |
| OS-17 | 65.0 | 0.08 | 300 | 20 | 17.1 | 350 | 6.0% | 2.5 | 2.3 | 19.4 | 11.6 | 0.19 |
| OS-18 | 65.0 | 0.08 | 300 | 18 | 17.7 | 300 | 6.0% | 2.5 | 2.0 | 19.7 | 11.8 | 0.20 |
| | | | | | | | | | | | | |
| BS-1A | 65.0 | 0.08 | 300 | 19 | 17.3 | | | | | 17.3 | 10.4 | 0.17 |
| BS-1B | 65.0 | 0.08 | 300 | 18 | 17.7 | 200 | 2.5% | 1.2 | 2.8 | 20.4 | 12.3 | 0.20 |
| BS-2 | 89.0 | 0.08 | 300 | 16 | 18.4 | 630 | 7.0% | 0.7 | 16.2 | 34.5 | 20.7 | 0.35 |
| BS-2A | 89.0 | 0.08 | 30 | 1.5 | 5.9 | 700 | 6.5% | 1.7 | 6.9 | 12.8 | 7.7 | 0.13 |
| BS-2B | 89.0 | 0.08 | 30 | 1.5 | 5.9 | 800 | 6.5% | 2.2 | 6.1 | 12.0 | 7.2 | 0.12 |
| BS-3 | 65.0 | 0.08 | 300 | 18 | 17.7 | 300 | 5.3% | 2.2 | 2.3 | 19.9 | 12.0 | 0.20 |
| BS-4 | 67.0 | 0.08 | 300 | 22 | 16.5 | 960 | 7.0% | 2.4 | 6.7 | 23.2 | 13.9 | 0.23 |
| BS-5 | 65.0 | 0.08 | 300 | 20 | 17.1 | 150 | 7.0% | 2.4 | 1.0 | 18.1 | 10.9 | 0.18 |
| BS-6 | 89.0 | 0.08 | 10 | 0.2 | 4.6 | 700 | 7.0% | 2.4 | 4.9 | 9.5 | 5.7 | 0.09 |

TIME OF CONCENTRATION - DEVELOPED

[illegible]

TIME OF CONCENTRATION - DEVELOPED

| BASIN | COMPOSITE Cn | C(5) | Length (ft) | OVERLAND Height (ft) | Tc (min) | STREET / CHANNEL FLOW (DCM Vol. 1 Fig. 6-25) | | | | Tc TOTAL (min) | Tc LAG (0.6tc) (min) | Tc LAG (0.6tc) (hr) |
|------------------|-----------------|------|----------------|----------------------------|-------------|--|--------------|-------------------|-------------|----------------------|----------------------------|---------------------------|
| | | | | | | Length (ft) | Slope (%) | Velocity (fps) | Tc (min) | | | |
| CC-1A | 65.0 | 0.08 | 300 | 16 | 18.4 | 500 | 5.0% | 1.7 | 4.9 | 23.3 | 14.0 | 0.23 |
| CC-1B | 64.8 | 0.08 | 300 | 14 | 19.2 | 700 | 4.0% | 2.0 | 5.8 | 25.0 | 15.0 | 0.25 |
| CC-2A | 65.0 | 0.08 | 300 | 14 | 19.2 | 250 | 3.0% | 1.5 | 2.8 | 22.0 | 13.2 | 0.22 |
| CC-2B | 65.0 | 0.08 | 300 | 14 | 19.2 | 280 | 3.0% | 1.5 | 3.1 | 22.3 | 13.4 | 0.22 |
| CC-2C | 65.0 | 0.08 | 300 | 18 | 17.7 | | | | | 17.7 | 10.6 | 0.18 |
| CC-3 | 63.1 | 0.08 | 300 | 18 | 17.7 | 2300 | 3.0% | 1.5 | 25.6 | 43.2 | 25.9 | 0.43 |
| CC-4A | 62.6 | 0.08 | 300 | 14 | 19.2 | 2700 | 2.0% | 1.8 | 25.0 | 44.2 | 26.5 | 0.44 |
| CC-4B | 76.1 | 0.08 | 300 | 12 | 20.2 | 600 | 3.0% | 1.6 | 6.3 | 26.4 | 15.9 | 0.26 |
| CC-4C (Pre-Dev.) | 61.0 | 0.08 | 40 | 0.8 | 9.3 | 350 | 3.0% | 1.5 | 3.9 | 13.2 | 7.9 | 0.13 |
| CC-5 | 65.0 | 0.08 | 300 | 18 | 17.7 | 1000 | 4.0% | 2.0 | 8.3 | 26.0 | 15.6 | 0.26 |
| CC-6 | 65.0 | 0.08 | 300 | 14 | 19.2 | 550 | 2.5% | 1.6 | 5.7 | 24.9 | 14.9 | 0.25 |
| CC-7 | 65.0 | 0.08 | 300 | 16 | 18.4 | 1000 | 3.0% | 1.6 | 10.4 | 28.8 | 17.3 | 0.29 |
| CC-8 | 65.0 | 0.08 | 300 | 10 | 21.4 | 250 | 2.0% | 1.2 | 3.5 | 24.9 | 14.9 | 0.25 |
| CC-9 | 65.0 | 0.08 | 300 | 18 | 17.7 | 100 | 2.0% | 1.2 | 1.4 | 19.0 | 11.4 | 0.19 |
| CC-10 | 62.6 | 0.08 | 300 | 22 | 16.5 | 2400 | 3.0% | 1.8 | 22.2 | 38.7 | 23.2 | 0.39 |
| CC-11 | 63.1 | 0.08 | 300 | 18 | 17.7 | 450 | 5.0% | 2.1 | 3.6 | 21.2 | 12.7 | 0.21 |
| CC-12 | 65.0 | 0.08 | 300 | 11 | 20.8 | 650 | 4.0% | 2.0 | 5.4 | 26.2 | 15.7 | 0.26 |
| CC-13A | 65.0 | 0.08 | 300 | 14 | 19.2 | 1400 | 4.0% | 2.0 | 11.7 | 30.9 | 18.5 | 0.31 |
| CC-13B | 65.0 | 0.08 | 300 | 18 | 17.7 | 1300 | 3.0% | 1.6 | 13.5 | 31.2 | 18.7 | 0.31 |
| CC-13C | 65.0 | 0.08 | 300 | 14 | 19.2 | 350 | 4.0% | 2.0 | 2.9 | 22.1 | 13.3 | 0.22 |
| CC-13D | 65.0 | 0.08 | 300 | 20 | 17.1 | 900 | 4.0% | 2.0 | 7.5 | 24.6 | 14.7 | 0.25 |
| CC-14 | 65.0 | 0.08 | 300 | 10 | 21.4 | | | | | 21.4 | 12.9 | 0.21 |
| CC-15 | 65.0 | 0.08 | 300 | 14 | 19.2 | 550 | 3.0% | 1.8 | 5.1 | 24.3 | 14.6 | 0.24 |
| CC-16 | 65.0 | 0.08 | 300 | 10 | 21.4 | 650 | 2.5% | 1.3 | 8.3 | 29.8 | 17.9 | 0.30 |
| CC-17 | 65.0 | 0.08 | 300 | 9 | 22.2 | 950 | 2.0% | 1.2 | 13.2 | 35.4 | 21.2 | 0.35 |
| CC-18 | 66.5 | 0.08 | 300 | 7 | 24.1 | 400 | 2.0% | 1.2 | 5.6 | 29.7 | 17.8 | 0.30 |
| CC-19 | 65.0 | 0.08 | 300 | 8 | 23.1 | 100 | 2.0% | 1.0 | 1.7 | 24.7 | 14.8 | 0.25 |
| CC-20 | 65.0 | 0.08 | 300 | 9 | 22.2 | 350 | 6.0% | 2.2 | 2.7 | 24.8 | 14.9 | 0.25 |
| CC-21 | 61.0 | 0.08 | 300 | 18 | 17.7 | 200 | 3.0% | 1.8 | 1.9 | 19.5 | 11.7 | 0.20 |
| CC-22 | 65.0 | 0.08 | 300 | 14 | 19.2 | 700 | 4.0% | 2.0 | 5.8 | 25.0 | 15.0 | 0.25 |
| CC-23 | 64.7 | 0.08 | 300 | 10 | 21.4 | 850 | 2.0% | 1.2 | 11.8 | 33.2 | 19.9 | 0.33 |
| CC-24 | 65.0 | 0.08 | 300 | 20 | 17.1 | 900 | 4.0% | 1.9 | 7.9 | 25.0 | 15.0 | 0.25 |
| CC-25 | 65.0 | 0.08 | 300 | 16 | 18.4 | 500 | 3.0% | 1.8 | 4.6 | 23.0 | 13.8 | 0.23 |
| CC-26 | 65.0 | 0.08 | 300 | 14 | 19.2 | 900 | 5.0% | 2.1 | 7.1 | 26.3 | 15.8 | 0.26 |
| CC-27 | 64.4 | 0.08 | 300 | 14 | 19.2 | 1300 | 3.0% | 1.8 | 12.0 | 31.2 | 18.7 | 0.31 |
| CC-28 | 64.4 | 0.08 | 300 | 14 | 19.2 | 4700 | 3.0% | 1.8 | 43.5 | 62.7 | 37.6 | 0.63 |

BASIN SUMMARY - DEVELOPED CONDITIONS

| BASIN (label) | AREA (acres) | COMPOSITE CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|--------------------|-----------------|-----------------|------------------------------|---------------------|---------------------|-----------------------|
| OS-1A | 4.40 | 61.0 | 0.20 | 0.4 | 1.6 | 7.7 |
| OS-1B | 5.60 | 61.0 | 0.21 | 0.5 | 1.9 | 9.4 |
| EX-DP-3 (Pre-Dev.) | 36.00 | 60.0 | 0.25 | 0.5 | 4.8 | 41.3 |
| OS-2 | 2.90 | 61.0 | 0.20 | 0.1 | 0.6 | 4.0 |
| OS-3 | 10.20 | 65.0 | 0.19 | 1.0 | 3.8 | 17.9 |
| OS-4 | 32.90 | 65.0 | 0.23 | 2.8 | 11.2 | 53.6 |
| OS-5 | 29.70 | 65.0 | 0.39 | 1.9 | 7.1 | 37.0 |
| OS-6 | 9.20 | 65.0 | 0.21 | 0.9 | 3.2 | 15.5 |
| OS-7 | 5.00 | 65.0 | 0.18 | 0.5 | 2.0 | 9.0 |
| OS-8 | 14.20 | 65.0 | 0.27 | 2.1 | 6.2 | 24.7 |
| OS-9 | 9.80 | 60.0 | 0.37 | 0.1 | 1.0 | 9.1 |
| OS-10 | 4.10 | 65.0 | 0.17 | 0.7 | 2.1 | 8.2 |
| OS-11 | 28.00 | 65.0 | 0.35 | 2.4 | 8.2 | 38.7 |
| OS-12 | 68.10 | 62.7 | 0.37 | 2.2 | 11.9 | 75.8 |
| OS-13 | 36.90 | 63.0 | 0.33 | 1.4 | 7.4 | 45.0 |
| OS-14 | 26.40 | 62.0 | 0.31 | 0.7 | 4.6 | 31.0 |
| OS-15 | 70.80 | 63.9 | 0.38 | 3.3 | 14.8 | 84.2 |
| OS-16 | 4.50 | 65.0 | 0.24 | 0.4 | 1.5 | 7.2 |
| OS-17 | 15.80 | 65.0 | 0.19 | 1.6 | 5.9 | 27.7 |
| OS-18 | 13.00 | 65.0 | 0.20 | 1.3 | 4.7 | 22.6 |
| | | | | | | |

BASIN SUMMARY - DEVELOPED CONDITIONS

| BASIN (label) | AREA (acres) | COMPOSITE CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|------------------|-----------------|-----------------|------------------------------|---------------------|---------------------|-----------------------|
| BS-1A | 3.50 | 65.0 | 0.17 | 0.4 | 1.4 | 6.3 |
| BS-1B | 8.90 | 65.0 | 0.20 | 0.4 | 2.4 | 13.8 |
| BS-2 | 1.90 | 89.0 | 0.35 | 2.9 | 4.2 | 8.4 |
| BS-2A | 0.80 | 89.0 | 0.13 | 1.2 | 1.8 | 3.5 |
| BS-2B | 0.90 | 89.0 | 0.12 | 1.4 | 2.0 | 4.0 |
| BS-3 | 6.20 | 65.0 | 0.20 | 0.6 | 2.3 | 10.8 |
| BS-4 | 13.00 | 67.0 | 0.23 | 1.9 | 5.5 | 23.6 |
| BS-5 | 11.20 | 65.0 | 0.18 | 1.1 | 4.4 | 20.1 |
| BS-6 | 1.20 | 89.0 | 0.09 | 1.9 | 2.8 | 5.4 |
| BS-7 | 2.90 | 65.0 | 0.13 | 4.4 | 6.4 | 12.8 |
| BS-8 | 1.00 | 89.0 | 0.12 | 1.6 | 2.2 | 4.5 |
| BS-9 | 1.50 | 89.0 | 0.13 | 2.3 | 3.3 | 6.6 |
| BS-10 | 4.50 | 65.0 | 0.24 | 6.0 | 8.7 | 17.5 |
| BS-11 | 0.90 | 89.0 | 0.08 | 1.5 | 2.1 | 4.1 |
| BS-12 | 7.70 | 65.0 | 0.19 | 0.8 | 3.0 | 13.8 |
| BS-13 | 25.60 | 65.0 | 0.23 | 3.7 | 10.2 | 40.7 |
| BS-14 | 13.40 | 65.0 | 0.23 | 2.6 | 6.8 | 26.5 |
| BS-15 | 5.30 | 65.0 | 0.18 | 1.6 | 3.7 | 12.2 |
| BS-16 | 21.60 | 65.0 | 0.34 | 4.6 | 11.8 | 44.1 |
| BS-17 | 12.10 | 65.0 | 0.21 | 3.1 | 7.7 | 26.7 |
| BS-18 | 33.80 | 63.6 | 0.41 | 3.5 | 12.4 | 56.0 |
| BS-19 | 6.30 | 65.0 | 0.18 | 2.1 | 4.6 | 15.0 |
| BS-20 | 73.90 | 63.4 | 0.31 | 7.4 | 24.6 | 112.4 |
| BS-21 | 69.50 | 64.3 | 0.35 | 7.8 | 23.9 | 103.0 |
| BS-22 | 18.10 | 64.4 | 0.22 | 3.7 | 9.6 | 36.5 |
| BS-23 | 37.10 | 63.3 | 0.33 | 4.5 | 13.6 | 58.2 |
| BS-23A | 16.30 | 64.4 | 0.29 | 5.5 | 12.0 | 38.3 |
| BS-24 | 10.90 | 63.0 | 0.17 | 0.6 | 3.3 | 17.6 |
| EX-24 (Pre-Dev.) | 13.20 | 60.0 | 0.17 | 0.2 | 2.2 | 17.8 |
| BS-25 | 12.70 | 63.0 | 0.23 | 0.4 | 2.7 | 17.3 |
| BS-26 | 2.50 | 60.0 | 0.18 | 0.0 | 0.4 | 3.4 |
| BS-27 | 23.30 | 65.0 | 0.22 | 2.1 | 8.0 | 38.8 |
| BS-28 | 36.90 | 64.4 | 0.32 | 2.2 | 9.3 | 49.4 |
| BS-29 | 27.70 | 64.0 | 0.33 | 1.4 | 6.5 | 35.9 |
| BS-30 | 6.70 | 65.0 | 0.20 | 0.7 | 2.4 | 11.7 |
| BS-31 | 8.40 | 62.5 | 0.23 | 0.3 | 1.9 | 11.8 |
| BS-32 | 6.20 | 62.6 | 0.20 | 0.3 | 1.6 | 9.4 |
| BS-33 | 8.90 | 64.7 | 0.19 | 0.8 | 3.2 | 15.3 |
| | | | | | | |

BASIN SUMMARY - DEVELOPED CONDITIONS

| BASIN (label) | AREA (acres) | COMPOSITE CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|------------------|-----------------|-----------------|------------------------------|---------------------|---------------------|-----------------------|
| CC-1A | 9.80 | 65.0 | 0.23 | 0.8 | 3.3 | 16.0 |
| CC-1B | 12.60 | 64.8 | 0.25 | 1.0 | 4.0 | 19.4 |
| CC-2A | 11.00 | 65.0 | 0.22 | 1.0 | 3.8 | 18.3 |
| CC-2B | 20.80 | 65.0 | 0.22 | 1.9 | 7.1 | 34.6 |
| CC-2C | 6.40 | 65.0 | 0.18 | 0.7 | 2.5 | 11.5 |
| CC-3 | 52.50 | 63.1 | 0.43 | 1.8 | 8.8 | 54.5 |
| CC-4A | 108.70 | 62.6 | 0.44 | 15.4 | 39.0 | 156.0 |
| CC-4B | 8.10 | 76.1 | 0.26 | 4.0 | 7.3 | 20.6 |
| CC-4C (Pre-Dev.) | 7.40 | 61.0 | 0.13 | 0.2 | 1.8 | 11.2 |
| CC-5 | 22.40 | 65.0 | 0.26 | 1.8 | 7.1 | 34.3 |
| CC-6 | 27.80 | 65.0 | 0.25 | 2.3 | 9.1 | 43.2 |
| CC-7 | 18.40 | 65.0 | 0.29 | 1.4 | 5.4 | 27.0 |
| CC-8 | 7.70 | 65.0 | 0.25 | 0.6 | 2.5 | 12.0 |
| CC-9 | 5.60 | 65.0 | 0.19 | 0.6 | 2.1 | 9.8 |
| CC-10 | 85.60 | 62.6 | 0.39 | 2.6 | 14.1 | 91.9 |
| CC-11 | 18.60 | 63.1 | 0.21 | 0.9 | 5.0 | 28.1 |
| CC-12 | 12.20 | 65.0 | 0.26 | 1.0 | 3.9 | 18.7 |
| CC-13A | 19.30 | 65.0 | 0.31 | 1.4 | 5.4 | 27.3 |
| CC-13B | 25.50 | 65.0 | 0.31 | 1.8 | 7.2 | 36.1 |
| CC-13C | 9.90 | 65.0 | 0.22 | 0.9 | 3.4 | 16.5 |
| CC-13D | 18.80 | 65.0 | 0.25 | 1.5 | 6.2 | 29.2 |
| CC-14 | 4.60 | 65.0 | 0.21 | 0.4 | 1.6 | 7.8 |
| CC-15 | 12.80 | 65.0 | 0.24 | 1.1 | 4.3 | 20.4 |
| CC-16 | 16.30 | 65.0 | 0.30 | 1.2 | 4.6 | 23.6 |
| CC-17 | 25.00 | 65.0 | 0.35 | 1.7 | 6.5 | 32.8 |
| CC-18 | 6.20 | 66.5 | 0.30 | 0.7 | 2.2 | 9.7 |
| CC-19 | 3.70 | 65.0 | 0.25 | 0.3 | 1.2 | 5.8 |
| CC-20 | 39.30 | 65.0 | 0.25 | 3.2 | 12.9 | 61.0 |
| CC-21 | 6.20 | 61.0 | 0.20 | 0.1 | 1.2 | 8.5 |
| CC-22 | 13.80 | 65.0 | 0.25 | 1.1 | 4.5 | 21.4 |
| CC-23 | 5.70 | 64.7 | 0.33 | 0.4 | 1.5 | 7.7 |
| CC-24 | 39.60 | 65.0 | 0.25 | 3.3 | 13.0 | 61.5 |
| CC-25 | 3.50 | 65.0 | 0.23 | 0.3 | 1.2 | 5.7 |
| CC-26 | 16.70 | 65.0 | 0.26 | 1.4 | 5.3 | 25.6 |
| CC-27 | 18.90 | 64.4 | 0.31 | 1.2 | 4.9 | 25.8 |
| CC-28 | 154.80 | 64.4 | 0.63 | 6.5 | 24.7 | 136.3 |
| | | | | | | |

DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS

| Design Point (label) | Contributing Basins | Q 2 Yr. Q (cfs) | Q 5 Yr. Q (cfs) | Q 100 Yr. Q (cfs) |
|--|---|-----------------------|-----------------------|-------------------------|
| DP-1 DEV | OS-1A, BS-2B | 1.6 | 3.4 | 11 |
| DP-2 DEV | DP-1, BS-4 | 3.2 | 8.8 | 35 |
| TOTAL INFLOW TO POND 1 (UD Detention hydrograph) | DP-1, DP-2, BS-1A | 4 | 7 | 38 |
| DP-3 DEV (Pond Pack routing) | OS-2, BS-3, BS-1B, Release from FHN Pond 1 | 1 | 6 | 39 |
| DP-4 DEV | BS-2 | 2.9 | 4.2 | 8 |
| DP-5 DEV | OS-1B, BS-2A | 1.5 | 3.5 | 13 |
| DP-6 DEV | OS-2, BS-3 | 0.6 | 2.8 | 15 |
| DP-7 DEV | OS-3, BS-5 | 2.1 | 8.2 | 38 |
| DP-8 DEV | OS-4, OS-5, OS-6, BS-7, BS-10, Release from Exist. HFR Pond 16 | 20.9 | 70.4 | 284 |
| DP-9 DEV | OS-7, BS-12 | 1.3 | 5.0 | 23 |
| DP-10 DEV | OS-8, OS-10, OS-11, BS-13, BS- 14 | 10.7 | 32.0 | 143 |
| DP-11 DEV | BS-16 | 4.6 | 11.8 | 36 |
| DP-12 DEV | DP-11, BS-15 | 4.0 | 11.0 | 44 |
| TOTAL INFLOW TO POND 4 (UD Detention hydrograph) | DP-10, DP-12, BS-17, OS-9 | 10 | 16 | 217 |
| DP-13 DEV | Release from FHN Pond 4 | 0.3 | 0.3 | 142 |
| DP-14 DEV | BS-18 | 3.5 | 12.4 | 56 |
| DP-15 DEV | BS-19 | 2.1 | 4.6 | 15 |
| DP-16 DEV | DP-14, DP-15, BS-20, BS-21, BS- 22, BS-23 | 25.0 | 78.0 | 362 |
| TOTAL INFLOW TO FHN POND 8 (Full Build-out) (UD Detention hydrograph) | DP-10, DP-12, BS-17, OS-9 | 24 | 37 | 390 |
| DP-17 DEV (Full Build-out) | Release from FHN Pond 8 | 0.8 | 1.0 | 253 |
| TOTAL INFLOW TO FHN POND 8 (Filing 1 Only) (UD Detention hydrograph) | DP-10, DP-12, BS-17, OS-9 | 9 | 14 | 301 |
| DP-17 DEV (Filing 1 Only) | Release from FHN Pond 8 | 0.4 | 0.5 | 219 |

DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS

| Design Point (label) | Contributing Basins | Q 2 Yr. Q (cfs) | Q 5 Yr. Q (cfs) | Q 100 Yr. Q (cfs) |
|--|--|-----------------------|-----------------------|-------------------------|
| DP-18 DEV | BS-28, BS-29, BS-30, OS-18 | 5.0 | 21.6 | 115 |
| DP-19 DEV | BS-27, OS-17, Release from DP-18 | 3.8 | 16.8 | 126 |
| DP-20 DEV | CC-1A, OS-12 | 3.2 | 14.3 | 88 |
| DP-21 DEV | CC-2A, OS-13 | 2.1 | 10.5 | 62 |
| DP-22 DEV | CC-2B, Release from DP-21 | 3.7 | 16.6 | 92 |
| DP-23 DEV | CC-3, OS-14 | 2.5 | 13.0 | 84 |
| DP-24 DEV | CC-4C (Pre-Dev.), CC-5 | 1.9 | 8.4 | 45 |
| TOTAL INFLOW TO POND 12 (UD Detention hydrograph) | CC-4C, CC-5, CC-6 | 6 | 9 | 85 |
| DP-25 DEV | Release from FHN Pond 12 | 0.2 | 0.3 | 45 |
| DP-26 DEV | CC-8, CC-10 | 3.0 | 15.9 | 102 |
| DP-27 DEV | CC-15, CC-20 | 4.3 | 17.2 | 81 |
| DP-28 DEV | CC-13A, OS-15 | 4.6 | 19.8 | 110 |
| DP-29 DEV | CC-13B, CC-13C, Release from DP-28 | 5.8 | 26.6 | 155 |
| DP-30 DEV | CC-18 | 0.7 | 2.2 | 10 |
| DP-31 DEV | CC-19, Release from DP-30 | 0.9 | 3.2 | 15 |
| DP-32 DEV | CC-17, OS-16 | 2.0 | 7.8 | 40 |
| DP-33 DEV | CC-23, CC-24 | 3.6 | 14.4 | 69 |
| DP-34 DEV | CC-26, CC-27, CC-28 and Release from CC-16 & DP-32 | 6.0 | 23.5 | 168 |
| | | | | |

ALL LAND ASSUMED 2 ACRE RESIDENTIAL LOTS, UNDEVELOPED WOODS (FUTURE FILING) OR
GOOD CONDITION OPEN SPACE (LAWNS, PARKS GOLF COURSES, CEMETARIES ETC.)

C_N VALUES - DEVELOPED CONDITIONS (FILING 1 ONLY)

| BASIN (label) | BASIN AREA (Ac) | GOLF COURSE (B) | | 2 AC. RESIDENTIAL (B) | | UNDEVELOPED WOODS (B) | | COMPOSITE C _N |
|------------------|-----------------------|-----------------|---------------|-----------------------|---------------|-----------------------|---------------|-----------------------------|
| | | CN | AREA (Ac.) | CN | AREA (Ac.) | CN | AREA (Ac.) | |
| BS-20 | 73.9 | 61 | 30.2 | 60 | 1.0 | 60 | 42.7 | 60.4 |
| BS-21 | 69.5 | 61 | 12.1 | 65 | 34.4 | 60 | 23.0 | 62.6 |
| BS-22 | 18.1 | 61 | 2.5 | 65 | 5.1 | 60 | 10.5 | 61.5 |
| BS-23 | 37.1 | 61 | 15.4 | 65 | 20.2 | 60 | 1.5 | 63.1 |
| BS-23A | 16.3 | 61 | 0.0 | 65 | 2.5 | 60 | 13.8 | 60.8 |

TIME OF CONCENTRATION DEVELOPED (FILING 1 ONLY)

| BASIN | COMPOSITE Cn | C(5) | Length (ft) | OVERLAND Height (ft) | Tc (min) | STREET / CHANNEL FLOW (DCM Vol. 1 Fig. 6-25) | | | | Tc TOTAL (min) | Tc LAG (0.6tc) (min) | Tc LAG (0.6tc) (hr) |
|--------|-----------------|------|----------------|----------------------------|-------------|--|--------------|-------------------|-------------|----------------------|----------------------------|---------------------------|
| | | | | | | Length (ft) | Slope (%) | Velocity (fps) | Tc (min) | | | |
| BS-20 | 60.4 | 0.08 | 1000 | 60 | 32.2 | | | | | 32.2 | 19.3 | 0.32 |
| BS-21 | 62.6 | 0.08 | 1000 | 30 | 40.5 | 500 | 4.0% | 1.7 | 4.9 | 45.4 | 27.3 | 0.45 |
| BS-22 | 61.5 | 0.08 | 300 | 21 | 16.8 | 500 | 4.0% | 1.5 | 5.6 | 22.3 | 13.4 | 0.22 |
| BS-23 | 63.1 | 0.08 | 300 | 14 | 19.2 | 800 | 4.0% | 1.0 | 13.3 | 32.5 | 19.5 | 0.33 |
| BS-23A | 60.8 | 0.08 | 1000 | 64 | 31.6 | 200 | 2.0% | 1.5 | 2.2 | 33.8 | 20.3 | 0.34 |

Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Monday, Nov 20 2017


DP 1 CULVERT

Invert Elev Dn (ft) = 7436.00
Pipe Length (ft) = 60.00
Slope (%) = 1.67
Invert Elev Up (ft) = 7437.00
Rise (in) = 24.0
Shape = Circular
Span (in) = 24.0
No. Barrels = 1
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Groove end projecting (C)
Coeff. K,M,c,Y,k = 0.0045, 2, 0.0317, 0.69, 0.2

Embankment
Top Elevation (ft) = 7440.50
Top Width (ft) = 36.00
Crest Width (ft) = 60.00

Calculations
Qmin (cfs) = 0.00
Qmax (cfs) = 12.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted
Qtotal (cfs) = 12.00
Qpipe (cfs) = 12.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 4.40
Veloc Up (ft/s) = 5.85
HGL Dn (ft) = 7437.62
HGL Up (ft) = 7438.24
Hw Elev (ft) = 7438.82
Hw/D (ft) = 0.91
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Mar 29 2018

DP 2 CULVERT

| | |
|---------------------|--------------------------------|
| Invert Elev Dn (ft) | = 7417.60 |
| Pipe Length (ft) | = 90.00 |
| Slope (%) | = 6.00 |
| Invert Elev Up (ft) | = 7423.00 |
| Rise (in) | = 30.0 |
| Shape | = Circular |
| Span (in) | = 30.0 |
| No. Barrels | = 1 |
| n-Value | = 0.013 |
| Culvert Type | = Circular Concrete |
| Culvert Entrance | = Groove end projecting (C) |
| Coeff. K,M,c,Y,k | = 0.0045, 2, 0.0317, 0.69, 0.2 |

Embankment


| | |
|--------------------|-----------|
| Top Elevation (ft) | = 7427.15 |
| Top Width (ft) | = 30.00 |
| Crest Width (ft) | = 60.00 |

Calculations

| | |
|---------------------|------------|
| Qmin (cfs) | = 0.00 |
| Qmax (cfs) | = 35.00 |
| Tailwater Elev (ft) | = (dc+D)/2 |

Highlighted

| | |
|-----------------|-----------------|
| Qtotal (cfs) | = 35.00 |
| Qpipe (cfs) | = 35.00 |
| Qovertop (cfs) | = 0.00 |
| Veloc Dn (ft/s) | = 7.51 |
| Veloc Up (ft/s) | = 8.28 |
| HGL Dn (ft) | = 7419.85 |
| HGL Up (ft) | = 7425.01 |
| Hw Elev (ft) | = 7426.26 |
| Hw/D (ft) | = 1.30 |
| Flow Regime | = Inlet Control |



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Mar 29 2018

CULVERT @ FIRE STATION DRIVEWAY

Invert Elev Dn (ft) = 7412.00
Pipe Length (ft) = 60.00
Slope (%) = 8.33
Invert Elev Up (ft) = 7417.00
Rise (in) = 18.0
Shape = Circular
Span (in) = 18.0
No. Barrels = 1
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Groove end projecting (C)
Coeff. K,M,c,Y,k = 0.0045, 2, 0.0317, 0.69, 0.2

Embankment


Top Elevation (ft) = 7419.00
Top Width (ft) = 28.00
Crest Width (ft) = 60.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 5.00
Tailwater Elev (ft) = $(dc+D)/2$

Highlighted

Qtotal (cfs) = 5.00
Qpipe (cfs) = 5.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 3.35
Veloc Up (ft/s) = 4.77
HGL Dn (ft) = 7413.18
HGL Up (ft) = 7417.86
Hw Elev (ft) = 7418.19
Hw/D (ft) = 0.79
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Mar 29 2018

DP 7 CULVERT

Invert Elev Dn (ft) = 7453.00
Pipe Length (ft) = 66.00
Slope (%) = 4.00
Invert Elev Up (ft) = 7455.64
Rise (in) = 30.0
Shape = Circular
Span (in) = 30.0
No. Barrels = 2
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Groove end projecting (C)
Coeff. K,M,c,Y,k = 0.0045, 2, 0.0317, 0.69, 0.2

Embankment


Top Elevation (ft) = 7459.80
Top Width (ft) = 36.00
Crest Width (ft) = 60.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 38.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 38.00
Qpipe (cfs) = 38.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 4.54
Veloc Up (ft/s) = 6.30
HGL Dn (ft) = 7454.99
HGL Up (ft) = 7457.12
Hw Elev (ft) = 7457.75
Hw/D (ft) = 0.84
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Mar 29 2018

DP 8 CULVERTS

Invert Elev Dn (ft) = 7438.30
Pipe Length (ft) = 100.00
Slope (%) = 5.70
Invert Elev Up (ft) = 7444.00
Rise (in) = 48.0
Shape = Circular
Span (in) = 48.0
No. Barrels = 3
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Square edge w/headwall (C)
Coeff. K,M,c,Y,k = 0.0098, 2, 0.0398, 0.67, 0.5

Embankment


Top Elevation (ft) = 7451.17
Top Width (ft) = 40.00
Crest Width (ft) = 50.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 280.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 280.00
Qpipe (cfs) = 280.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 8.07
Veloc Up (ft/s) = 9.47
HGL Dn (ft) = 7441.76
HGL Up (ft) = 7446.93
Hw Elev (ft) = 7448.76
Hw/D (ft) = 1.19
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Mar 29 2018

DP 9 CULVERTS

Invert Elev Dn (ft) = 7486.10
Pipe Length (ft) = 60.00
Slope (%) = 2.30
Invert Elev Up (ft) = 7487.48
Rise (in) = 24.0
Shape = Circular
Span (in) = 24.0
No. Barrels = 2
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Groove end projecting (C)
Coeff. K,M,c,Y,k = 0.0045, 2, 0.0317, 0.69, 0.2

Embankment


Top Elevation (ft) = 7491.20
Top Width (ft) = 36.00
Crest Width (ft) = 60.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 23.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 23.00
Qpipe (cfs) = 23.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 4.25
Veloc Up (ft/s) = 5.75
HGL Dn (ft) = 7487.71
HGL Up (ft) = 7488.70
Hw Elev (ft) = 7489.25
Hw/D (ft) = 0.88
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Nov 30 2017

DP 10 CULVERT

Invert Elev Dn (ft) = 7455.80
Pipe Length (ft) = 112.07
Slope (%) = 4.00
Invert Elev Up (ft) = 7460.28
Rise (in) = 42.0
Shape = Circular
Span (in) = 42.0
No. Barrels = 2
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Square edge w/headwall (C)
Coeff. K,M,c,Y,k = 0.0098, 2, 0.0398, 0.67, 0.5

Embankment


Top Elevation (ft) = 7470.42
Top Width (ft) = 40.00
Crest Width (ft) = 50.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 144.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 144.00
Qpipe (cfs) = 144.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 8.03
Veloc Up (ft/s) = 9.19
HGL Dn (ft) = 7458.88
HGL Up (ft) = 7462.94
Hw Elev (ft) = 7464.78
Hw/D (ft) = 1.29
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Nov 30 2017

DP 11 CULVERT

Invert Elev Dn (ft) = 7451.50
Pipe Length (ft) = 75.00
Slope (%) = 2.00
Invert Elev Up (ft) = 7453.00
Rise (in) = 24.0
Shape = Circular
Span (in) = 24.0
No. Barrels = 2
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Groove end projecting (C)
Coeff. K,M,c,Y,k = 0.0045, 2, 0.0317, 0.69, 0.2

Embankment


Top Elevation (ft) = 7457.00
Top Width (ft) = 30.00
Crest Width (ft) = 20.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 36.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 36.00
Qpipe (cfs) = 36.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 6.14
Veloc Up (ft/s) = 6.99
HGL Dn (ft) = 7453.26
HGL Up (ft) = 7454.53
Hw Elev (ft) = 7455.42
Hw/D (ft) = 1.21
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Mar 29 2018

DP 12 CULVERT

Invert Elev Dn (ft) = 7426.00
Pipe Length (ft) = 130.00
Slope (%) = 1.15
Invert Elev Up (ft) = 7427.50
Rise (in) = 36.0
Shape = Circular
Span (in) = 36.0
No. Barrels = 1
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Groove end projecting (C)
Coeff. K,M,c,Y,k = 0.0045, 2, 0.0317, 0.69, 0.2

Embankment


Top Elevation (ft) = 7432.30
Top Width (ft) = 30.00
Crest Width (ft) = 20.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 44.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 44.00
Qpipe (cfs) = 44.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 6.80
Veloc Up (ft/s) = 8.08
HGL Dn (ft) = 7428.58
HGL Up (ft) = 7429.66
Hw Elev (ft) = 7430.83
Hw/D (ft) = 1.11
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Nov 30 2017

DP 14 CULVERT

| | | |
|---------------------|---|------------------------------|
| Invert Elev Dn (ft) | = | 7448.18 |
| Pipe Length (ft) | = | 111.84 |
| Slope (%) | = | 3.92 |
| Invert Elev Up (ft) | = | 7452.57 |
| Rise (in) | = | 24.0 |
| Shape | = | Circular |
| Span (in) | = | 24.0 |
| No. Barrels | = | 3 |
| n-Value | = | 0.012 |
| Culvert Type | = | Circular Concrete |
| Culvert Entrance | = | Square edge w/headwall (C) |
| Coeff. K,M,c,Y,k | = | 0.0098, 2, 0.0398, 0.67, 0.5 |

Embankment


| | | |
|--------------------|---|---------|
| Top Elevation (ft) | = | 7457.97 |
| Top Width (ft) | = | 32.00 |
| Crest Width (ft) | = | 40.00 |

Calculations

| | | |
|---------------------|---|----------|
| Qmin (cfs) | = | 0.00 |
| Qmax (cfs) | = | 56.00 |
| Tailwater Elev (ft) | = | (dc+D)/2 |

Highlighted

| | | |
|-----------------|---|---------------|
| Qtotal (cfs) | = | 56.00 |
| Qpipe (cfs) | = | 56.00 |
| Qovertop (cfs) | = | 0.00 |
| Veloc Dn (ft/s) | = | 6.33 |
| Veloc Up (ft/s) | = | 7.13 |
| HGL Dn (ft) | = | 7449.96 |
| HGL Up (ft) | = | 7454.12 |
| Hw Elev (ft) | = | 7455.28 |
| Hw/D (ft) | = | 1.35 |
| Flow Regime | = | Inlet Control |



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Nov 30 2017

DP 15 CULVERT

Invert Elev Dn (ft) = 7465.95
Pipe Length (ft) = 61.74
Slope (%) = 1.15
Invert Elev Up (ft) = 7466.66
Rise (in) = 18.0
Shape = Circular
Span (in) = 18.0
No. Barrels = 2
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Square edge w/headwall (C)
Coeff. K,M,c,Y,k = 0.0098, 2, 0.0398, 0.67, 0.5

Embankment


Top Elevation (ft) = 7469.55
Top Width (ft) = 32.00
Crest Width (ft) = 40.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 15.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 15.00
Qpipe (cfs) = 15.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 4.67
Veloc Up (ft/s) = 5.62
HGL Dn (ft) = 7467.23
HGL Up (ft) = 7467.72
Hw Elev (ft) = 7468.38
Hw/D (ft) = 1.15
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Nov 30 2017

DP 16 CULVERT

| | | |
|---------------------|---|------------------------------|
| Invert Elev Dn (ft) | = | 7373.00 |
| Pipe Length (ft) | = | 200.00 |
| Slope (%) | = | 6.00 |
| Invert Elev Up (ft) | = | 7385.00 |
| Rise (in) | = | 60.0 |
| Shape | = | Circular |
| Span (in) | = | 60.0 |
| No. Barrels | = | 2 |
| n-Value | = | 0.013 |
| Culvert Type | = | Circular Concrete |
| Culvert Entrance | = | Groove end w/headwall (C) |
| Coeff. K,M,c,Y,k | = | 0.0018, 2, 0.0292, 0.74, 0.2 |

Embankment


| | | |
|--------------------|---|---------|
| Top Elevation (ft) | = | 7394.00 |
| Top Width (ft) | = | 40.00 |
| Crest Width (ft) | = | 80.00 |

Calculations

| | | |
|---------------------|---|----------|
| Qmin (cfs) | = | 0.00 |
| Qmax (cfs) | = | 365.00 |
| Tailwater Elev (ft) | = | (dc+D)/2 |

Highlighted

| | | |
|-----------------|---|---------------|
| Qtotal (cfs) | = | 365.00 |
| Qpipe (cfs) | = | 365.00 |
| Qovertop (cfs) | = | 0.00 |
| Veloc Dn (ft/s) | = | 9.92 |
| Veloc Up (ft/s) | = | 11.21 |
| HGL Dn (ft) | = | 7377.43 |
| HGL Up (ft) | = | 7388.87 |
| Hw Elev (ft) | = | 7391.07 |
| Hw/D (ft) | = | 1.21 |
| Flow Regime | = | Inlet Control |



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Nov 30 2017

DP 24 CULVERT

Invert Elev Dn (ft) = 7562.87
Pipe Length (ft) = 89.81
Slope (%) = 3.49
Invert Elev Up (ft) = 7566.00
Rise (in) = 36.0
Shape = Circular
Span (in) = 36.0
No. Barrels = 1
n-Value = 0.012
Culvert Type = Circular Concrete
Culvert Entrance = Square edge w/headwall (C)
Coeff. K,M,c,Y,k = 0.0098, 2, 0.0398, 0.67, 0.5

Embankment


Top Elevation (ft) = 7571.44
Top Width (ft) = 36.00
Crest Width (ft) = 40.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 45.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 45.00
Qpipe (cfs) = 45.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 6.93
Veloc Up (ft/s) = 8.16
HGL Dn (ft) = 7565.46
HGL Up (ft) = 7568.18
Hw Elev (ft) = 7569.57
Hw/D (ft) = 1.19
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Nov 30 2017

DP 26 CULVERT

Invert Elev Dn (ft) = 7532.00
Pipe Length (ft) = 123.98
Slope (%) = 1.33
Invert Elev Up (ft) = 7533.65
Rise (in) = 48.0
Shape = Circular
Span (in) = 48.0
No. Barrels = 1
n-Value = 0.012
Culvert Type = Circular Concrete
Culvert Entrance = Square edge w/headwall (C)
Coeff. K,M,c,Y,k = 0.0098, 2, 0.0398, 0.67, 0.5

Calculations


Qmin (cfs) = 0.00
Qmax (cfs) = 102.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 102.00
Qpipe (cfs) = 102.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 8.69
Veloc Up (ft/s) = 9.90
HGL Dn (ft) = 7535.53
HGL Up (ft) = 7536.71
Hw Elev (ft) = 7538.93
Hw/D (ft) = 1.32
Flow Regime = Inlet Control

Embankment

Top Elevation (ft) = 7543.81
Top Width (ft) = 36.00
Crest Width (ft) = 50.00



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Nov 30 2017

BASIN CC-15 CULVERT

Invert Elev Dn (ft) = 7564.75
Pipe Length (ft) = 82.63
Slope (%) = 4.54
Invert Elev Up (ft) = 7568.50
Rise (in) = 30.0
Shape = Circular
Span (in) = 30.0
No. Barrels = 1
n-Value = 0.012
Culvert Type = Circular Concrete
Culvert Entrance = Square edge w/headwall (C)
Coeff. K,M,c,Y,k = 0.0098, 2, 0.0398, 0.67, 0.5

Embankment


Top Elevation (ft) = 7572.92
Top Width (ft) = 36.00
Crest Width (ft) = 50.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 21.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 21.00
Qpipe (cfs) = 21.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 4.92
Veloc Up (ft/s) = 6.54
HGL Dn (ft) = 7566.78
HGL Up (ft) = 7570.06
Hw Elev (ft) = 7570.84
Hw/D (ft) = 0.94
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Wednesday, Apr 4 2018

BASIN CC-16 CULVERT

Invert Elev Dn (ft) = 7568.00
Pipe Length (ft) = 100.00
Slope (%) = 1.00
Invert Elev Up (ft) = 7569.00
Rise (in) = 30.0
Shape = Circular
Span (in) = 30.0
No. Barrels = 1
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Square edge w/headwall (C)
Coeff. K,M,c,Y,k = 0.0098, 2, 0.0398, 0.67, 0.5

Embankment


Top Elevation (ft) = 7574.00
Top Width (ft) = 36.00
Crest Width (ft) = 50.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 24.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 24.00
Qpipe (cfs) = 24.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 5.49
Veloc Up (ft/s) = 6.90
HGL Dn (ft) = 7570.08
HGL Up (ft) = 7570.67
Hw Elev (ft) = 7571.63
Hw/D (ft) = 1.05
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Wednesday, Apr 4 2018

DP 30 CULVERT

Invert Elev Dn (ft) = 7565.50
Pipe Length (ft) = 100.00
Slope (%) = 0.50
Invert Elev Up (ft) = 7566.00
Rise (in) = 24.0
Shape = Circular
Span (in) = 24.0
No. Barrels = 1
n-Value = 0.013
Culvert Type = Circular Concrete
Culvert Entrance = Square edge w/headwall (C)
Coeff. K,M,c,Y,k = 0.0098, 2, 0.0398, 0.67, 0.5

Embankment


Top Elevation (ft) = 7569.00
Top Width (ft) = 36.00
Crest Width (ft) = 40.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 10.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 10.00
Qpipe (cfs) = 10.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 3.79
Veloc Up (ft/s) = 5.46
HGL Dn (ft) = 7567.07
HGL Up (ft) = 7567.13
Hw Elev (ft) = 7567.69
Hw/D (ft) = 0.84
Flow Regime = Inlet Control



Culvert Report

Hydraflow Express Extension for Autodesk® AutoCAD® Civil 3D® by Autodesk, Inc.

Thursday, Nov 30 2017

DP 32 CULVERT

Invert Elev Dn (ft) = 7543.08
Pipe Length (ft) = 83.29
Slope (%) = 2.91
Invert Elev Up (ft) = 7545.50
Rise (in) = 36.0
Shape = Circular
Span (in) = 36.0
No. Barrels = 1
n-Value = 0.012
Culvert Type = Circular Concrete
Culvert Entrance = Square edge w/headwall (C)
Coeff. K,M,c,Y,k = 0.0098, 2, 0.0398, 0.67, 0.5

Embankment


Top Elevation (ft) = 7549.16
Top Width (ft) = 36.00
Crest Width (ft) = 40.00

Calculations

Qmin (cfs) = 0.00
Qmax (cfs) = 40.00
Tailwater Elev (ft) = (dc+D)/2

Highlighted

Qtotal (cfs) = 40.00
Qpipe (cfs) = 40.00
Qovertop (cfs) = 0.00
Veloc Dn (ft/s) = 6.29
Veloc Up (ft/s) = 7.74
HGL Dn (ft) = 7545.61
HGL Up (ft) = 7547.56
Hw Elev (ft) = 7548.76
Hw/D (ft) = 1.09
Flow Regime = Inlet Control



Rock Chute Design Data

(Version 4.01 - 04/23/03, Based on Design of Rock Chutes by Robinson, Rice, Kadavy, ASAE, 1998)

Project: Flying Horse Filing No. 1 (Pond 4)
Designer: Marc Whorton
Date: 11/30/2017

County: EL Paso
Checked by: _____
Date: _____


Input Channel Geometry

| Inlet Channel | Chute | Outlet Channel |
|----------------------------|--|----------------------------|
| Bw = 20.0 ft. | Bw = 15.0 ft. | Bw = 18.0 ft. |
| Side slopes = 4.0 (m:1) | Factor of safety = 1.20 (F_s) | Side slopes = 4.0 (m:1) |
| n-value = 0.035 | Side slopes = 4.0 (m:1) → 2.0:1 max. | n-value = 0.035 |
| Bed slope = 0.0100 ft./ft. | Bed slope (4:1) = 0.250 ft./ft. → 2.5:1 max. | Bed slope = 0.0100 ft./ft. |
| Freeboard = 2.0 ft. | Outlet apron depth, d = 1.5 ft. | Base flow = 40.0 cfs |


Design Storm Data (Table 2, NHCP, NRCS Grade Stabilization Structure No. 410)

| | | |
|--|--|---|
| Drainage area = _____ acres | Rainfall = <input type="radio"/> 0 - 3 in. <input checked="" type="radio"/> 3 - 5 in. <input type="radio"/> 5+ in. | Note: The total required capacity is routed through the chute (principal spillway) or in combination with an auxiliary spillway. |
| Apron elev. --- Inlet = 7436.0 ft. --- Outlet = 7426.0 ft. --- ($H_{drop} = 8.5$ ft.) | | Input tailwater (T_w): |
| Chute capacity = Q10-year | Minimum capacity (based on a 5-year, 24-hour storm with a 3 - 5 inch rainfall) | |
| Total capacity = Q25-year | | |
| $Q_{high} = 170.0$ cfs | High flow storm through chute | T_w (ft.) = Program 0.25 |
| $Q_{low} = 40.0$ cfs | Low flow storm through chute | T_w (ft.) = Program |

Profile and Cross Section (Output)



Profile Along Centerline of Chute



Rock Chute Design - Plan Sheet

(Version 4.0 - 07/10/00, Based on Design of Rock Chutes by Robinson, Rice, Kadavy, ASAE, 1998)

Project: Flying Horse Filing No. 1 (Pond 4)
Designer: Marc Whorton
Date: 11/30/2017

County: EL Paso
Checked by: _____
Date: _____

Design Values

Angular D_{50} dia. = 14.2 in.
 Rock_{chute} thickness = 28.3 in.
 Inlet apron length = 14 ft.
 Outlet apron length = 18 ft.
 Radius = 39 ft.

Rock Gradation Envelope

| % Passing | Diameter, in. (weight, lbs.) |
|-----------------|------------------------------|
| D_{100} ----- | 21 - 28 (704 - 1669) |
| D_{85} ----- | 18 - 26 (458 - 1217) |
| D_{50} ----- | 14 - 21 (209 - 704) |
| D_{10} ----- | 11 - 18 (107 - 458) |

Quantities^a

Angular Rock = 291 yd³
 Geotextile (8 oz.)^b = 456 yd²
 Bedding (6 in.) = 79 yd³
 Excavation = 700 yd³
 Earthfill = 500 yd³
 Seeding = 1.0 acres


Will bedding be used? Yes ----- Depth (in.) = 6.0

Notes: ^a Rock, bedding, and geotextile quantities are determined from the x-section below (neglect radius).

^b Geotextile shall be overlapped (18-in. min.) and anchored (18-in. min. along sides and 24-in. min. on the ends).

Rock Chute Cost Estimate

| Unit | Unit Cost | Cost |
|------------|--------------------------|--------------------------|
| Rock | \$36.00 /yd ³ | \$10,476.00 |
| Geotextile | \$2.00 /yd ² | \$912.00 |
| Bedding | \$8.00 /yd ³ | \$632.00 |
| Excavation | \$3.00 /yd ³ | \$2,100.00 |
| Earthfill | \$1.00 /yd ³ | \$500.00 |
| Seeding | \$500.00 /ac. | \$500.00 |
| | | Total \$15,120.00 |




Profile Along Centerline of Rock Chute


****Note:** The outlet **will** function adequately

Stakeout Notes


| Sta. | Elev. (Pnt) |
|--------|----------------|
| 0+00 | 7436 ft. (1) |
| 0+9.2 | 7436 ft. (2) |
| 0+14 | 7435.7 ft. (3) |
| 0+18.7 | 7434.8 ft. (4) |
| 0+54 | 7426 ft. (5) |
| 0+72 | 7426 ft. (6) |
| 0+75.8 | 7427.5 ft. (7) |



Inlet Channel Cross Section



Rock Chute Cross Section * Use H_p throughout chute but not less than z_2 .



Outlet Channel Cross Section

Profile, Cross Sections, and Quantities

Project: Flying Horse Filing No. 1 (Pond 4)
Location: EL Paso County

**U.S. Department of Agriculture
 Natural Resources Conservation Service**

| | |
|----------------------------------|--------------------|
| Designed: <u>Marc Whorton</u> | Approved by: _____ |
| Drawn: <u>NRCS Standard Dwg.</u> | Title: _____ |
| Traced: _____ | Title: _____ |
| Checked: _____ | Sheet No. _____ |
| | Drawing No. _____ |



Publication No. FHWA-NHI-05-114
September 2005

U.S. Department of Transportation

**Federal Highway
Administration**

Hydraulic Engineering Circular No. 15, Third Edition

Design of Roadside Channels with Flexible Linings



National Highway Institute

Table 2.1. Typical Roughness Coefficients for Selected Linings

| Lining Category | Lining Type | Manning's n ¹ | | |
|-----------------|----------------------------|--------------------------|---------|---------|
| | | Maximum | Typical | Minimum |
| Rigid | Concrete | 0.015 | 0.013 | 0.011 |
| | Grouted Riprap | 0.040 | 0.030 | 0.028 |
| | Stone Masonry | 0.042 | 0.032 | 0.030 |
| | Soil Cement | 0.025 | 0.022 | 0.020 |
| | Asphalt | 0.018 | 0.016 | 0.016 |
| Unlined | Bare Soil ² | 0.025 | 0.020 | 0.016 |
| | Rock Cut (smooth, uniform) | 0.045 | 0.035 | 0.025 |
| RECP | Open-weave textile | 0.028 | 0.025 | 0.022 |
| | Erosion control blankets | 0.045 | 0.035 | 0.028 |
| | Turf reinforcement mat | 0.036 | 0.030 | 0.024 |

¹Based on data from Kouwen, et al. (1980), Cox, et al. (1970), McWhorter, et al. (1968) and Thibodeaux (1968).

²Minimum value accounts for grain roughness. Typical and maximum values incorporate varying degrees of form roughness.

Table 2.2. Typical Roughness Coefficients for Riprap, Cobble, and Gravel Linings

| Lining Category | Lining Type | Manning's n for Selected Flow Depths ¹ | | |
|-----------------|------------------------------------|---|-----------------|----------------|
| | | 0.15 m (0.5 ft) | 0.50 m (1.6 ft) | 1.0 m (3.3 ft) |
| Gravel Mulch | D ₅₀ = 25 mm (1 in.) | 0.040 | 0.033 | 0.031 |
| | D ₅₀ = 50 mm (2 in.) | 0.056 | 0.042 | 0.038 |
| Cobbles | D ₅₀ = 0.10 m (0.33 ft) | -- ² | 0.055 | 0.047 |
| Rock Riprap | D ₅₀ = 0.15 m (0.5 ft) | -- ² | 0.069 | 0.056 |
| | D ₅₀ = 0.30 m (1.0 ft) | -- ² | -- ² | 0.080 |

¹Based on Equation 6.1 (Blodgett and McConaughy, 1985). Manning's n estimated assuming a trapezoidal channel with 1:3 side slopes and 0.6 m (2 ft) bottom width.

²Shallow relative depth (average depth to D₅₀ ratio less than 1.5) requires use of Equation 6.2 (Bathurst, et al., 1981) and is slope-dependent. See Section 6.1.

2.2 SHEAR STRESS

2.2.1 Equilibrium Concepts

Most highway drainage channels cannot tolerate bank instability and possible lateral migration. Stable channel design concepts focus on evaluating and defining a channel configuration that will perform within acceptable limits of stability. Methods for evaluation and definition of a stable configuration depend on whether the channel boundaries can be viewed as:

- essentially rigid (static)
- movable (dynamic).

In the first case, stability is achieved when the material forming the channel boundary effectively resists the erosive forces of the flow. Under such conditions the channel bed and banks are in

protected. Therefore permissible shear stress is not significantly affected by the erodibility of the underlying soil. However, if the lining moves, the underlying soil will be exposed to the erosive force of the flow.

Table 2.3 provides typical examples of permissible shear stress for selected lining types. Representative values for different soil types are based on the methods found in Chapter 4 while those for gravel mulch and riprap are based on methods found in Chapter 7. Vegetative and RECP lining performance relates to how well they protect the underlying soil from shear stresses so these linings do not have permissible shear stresses independent of soil types. Chapters 4 (vegetation) and 5 (RECPs) describe the methods for analyzing these linings. Permissible shear stress for gabion mattresses depends on rock size and mattress thickness as is described in Section 7.2.

Table 2.3. Typical Permissible Shear Stresses for Bare Soil and Stone Linings

| Lining Category | Lining Type | Permissible Shear Stress | |
|--|--|--------------------------|--------------------|
| | | N/m ² | lb/ft ² |
| Bare Soil ¹ Cohesive (PI = 10) | Clayey sands | 1.8-4.5 | 0.037-0.095 |
| | Inorganic silts | 1.1-4.0 | 0.027-0.11 |
| | Silty sands | 1.1-3.4 | 0.024-0.072 |
| Bare Soil ¹ Cohesive (PI ≥ 20) | Clayey sands | 4.5 | 0.094 |
| | Inorganic silts | 4.0 | 0.083 |
| | Silty sands | 3.5 | 0.072 |
| | Inorganic clays | 6.6 | 0.14 |
| Bare Soil ² Non-cohesive (PI < 10) | Finer than coarse sand D ₇₅ < 1.3 mm (0.05 in) | 1.0 | 0.02 |
| | Fine gravel D ₇₅ = 7.5 mm (0.3 in) | 5.6 | 0.12 |
| | Gravel D ₇₅ = 15 mm (0.6 in) | 11 | 0.24 |
| Gravel Mulch ³ | Coarse gravel D ₅₀ = 25 mm (1 in) | 19 | 0.4 |
| | Very coarse gravel D ₅₀ = 50 mm (2 in) | 38 | 0.8 |
| Rock Riprap ³ | D ₅₀ = 0.15 m (0.5 ft) | 113 | 2.4 |
| | D ₅₀ = 0.30 m (1.0 ft) | 227 | 4.8 |

¹Based on Equation 4.6 assuming a soil void ratio of 0.5 (USDA, 1987).

²Based on Equation 4.5 derived from USDA (1987)

³Based on Equation 6.7 with Shield's parameter equal to 0.047.

2.3 DESIGN PARAMETERS

2.3.1 Design Discharge Frequency

Design flow rates for permanent roadside and median drainage channel linings usually have a 5 or 10-year return period. A lower return period flow is allowable if a transitional lining is to be used, typically the mean annual storm (approximately a 2-year return period, i.e., 50 percent probability of occurrence in a year). Transitional channel linings are often used during the establishment of vegetation. The probability of damage during this relatively short time is low,

- significant uncertainty regarding the design discharge
- consequences of failure are high

The basic procedure for flexible lining design consists of the following steps and is summarized in Figure 3.1. (An alternative process for determining an allowable discharge given slope and shape is presented in Section 3.6.)





Figure 3.1. Flexible Channel Lining Design Flow Chart

APPENDIX B: CHANNEL GEOMETRY EQUATIONS

V- SHAPE




$$A = Zd^2$$

$$p = 2d\sqrt{Z^2 + 1}$$

$$T = 2dZ$$

TRAPEZOIDAL




$$A = Bd + Zd^2$$

$$P = B + 2d\sqrt{Z^2 + 1}$$

$$T = B + 2dZ$$

PARABOLIC




$$A = \frac{2}{3}Td$$

$$P = \frac{1}{2}\sqrt{16d^2 + T^2} + \left(\frac{T^2}{8d}\right)\ln_e\left(\frac{4d + \sqrt{16d^2 + T^2}}{T}\right)$$

$$T = 1.5\frac{A}{d}$$

V-SHAPE WITH ROUNDED BOTTOM



2 CASES

No. 1

If $d \leq 1/Z$, then:

$$A = \frac{8}{3}d\sqrt{dZ}$$

$$P = 2Z \ln_e \left(\sqrt{\frac{d}{Z}} + \sqrt{1 + \frac{d}{Z}} \right) + 2\sqrt{d^2 + dZ}$$

$$T = 4\sqrt{dZ}$$

No. 2

If $d > 1/Z$, then:

$$A = \frac{8}{3}d + 4\left(d - \frac{1}{Z}\right) + Z\left(d - \frac{1}{Z}\right)^2$$

$$P = 2Z \ln_e \left(\frac{1 + \sqrt{Z^2 + 1}}{Z} \right) + 2\frac{\sqrt{Z^2 + 1}}{Z} + 2\left(d - \frac{1}{Z}\right)\sqrt{1 + Z^2}$$

$$T = 4 + 2Z\left(d - \frac{1}{Z}\right)$$

Note: The equations for V-shape with rounded bottom only apply in customary units for a channel with a 4 ft wide rounded bottom.

Channel Report

Natural Channel to Pond 12 (channel approaching pond)

Trapezoidal


| | |
|-------------------|----------------|
| Bottom Width (ft) | = 8.00 |
| Side Slopes (z:1) | = 30.00, 10.00 |
| Total Depth (ft) | = 1.00 |
| Invert Elev (ft) | = 7560.00 |
| Slope (%) | = 2.70 |
| N-Value | = 0.030 |

Highlighted

| | |
|---------------------|---------|
| Depth (ft) | = 0.68 |
| Q (cfs) | = 65.00 |
| Area (sqft) | = 14.69 |
| Velocity (ft/s) | = 4.43 |
| Wetted Perim (ft) | = 35.25 |
| Crit Depth, Yc (ft) | = 0.75 |
| Top Width (ft) | = 35.20 |
| EGL (ft) | = 0.98 |

Calculations


| | |
|---------------|---------|
| Compute by: | Known Q |
| Known Q (cfs) | = 65.00 |



Channel Report

Natural Channel to Pond 12 (Just north of Stagecoach Rd.)

| | | | |
|---------------------|----------------|---------------------|---------|
| Trapezoidal | | Highlighted | |
| Bottom Width (ft) | = 8.00 | Depth (ft) | = 0.72 |
| Side Slopes (z:1) | = 20.00, 20.00 | Q (cfs) | = 45.00 |
| Total Depth (ft) | = 1.00 | Area (sqft) | = 16.13 |
| Invert Elev (ft) | = 7560.00 | Velocity (ft/s) | = 2.79 |
| Slope (%) | = 1.00 | Wetted Perim (ft) | = 36.84 |
| N-Value | = 0.030 | Crit Depth, Yc (ft) | = 0.63 |
| Calculations | | Top Width (ft) | = 36.80 |
| Compute by: | | EGL (ft) | = 0.84 |
| Known Q (cfs) | = 45.00 | | |




Channel Report

Natural Channel running through lots 58-59

| | | | |
|---------------------|--------------|---------------------|---------|
| Trapezoidal | | Highlighted | |
| Bottom Width (ft) | = 5.00 | Depth (ft) | = 0.72 |
| Side Slopes (z:1) | = 6.00, 6.00 | Q (cfs) | = 46.00 |
| Total Depth (ft) | = 1.00 | Area (sqft) | = 6.71 |
| Invert Elev (ft) | = 7600.00 | Velocity (ft/s) | = 6.86 |
| Slope (%) | = 5.00 | Wetted Perim (ft) | = 13.76 |
| N-Value | = 0.030 | Crit Depth, Yc (ft) | = 0.96 |
| Calculations | | Top Width (ft) | = 13.64 |
| Compute by: | Known Q | EGL (ft) | = 1.45 |
| Known Q (cfs) | = 46.00 | | |

The velocity appears to be greater than permissible velocities for native grass (typically 4 fps for short native grass). Improvements appears to be required for erosion protection. Check the other channel reports and update narrative to discuss the findings.

Include the Froude number in all the channel reports. See DCM 6.5.2



Channel Report

Natural Channel running through lots 46-50

Trapezoidal


Bottom Width (ft) = 5.00
Side Slopes (z:1) = 10.00, 10.00
Total Depth (ft) = 1.00
Invert Elev (ft) = 7600.00
Slope (%) = 6.00
N-Value = 0.030

Highlighted

Depth (ft) = 0.44
Q (cfs) = 22.00
Area (sqft) = 4.14
Velocity (ft/s) = 5.32
Wetted Perim (ft) = 13.84
Crit Depth, Yc (ft) = 0.59
Top Width (ft) = 13.80
EGL (ft) = 0.88

Calculations

Compute by: Known Q
Known Q (cfs) = 22.00



Channel Report

Natural Channel from DP 15

Trapezoidal


Bottom Width (ft) = 10.00
Side Slopes (z:1) = 4.00, 4.00
Total Depth (ft) = 1.00
Invert Elev (ft) = 7460.00
Slope (%) = 4.50
N-Value = 0.030

Calculations

Compute by: Known Q
Known Q (cfs) = 15.00

Highlighted

Depth (ft) = 0.31
Q (cfs) = 15.00
Area (sqft) = 3.48
Velocity (ft/s) = 4.30
Wetted Perim (ft) = 12.56
Crit Depth, Yc (ft) = 0.40
Top Width (ft) = 12.48
EGL (ft) = 0.60



Channel Report

Natural Channel from DP 14

Trapezoidal


Bottom Width (ft) = 15.00
Side Slopes (z:1) = 10.00, 10.00
Total Depth (ft) = 1.00
Invert Elev (ft) = 7450.00
Slope (%) = 4.50
N-Value = 0.030

Calculations

Compute by: Known Q
Known Q (cfs) = 56.00

Highlighted

Depth (ft) = 0.50
Q (cfs) = 56.00
Area (sqft) = 10.00
Velocity (ft/s) = 5.60
Wetted Perim (ft) = 25.05
Crit Depth, Yc (ft) = 0.66
Top Width (ft) = 25.00
EGL (ft) = 0.99



Channel Report

Natural Channel from DP 2

Trapezoidal


| | |
|-------------------|----------------|
| Bottom Width (ft) | = 5.00 |
| Side Slopes (z:1) | = 30.00, 30.00 |
| Total Depth (ft) | = 1.00 |
| Invert Elev (ft) | = 7560.00 |
| Slope (%) | = 5.00 |
| N-Value | = 0.030 |

Highlighted

| | |
|---------------------|---------|
| Depth (ft) | = 0.44 |
| Q (cfs) | = 35.00 |
| Area (sqft) | = 8.01 |
| Velocity (ft/s) | = 4.37 |
| Wetted Perim (ft) | = 31.41 |
| Crit Depth, Yc (ft) | = 0.54 |
| Top Width (ft) | = 31.40 |
| EGL (ft) | = 0.74 |

Calculations

| | |
|---------------|---------|
| Compute by: | Known Q |
| Known Q (cfs) | = 35.00 |



$$H_a = \frac{(H + Y_n)}{2}$$

Equation 9-19

Where the maximum value of H_a shall not exceed H , and:


D_a = parameter to use in place of D in Figure 9-38 when flow is supercritical (ft)

D_c = diameter of circular culvert (ft)

H_a = parameter to use in place of H in Figure 9-39 when flow is supercritical (ft)

H = height of rectangular culvert (ft)

Y_n = normal depth of supercritical flow in the culvert (ft)



Use D_a instead of D whenever flow is supercritical in the barrel.

** Use Type L for a distance of $3D$ downstream.

Figure 9-38. Riprap erosion protection at circular conduit outlet (valid for $Q/D^{2.5} \leq 6.0$)

RIP-RAP CALCULATIONS

| Design Point | Flow (cfs) | Tailwater Depth (ft.) (See Culvert Reports) | Pipe Diameter (ft.) | $Q / D^{1.5}$ | Y_1 / D | Rock Type (See Fig. 9-38) | Rock Size (d50) (in.) |
|-------------------|------------|--|---------------------|---------------|-----------|------------------------------|-----------------------|
| DP-1 | 11 | 1.62 | 2.0 | 3.9 | 0.8 | Type L | 9" |
| DP-2 | 35 | 2.25 | 2.5 | 8.9 | 0.9 | Type L | 9" |
| Fire Station Dwy. | 5 | 1.18 | 1.5 | 2.7 | 0.8 | Type L | 9" |
| DP-4 | 11 | 1.40 | 1.5 | 6.0 | 0.9 | Type L | 9" |
| DP-5 | 15 | 1.45 | 1.5 | 8.2 | 1.0 | Type L | 9" |
| DP-7 | 38 | 1.99 | 2.5 | 9.6 | 0.8 | Type L | 9" |
| DP-8 | 284 | 3.46 | 4.0 | 35.5 | 0.9 | Type M | 12" |
| DP-9 | 23 | 1.61 | 2.0 | 8.1 | 0.8 | Type L | 9" |
| DP-10 | 144 | 3.08 | 3.5 | 22.0 | 0.9 | Type L | 9" |
| DP-11 | 36 | 1.76 | 2.0 | 12.7 | 0.9 | Type L | 9" |
| DP-12 | 44 | 2.58 | 3.0 | 8.5 | 0.9 | Type L | 9" |
| DP-14 | 56 | 1.78 | 2.0 | 19.8 | 0.9 | Type L | 9" |
| DP-15 | 15 | 1.28 | 1.5 | 8.2 | 0.9 | Type L | 9" |
| DP-24 | 45 | 2.59 | 3.0 | 8.7 | 0.9 | Type L | 9" |
| DP-26 | 102 | 3.53 | 4.0 | 12.8 | 0.9 | Type L | 9" |
| Basin CC-15 | 21 | 2.03 | 2.5 | 5.3 | 0.8 | Type L | 9" |
| Basin CC-16 | 24 | 2.08 | 2.5 | 6.1 | 0.8 | Type L | 9" |
| DP-30 | 10 | 1.57 | 2.0 | 3.5 | 0.8 | Type L | 9" |
| DP-32 | 40 | 2.53 | 3.0 | 7.7 | 0.8 | Type L | 9" |

DETENTION FACILITY CALCULATIONS

Design Procedure Form: Extended Detention Basin (EDB)

UD-BMP (Version 3.06, November 2016)

Sheet 1 of 4

Designer: Marc A. Whorton, P.E.
Company: Classic Consulting
Date: November 27, 2017
Project: Flying Horse North Filing No. 1
Location: Pond 1

1. Basin Storage Volume

- A) Effective Imperviousness of Tributary Area, I_a
- B) Tributary Area's Imperviousness Ratio ($i = I_a / 100$)
- C) Contributing Watershed Area
- D) For Watersheds Outside of the Denver Region, Depth of Average Runoff Producing Storm
- E) Design Concept
(Select EURV when also designing for flood control)
- F) Design Volume (WQCV) Based on 40-hour Drain Time
($V_{DESIGN} = (1.0 * (0.91 * i^3 - 1.19 * i^2 + 0.78 * i) / 12 * \text{Area})$)
- G) For Watersheds Outside of the Denver Region, Water Quality Capture Volume (WQCV) Design Volume
($V_{WQCV \text{ OTHER}} = (d_6 * (V_{DESIGN} / 0.43))$)
- H) User Input of Water Quality Capture Volume (WQCV) Design Volume
(Only if a different WQCV Design Volume is desired)
- I) Predominant Watershed NRCS Soil Group
- J) Excess Urban Runoff Volume (EURV) Design Volume
 For HSG A: $EURV_A = 1.68 * i^{1.28}$
 For HSG B: $EURV_B = 1.36 * i^{1.08}$
 For HSG C/D: $EURV_{C/D} = 1.20 * i^{1.08}$

$I_a = 20.0$ %

$i = 0.200$

Area = 21.800 ac

$d_6 = 0.42$ in

Choose One

- ☐ Water Quality Capture Volume (WQCV)
☒ Excess Urban Runoff Volume (EURV)

$V_{DESIGN} = 0.210$ ac-ft

$V_{DESIGN \text{ OTHER}} = 0.205$ ac-ft

$V_{DESIGN \text{ USER}} =$ ac-ft

Choose One

- ☐ A
☒ B
☐ C / D

EURV = 0.434 ac-ft

2. Basin Shape: Length to Width Ratio

(A basin length to width ratio of at least 2:1 will improve TSS reduction.)

L : W = 2.0 : 1

3. Basin Side Slopes

- A) Basin Maximum Side Slopes
(Horizontal distance per unit vertical, 4:1 or flatter preferred)

Z = 4.00 ft / ft

4. Inlet

- A) Describe means of providing energy dissipation at concentrated inflow locations:

No concentrated inflow. Flows will enter as sheet flow

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 2 of 4

Designer: Marc A. Whorton, P.E.
Company: Classic Consulting
Date: November 27, 2017
Project: Flying Horse North Filing No. 1
Location: Pond 1

5. Forebay

A) Minimum Forebay Volume
($V_{FMIN} = 2\%$ of the WQCV)

$V_{FMIN} = 0.004$ ac-ft

B) Actual Forebay Volume

$V_F = 0.005$ ac-ft

C) Forebay Depth
($D_F = 18$ inch maximum)

$D_F = 12.0$ in

D) Forebay Discharge

i) Undetained 100-year Peak Discharge

$Q_{100} = 38.00$ cfs

ii) Forebay Discharge Design Flow
($Q_F = 0.02 * Q_{100}$)

$Q_F = 0.76$ cfs

E) Forebay Discharge Design

Choose One
☐ Berm With Pipe
☒ Wall with Rect. Notch
☐ Wall with V-Notch Weir

(flow too small for berm w/ pipe)

F) Discharge Pipe Size (minimum 8-inches)

Calculated $D_p =$ in

G) Rectangular Notch Width

Calculated $W_N = 5.1$ in

6. Trickle Channel

A) Type of Trickle Channel

Choose One
☐ Concrete
☒ Soft Bottom

PROVIDE A CONSISTENT LONGITUDINAL SLOPE FROM FOREBAY TO MICROPOL WITH NO MEANDERING. RIPRAP AND SOIL RIPRAP LINED CHANNELS ARE NOT RECOMMENDED. MINIMUM DEPTH OF 1.5 FEET

F) Slope of Trickle Channel

$S = 0.0100$ ft / ft

7. Micropool and Outlet Structure

A) Depth of Micropool (2.5-feet minimum)

$D_M = 2.5$ ft

B) Surface Area of Micropool (10 ft² minimum)

$A_M = 50$ sq ft

C) Outlet Type

Choose One
☒ Orifice Plate
☐ Other (Describe):

D) Smallest Dimension of Orifice Opening Based on Hydrograph Routing
(Use UD-Detention)

$D_{orifice} = 1.13$ inches

E) Total Outlet Area

$A_{ot} = 5.16$ square inches

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 3 of 4

Designer: Marc A. Whorton, P.E.
 Company: Classic Consulting
 Date: November 27, 2017
 Project: Flying Horse North Filing No. 1
 Location: Pond 1

8. Initial Surge Volume

- A) Depth of Initial Surge Volume
(Minimum recommended depth is 4 inches)
- B) Minimum Initial Surge Volume
(Minimum volume of 0.3% of the WQCV)
- C) Initial Surge Provided Above Micropool

$D_{IS} =$ 6 in

$V_{IS} =$ cu ft

$V_s =$ 25.0 cu ft

9. Trash Rack

- A) Water Quality Screen Open Area: $A_t = A_{ot} * 38.5 * (e^{-0.095D})$
- B) Type of Screen (If specifying an alternative to the materials recommended in the USDCM, indicate "other" and enter the ratio of the total open area to the total screen area for the material specified.)
- Other (Y/N): N
- C) Ratio of Total Open Area to Total Area (only for type 'Other')
- D) Total Water Quality Screen Area (based on screen type)
- E) Depth of Design Volume (EURV or WQCV)
(Based on design concept chosen under 1E)
- F) Height of Water Quality Screen (H_{TR})
- G) Width of Water Quality Screen Opening ($W_{opening}$)
(Minimum of 12 inches is recommended)

$A_t =$ 179 square inches

S.S. Well Screen with 60% Open Area

User Ratio =

$A_{total} =$ 298 sq. in.

$H =$ 2.75 feet

$H_{TR} =$ 61 inches

$W_{opening} =$ 12.0 inches

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 4 of 4

Designer: Marc A. Whorton, P.E.
Company: Classic Consulting
Date: November 27, 2017
Project: Flying Horse North Filing No. 1
Location: Pond 1

10. Overflow Embankment

A) Describe embankment protection for 100-year and greater overtopping:

Soil Rip-Rap

B) Slope of Overflow Embankment
(Horizontal distance per unit vertical, 4:1 or flatter preferred)

4.00

11. Vegetation

Choose One

☐ Irrigated

☒ Not Irrigated

12. Access

A) Describe Sediment Removal Procedures

Notes:

Site-Level Low Impact Development (LID) Design Effective Impervious Calculator

LID Credit by Impervious Reduction Factor (IRF) Method

UD-BMP (Version 3.06, November 2016)

User Input

Calculated cells

| | | | |
|--|----------------|------|--------|
| ***Design Storm: 1-Hour Rain Depth | WQCV Event | 0.42 | inches |
| ***Minor Storm: 1-Hour Rain Depth | 5-Year Event | 1.50 | inches |
| ***Major Storm: 1-Hour Rain Depth | 100-Year Event | 2.52 | inches |
| Optional User Defined Storm | CUHP | | |
| (CUHP) NOAA 1 Hour Rainfall Depth and Frequency for User Defined Storm | 100-Year Event | 2.52 | |

Max Intensity for Optional User Defined Storm

| |
|---------|
| 2.51496 |
|---------|

Designer: Marc A. Whorton, P.E.

Company: Classic Consulting

Date: November 30, 2017

Project: Flying Horse North (Trib. Basins to Pond 4)

Location: Black Forest, CO

SITE INFORMATION (USER-INPUT)

| Sub-basin Identifier | OS-8 | OS-9 | OS-10 | OS-11 | BS-13 | BS-14 | BS-15 | BS-16 | BS-17 | | | | | |
|--|------------|------------|------------|------------|------------|------------|------------|------------|------------|--|--|--|--|--|
| Receiving Pervious Area Soil Type | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | | | | | |
| Total Area (ac., Sum of DCIA, UIA, RPA, & SPA) | 14.200 | 9.800 | 4.100 | 28.000 | 25.600 | 13.400 | 5.300 | 21.600 | 12.100 | | | | | |
| Directly Connected Impervious Area (DCIA, acres) | 0.950 | 0.000 | 0.180 | 0.500 | 2.200 | 1.100 | 0.760 | 1.900 | 1.600 | | | | | |
| Unconnected Impervious Area (UIA, acres) | 0.520 | 0.000 | 0.200 | 0.500 | 1.000 | 0.500 | 0.200 | 1.200 | 0.400 | | | | | |
| Receiving Pervious Area (RPA, acres) | 3.000 | 0.000 | 1.200 | 6.300 | 5.000 | 3.000 | 1.000 | 6.000 | 2.000 | | | | | |
| Separate Pervious Area (SPA, acres) | 9.730 | 9.800 | 2.520 | 20.700 | 17.400 | 8.800 | 3.340 | 12.500 | 8.100 | | | | | |
| RPA Treatment Type: Conveyance (C), Volume (V), or Permeable Pavement (PP) | C | C | C | C | C | C | C | C | C | | | | | |

CALCULATED RESULTS (OUTPUT)

| | | | | | | | | | | | | | | |
|--|--------|--------|-------|--------|--------|--------|-------|--------|--------|--|--|--|--|--|
| Total Calculated Area (ac, check against input) | 14.200 | 9.800 | 4.100 | 28.000 | 25.600 | 13.400 | 5.300 | 21.600 | 12.100 | | | | | |
| Directly Connected Impervious Area (DCIA, %) | 6.7% | 0.0% | 4.4% | 1.8% | 8.6% | 8.2% | 14.3% | 8.8% | 13.2% | | | | | |
| Unconnected Impervious Area (UIA, %) | 3.7% | 0.0% | 4.9% | 1.8% | 3.9% | 3.7% | 3.8% | 5.6% | 3.3% | | | | | |
| Receiving Pervious Area (RPA, %) | 21.1% | 0.0% | 29.3% | 22.5% | 19.5% | 22.4% | 18.9% | 27.8% | 16.5% | | | | | |
| Separate Pervious Area (SPA, %) | 68.5% | 100.0% | 61.5% | 73.9% | 68.0% | 65.7% | 63.0% | 57.9% | 66.9% | | | | | |
| A _u (RPA / UIA) | 5.769 | 0.000 | 6.000 | 12.600 | 5.000 | 6.000 | 5.000 | 5.000 | 5.000 | | | | | |
| I _u Check | 0.150 | 1.000 | 0.140 | 0.070 | 0.170 | 0.140 | 0.170 | 0.170 | 0.170 | | | | | |
| f / i for WQCV Event: | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | | | | | |
| f / i for 5-Year Event: | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | | | | | |
| f / i for 100-Year Event: | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 | | | | | |
| f / i for Optional User Defined Storm CUHP: | 0.39 | 0.39 | 0.39 | 0.39 | 0.39 | 0.39 | 0.39 | 0.39 | 0.39 | | | | | |
| IRF for WQCV Event: | 0.32 | 1.00 | 0.30 | 0.15 | 0.37 | 0.30 | 0.37 | 0.37 | 0.37 | | | | | |
| IRF for 5-Year Event: | 0.63 | 1.00 | 0.59 | 0.29 | 0.71 | 0.59 | 0.71 | 0.71 | 0.71 | | | | | |
| IRF for 100-Year Event: | 0.65 | 1.00 | 0.61 | 0.30 | 0.73 | 0.61 | 0.73 | 0.73 | 0.73 | | | | | |
| IRF for Optional User Defined Storm CUHP: | 0.65 | 1.00 | 0.61 | 0.30 | 0.73 | 0.61 | 0.73 | 0.73 | 0.73 | | | | | |
| Total Site Imperviousness: I _{total} | 10.4% | 0.0% | 9.3% | 3.6% | 12.5% | 11.9% | 18.1% | 14.4% | 16.5% | | | | | |
| Effective Imperviousness for WQCV Event: | 7.9% | 0.0% | 5.9% | 2.1% | 10.0% | 9.3% | 15.7% | 10.8% | 14.4% | | | | | |
| Effective Imperviousness for 5-Year Event: | 9.0% | 0.0% | 7.3% | 2.3% | 11.4% | 10.4% | 17.0% | 12.8% | 15.6% | | | | | |
| Effective Imperviousness for 100-Year Event: | 9.1% | 0.0% | 7.3% | 2.3% | 11.5% | 10.5% | 17.1% | 12.9% | 15.7% | | | | | |
| Effective Imperviousness for Optional User Defined Storm CUHP: | 9.1% | 0.0% | 7.3% | 2.3% | 11.5% | 10.5% | 17.1% | 12.9% | 15.7% | | | | | |

LID / EFFECTIVE IMPERVIOUSNESS CREDITS

| | | | | | | | | | | | | | | |
|--|-------|------|-------|-------|-------|-------|-------|-------|------|-----|-----|-----|-----|-----|
| WQCV Event CREDIT: Reduce Detention By: | 21.0% | N/A | 33.4% | 41.1% | 16.8% | 18.7% | 10.1% | 20.5% | 9.9% | N/A | N/A | N/A | N/A | N/A |
| This line only for 10-Year Event | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 100-Year Event CREDIT**: Reduce Detention By: | 15.3% | N/A | 26.4% | 79.5% | 9.8% | 14.7% | 6.1% | 11.8% | 6.0% | N/A | N/A | N/A | N/A | N/A |
| User Defined CUHP CREDIT: Reduce Detention By: | 7.4% | 0.0% | 12.1% | 13.6% | 5.1% | 7.6% | 3.6% | 6.5% | 3.4% | | | | | |

Total Site Imperviousness: 10.2%

Total Site Effective Imperviousness for WQCV Event: 8.0%

Total Site Effective Imperviousness for 5-Year Event: 9.0%

Total Site Effective Imperviousness for 100-Year Event: 9.1%

Total Site Effective Imperviousness for Optional User Defined Storm CUHP: 9.1%

Notes:

* Use Green-Ampt average infiltration rate values from Table 3-3.

** Flood control detention volume credits based on empirical equations from Storage Chapter of USDCM.

*** Method assumes that 1-hour rainfall depth is equivalent to 1-hour intensity for calculation purposes

Design Procedure Form: Extended Detention Basin (EDB)

UD-BMP (Version 3.06, November 2016)

Sheet 1 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 27, 2017
Project: Flying Horse North Filing 1 (Pond 4)
Location: Black Forest, CO

1. Basin Storage Volume

- A) Effective Imperviousness of Tributary Area, I_a
- B) Tributary Area's Imperviousness Ratio ($i = I_a / 100$)
- C) Contributing Watershed Area
- D) For Watersheds Outside of the Denver Region, Depth of Average Runoff Producing Storm
- E) Design Concept
(Select EURV when also designing for flood control)
- F) Design Volume (WQCV) Based on 40-hour Drain Time
($V_{DESIGN} = (1.0 * (0.91 * i^3 - 1.19 * i^2 + 0.78 * i) / 12 * \text{Area})$)
- G) For Watersheds Outside of the Denver Region, Water Quality Capture Volume (WQCV) Design Volume
($V_{WQCV \text{ OTHER}} = (d_6 * (V_{DESIGN} / 0.43))$)
- H) User Input of Water Quality Capture Volume (WQCV) Design Volume
(Only if a different WQCV Design Volume is desired)
- I) Predominant Watershed NRCS Soil Group
- J) Excess Urban Runoff Volume (EURV) Design Volume
 For HSG A: $EURV_A = 1.68 * i^{1.28}$
 For HSG B: $EURV_B = 1.36 * i^{1.08}$
 For HSG C/D: $EURV_{C/D} = 1.20 * i^{1.08}$

$I_a = 8.0$ %

$i = 0.080$

Area = 134.100 ac

$d_6 = 0.42$ in

Choose One

- ☐ Water Quality Capture Volume (WQCV)
☒ Excess Urban Runoff Volume (EURV)

$V_{DESIGN} = 0.617$ ac-ft

$V_{DESIGN \text{ OTHER}} = 0.603$ ac-ft

$V_{DESIGN \text{ USER}} =$ ac-ft

Choose One

- ☐ A
☒ B
☐ C / D

EURV = 0.993 ac-ft

2. Basin Shape: Length to Width Ratio

(A basin length to width ratio of at least 2:1 will improve TSS reduction.)

L : W = 2.0 : 1

3. Basin Side Slopes

- A) Basin Maximum Side Slopes
(Horizontal distance per unit vertical, 4:1 or flatter preferred)

Z = 4.00 ft / ft

4. Inlet

- A) Describe means of providing energy dissipation at concentrated inflow locations:

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 2 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 27, 2017
Project: Flying Horse North Filing 1 (Pond 4)
Location: Black Forest, CO

5. Forebay

A) Minimum Forebay Volume
($V_{FMIN} = 3\%$ of the WQCV)

$V_{FMIN} = 0.018$ ac-ft

B) Actual Forebay Volume

$V_F = 0.019$ ac-ft

C) Forebay Depth
($D_F = 18$ inch maximum)

$D_F = 12.0$ in

D) Forebay Discharge

i) Undetained 100-year Peak Discharge

$Q_{100} = 217.00$ cfs

ii) Forebay Discharge Design Flow
($Q_F = 0.02 * Q_{100}$)

$Q_F = 4.34$ cfs

E) Forebay Discharge Design

Choose One
☐ Berm With Pipe
☒ Wall with Rect. Notch
☐ Wall with V-Notch Weir

(flow too small for berm w/ pipe)

F) Discharge Pipe Size (minimum 8-inches)

Calculated $D_p =$ in

G) Rectangular Notch Width

Calculated $W_N = 18.0$ in

6. Trickle Channel

A) Type of Trickle Channel

Choose One
☒ Concrete
☐ Soft Bottom

F) Slope of Trickle Channel

$S = 0.0100$ ft / ft

7. Micropool and Outlet Structure

A) Depth of Micropool (2.5-feet minimum)

$D_M = 2.5$ ft

B) Surface Area of Micropool (10 ft² minimum)

$A_M = 160$ sq ft

C) Outlet Type

Choose One
☒ Orifice Plate
☐ Other (Describe):

D) Smallest Dimension of Orifice Opening Based on Hydrograph Routing
(Use UD-Detention)

$D_{orifice} = 1.88$ inches

E) Total Outlet Area

$A_{ot} = 8.58$ square inches

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 3 of 4

Designer: Marc A. Whorton
 Company: Classic Consulting
 Date: November 27, 2017
 Project: Flying Horse North Filing 1 (Pond 4)
 Location: Black Forest, CO

8. Initial Surge Volume

- A) Depth of Initial Surge Volume
(Minimum recommended depth is 4 inches)
- B) Minimum Initial Surge Volume
(Minimum volume of 0.3% of the WQCV)
- C) Initial Surge Provided Above Micropool

$D_{IS} =$ 6 in

$V_{IS} =$ 78.8 cu ft

$V_s =$ 80.0 cu ft

9. Trash Rack

- A) Water Quality Screen Open Area: $A_t = A_{ot} * 38.5 * (e^{-0.095D})$
- B) Type of Screen (If specifying an alternative to the materials recommended in the USDCM, indicate "other" and enter the ratio of the total open area to the total screen area for the material specified.)

Other (Y/N): N

C) Ratio of Total Open Area to Total Area (only for type 'Other')

D) Total Water Quality Screen Area (based on screen type)

E) Depth of Design Volume (EURV or WQCV)
(Based on design concept chosen under 1E)

F) Height of Water Quality Screen (H_{TR})

G) Width of Water Quality Screen Opening ($W_{opening}$)
(Minimum of 12 inches is recommended)

$A_t =$ 276 square inches

Aluminum Amico-Klemp SR Series with Cross Rods 2" O.C.

User Ratio =

$A_{total} =$ 389 sq. in.

$H =$ 4 feet

$H_{TR} =$ 76 inches

$W_{opening} =$ 12.0 inches

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 4 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 27, 2017
Project: Flying Horse North Filing 1 (Pond 4)
Location: Black Forest, CO

10. Overflow Embankment

A) Describe embankment protection for 100-year and greater overtopping:

Soil Rip-Rap

B) Slope of Overflow Embankment
(Horizontal distance per unit vertical, 4:1 or flatter preferred)

4.00

11. Vegetation

Choose One

☐ Irrigated

☒ Not Irrigated

12. Access

A) Describe Sediment Removal Procedures

Notes:

Design Procedure Form: Extended Detention Basin (EDB)

UD-BMP (Version 3.06, November 2016)

Sheet 1 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 30, 2017
Project: Flying Horse North Filing 1 (Pond 4 - North Forbay Design)
Location: Black Forest, CO

1. Basin Storage Volume

- A) Effective Imperviousness of Tributary Area, I_a
- B) Tributary Area's Imperviousness Ratio ($i = I_a / 100$)
- C) Contributing Watershed Area
- D) For Watersheds Outside of the Denver Region, Depth of Average Runoff Producing Storm
- E) Design Concept
(Select EURV when also designing for flood control)
- F) Design Volume (WQCV) Based on 40-hour Drain Time
($V_{DESIGN} = (1.0 * (0.91 * i^3 - 1.19 * i^2 + 0.78 * i) / 12 * \text{Area})$)
- G) For Watersheds Outside of the Denver Region, Water Quality Capture Volume (WQCV) Design Volume
($V_{WQCV \text{ OTHER}} = (d_6 * (V_{DESIGN} / 0.43))$)
- H) User Input of Water Quality Capture Volume (WQCV) Design Volume
(Only if a different WQCV Design Volume is desired)
- I) Predominant Watershed NRCS Soil Group
- J) Excess Urban Runoff Volume (EURV) Design Volume
 For HSG A: $EURV_A = 1.68 * i^{1.28}$
 For HSG B: $EURV_B = 1.36 * i^{1.08}$
 For HSG C/D: $EURV_{C/D} = 1.20 * i^{1.08}$

$I_a = 8.0$ %

$i = 0.080$

Area = 107.200 ac

$d_6 = 0.42$ in

Choose One

- ☐ Water Quality Capture Volume (WQCV)
☒ Excess Urban Runoff Volume (EURV)

$V_{DESIGN} = 0.494$ ac-ft

$V_{DESIGN \text{ OTHER}} = 0.482$ ac-ft

$V_{DESIGN \text{ USER}} =$ ac-ft

Choose One

- ☐ A
☒ B
☐ C / D

EURV = 0.794 ac-ft

2. Basin Shape: Length to Width Ratio

(A basin length to width ratio of at least 2:1 will improve TSS reduction.)

L : W = 2.0 : 1

3. Basin Side Slopes

- A) Basin Maximum Side Slopes
(Horizontal distance per unit vertical, 4:1 or flatter preferred)

Z = 4.00 ft / ft

4. Inlet

- A) Describe means of providing energy dissipation at concentrated inflow locations:

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 2 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 30, 2017
Project: Flying Horse North Filing 1 (Pond 4 - North Forbay Design)
Location: Black Forest, CO

5. Forebay

A) Minimum Forebay Volume
($V_{FMIN} = 3\%$ of the WQCV)

$V_{FMIN} = 0.015$ ac-ft

B) Actual Forebay Volume

$V_F = 0.015$ ac-ft

C) Forebay Depth
($D_F = 18$ inch maximum)

$D_F = 12.0$ in

D) Forebay Discharge

i) Undetained 100-year Peak Discharge

$Q_{100} = 170.00$ cfs

ii) Forebay Discharge Design Flow
($Q_F = 0.02 * Q_{100}$)

$Q_F = 3.40$ cfs

E) Forebay Discharge Design

Choose One
☐ Berm With Pipe
☒ Wall with Rect. Notch
☐ Wall with V-Notch Weir

(flow too small for berm w/ pipe)

F) Discharge Pipe Size (minimum 8-inches)

Calculated $D_p =$ in

G) Rectangular Notch Width

Calculated $W_N = 14.7$ in

6. Trickle Channel

A) Type of Trickle Channel

Choose One
☒ Concrete
☐ Soft Bottom

F) Slope of Trickle Channel

$S = 0.0100$ ft / ft

7. Micropool and Outlet Structure

A) Depth of Micropool (2.5-feet minimum)

$D_M = 2.5$ ft

B) Surface Area of Micropool (10 ft² minimum)

$A_M = 160$ sq ft

C) Outlet Type

Choose One
☒ Orifice Plate
☐ Other (Describe):

D) Smallest Dimension of Orifice Opening Based on Hydrograph Routing
(Use UD-Detention)

$D_{orifice} = 1.88$ inches

E) Total Outlet Area

$A_{ot} = 8.58$ square inches

Design Procedure Form: Extended Detention Basin (EDB)

UD-BMP (Version 3.06, November 2016)

Sheet 1 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 30, 2017
Project: Flying Horse North Filing 1 (Pond 4 - South Forbay Design)
Location: Black Forest, CO

1. Basin Storage Volume

- A) Effective Imperviousness of Tributary Area, I_a
- B) Tributary Area's Imperviousness Ratio ($i = I_a / 100$)
- C) Contributing Watershed Area
- D) For Watersheds Outside of the Denver Region, Depth of Average Runoff Producing Storm
- E) Design Concept
(Select EURV when also designing for flood control)
- F) Design Volume (WQCV) Based on 40-hour Drain Time
($V_{DESIGN} = (1.0 * (0.91 * i^3 - 1.19 * i^2 + 0.78 * i)) / 12 * \text{Area}$)
- G) For Watersheds Outside of the Denver Region, Water Quality Capture Volume (WQCV) Design Volume
($V_{WQCV \text{ OTHER}} = (d_6 * (V_{DESIGN} / 0.43))$)
- H) User Input of Water Quality Capture Volume (WQCV) Design Volume
(Only if a different WQCV Design Volume is desired)
- I) Predominant Watershed NRCS Soil Group
- J) Excess Urban Runoff Volume (EURV) Design Volume
 For HSG A: $EURV_A = 1.68 * i^{1.28}$
 For HSG B: $EURV_B = 1.36 * i^{1.08}$
 For HSG C/D: $EURV_{C/D} = 1.20 * i^{1.08}$

$I_a = 8.0$ %

$i = 0.080$

Area = 26.900 ac

$d_6 = 0.42$ in

Choose One

- ☐ Water Quality Capture Volume (WQCV)
☒ Excess Urban Runoff Volume (EURV)

$V_{DESIGN} = 0.124$ ac-ft

$V_{DESIGN \text{ OTHER}} = 0.121$ ac-ft

$V_{DESIGN \text{ USER}} =$ ac-ft

Choose One

- ☐ A
☒ B
☐ C / D

EURV = 0.199 ac-ft

2. Basin Shape: Length to Width Ratio

(A basin length to width ratio of at least 2:1 will improve TSS reduction.)

L : W = 2.0 : 1

3. Basin Side Slopes

- A) Basin Maximum Side Slopes
(Horizontal distance per unit vertical, 4:1 or flatter preferred)

Z = 4.00 ft / ft

4. Inlet

- A) Describe means of providing energy dissipation at concentrated inflow locations:

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 2 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 30, 2017
Project: Flying Horse North Filing 1 (Pond 4 - South Forbay Design)
Location: Black Forest, CO

5. Forebay

A) Minimum Forebay Volume
($V_{FMIN} = 2\%$ of the WQCV)

$V_{FMIN} = 0.002$ ac-ft

B) Actual Forebay Volume

$V_F = 0.002$ ac-ft

C) Forebay Depth
($D_F = 18$ inch maximum)

$D_F = 8.0$ in

D) Forebay Discharge

i) Undetained 100-year Peak Discharge

$Q_{100} = 56.00$ cfs

ii) Forebay Discharge Design Flow
($Q_F = 0.02 * Q_{100}$)

$Q_F = 1.12$ cfs

E) Forebay Discharge Design

Choose One
☐ Berm With Pipe
☒ Wall with Rect. Notch
☐ Wall with V-Notch Weir

(flow too small for berm w/ pipe)

F) Discharge Pipe Size (minimum 8-inches)

Calculated $D_p =$ in

G) Rectangular Notch Width

Calculated $W_N = 9.0$ in

6. Trickle Channel

A) Type of Trickle Channel

Choose One
☒ Concrete
☐ Soft Bottom

F) Slope of Trickle Channel

$S = 0.0100$ ft / ft

7. Micropool and Outlet Structure

A) Depth of Micropool (2.5-feet minimum)

$D_M = 2.5$ ft

B) Surface Area of Micropool (10 ft² minimum)

$A_M = 160$ sq ft

C) Outlet Type

Choose One
☒ Orifice Plate
☐ Other (Describe):

D) Smallest Dimension of Orifice Opening Based on Hydrograph Routing
(Use UD-Detention)

$D_{orifice} = 1.88$ inches

E) Total Outlet Area

$A_{ot} = 8.58$ square inches

Site-Level Low Impact Development (LID) Design Effective Impervious Calculator

LID Credit by Impervious Reduction Factor (IRF) Method

UD-BMP (Version 3.06, November 2016)

User Input

Calculated cells

| | | | |
|--|----------------|------|--------|
| ***Design Storm: 1-Hour Rain Depth | WQCV Event | 0.42 | inches |
| ***Minor Storm: 1-Hour Rain Depth | 5-Year Event | 1.50 | inches |
| ***Major Storm: 1-Hour Rain Depth | 100-Year Event | 2.52 | inches |
| Optional User Defined Storm | CUHP | | |
| (CUHP) NOAA 1 Hour Rainfall Depth and Frequency for User Defined Storm | 100-Year Event | 2.52 | |

Max Intensity for Optional User Defined Storm 2.51496

Designer: Marc A. Whorton, P.E.

Company: Classic Consulting

Date: November 30, 2017

Project: Flying Horse North (Trib. Basins to Pond 8)

Location: Black Forest, CO

SITE INFORMATION (USER-INPUT)

| Sub-basin Identifier | BS-18 | BS-19 | BS-20 | BS-21 | BS-22 | BS-23 | BS-23A | | | | | | | | |
|--|------------|------------|------------|------------|------------|------------|------------|--|--|--|--|--|--|--|--|
| Receiving Pervious Area Soil Type | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | Loamy Sand | | | | | | | | |
| Total Area (ac., Sum of DCIA, UIA, RPA, & SPA) | 33.800 | 6.300 | 73.900 | 69.500 | 18.100 | 37.100 | 16.300 | | | | | | | | |
| Directly Connected Impervious Area (DCIA, acres) | 1.500 | 1.000 | 4.500 | 4.200 | 1.500 | 3.200 | 2.900 | | | | | | | | |
| Unconnected Impervious Area (UIA, acres) | 1.200 | 0.300 | 3.400 | 3.500 | 1.700 | 2.300 | 1.800 | | | | | | | | |
| Receiving Pervious Area (RPA, acres) | 5.200 | 0.700 | 11.500 | 10.100 | 4.000 | 5.500 | 2.500 | | | | | | | | |
| Separate Pervious Area (SPA, acres) | 25.900 | 4.300 | 54.500 | 51.700 | 10.900 | 26.100 | 9.100 | | | | | | | | |
| RPA Treatment Type: Conveyance (C), Volume (V), or Permeable Pavement (PP) | C | C | C | C | C | C | C | | | | | | | | |

CALCULATED RESULTS (OUTPUT)

| | | | | | | | | | | | | | | | |
|--|--------|-------|--------|--------|--------|--------|--------|--|--|--|--|--|--|--|--|
| Total Calculated Area (ac, check against input) | 33.800 | 6.300 | 73.900 | 69.500 | 18.100 | 37.100 | 16.300 | | | | | | | | |
| Directly Connected Impervious Area (DCIA, %) | 4.4% | 15.9% | 6.1% | 6.0% | 8.3% | 8.6% | 17.8% | | | | | | | | |
| Unconnected Impervious Area (UIA, %) | 3.6% | 4.8% | 4.6% | 5.0% | 9.4% | 6.2% | 11.0% | | | | | | | | |
| Receiving Pervious Area (RPA, %) | 15.4% | 11.1% | 15.6% | 14.5% | 22.1% | 14.8% | 15.3% | | | | | | | | |
| Separate Pervious Area (SPA, %) | 76.6% | 68.3% | 73.7% | 74.4% | 60.2% | 70.4% | 55.8% | | | | | | | | |
| A _p (RPA / UIA) | 4.333 | 2.333 | 3.382 | 2.886 | 2.353 | 2.391 | 1.389 | | | | | | | | |
| I _p Check | 0.190 | 0.300 | 0.230 | 0.260 | 0.300 | 0.290 | 0.420 | | | | | | | | |
| f / i for WQCV Event: | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | 4.6 | | | | | | | | |
| f / i for 5-Year Event: | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | | | | | | | | |
| f / i for 100-Year Event: | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 | | | | | | | | |
| f / i for Optional User Defined Storm CUHP: | 0.39 | 0.39 | 0.39 | 0.39 | 0.39 | 0.39 | 0.39 | | | | | | | | |
| IRF for WQCV Event: | 0.41 | 0.49 | 0.45 | 0.47 | 0.49 | 0.49 | 0.56 | | | | | | | | |
| IRF for 5-Year Event: | 0.80 | 0.86 | 0.84 | 0.85 | 0.86 | 0.85 | 0.88 | | | | | | | | |
| IRF for 100-Year Event: | 0.82 | 0.88 | 0.87 | 0.88 | 0.88 | 0.88 | 0.90 | | | | | | | | |
| IRF for Optional User Defined Storm CUHP: | 0.82 | 0.88 | 0.87 | 0.88 | 0.88 | 0.88 | 0.90 | | | | | | | | |
| Total Site Imperviousness: I _{total} | 8.0% | 20.6% | 10.7% | 11.1% | 17.7% | 14.8% | 28.8% | | | | | | | | |
| Effective Imperviousness for WQCV Event: | 5.9% | 18.2% | 8.2% | 8.4% | 12.9% | 11.6% | 24.0% | | | | | | | | |
| Effective Imperviousness for 5-Year Event: | 7.3% | 19.9% | 10.0% | 10.3% | 16.3% | 13.9% | 27.5% | | | | | | | | |
| Effective Imperviousness for 100-Year Event: | 7.4% | 20.1% | 10.1% | 10.4% | 16.6% | 14.1% | 27.7% | | | | | | | | |
| Effective Imperviousness for Optional User Defined Storm CUHP: | 7.4% | 20.1% | 10.1% | 10.4% | 16.6% | 14.1% | 27.7% | | | | | | | | |

LID / EFFECTIVE IMPERVIOUSNESS CREDITS

| | | | | | | | | | | | | | | | |
|--|-------|------|-------|-------|-------|-------|-------|-----|-----|-----|-----|-----|-----|-----|-----|
| WQCV Event CREDIT: Reduce Detention By: | 23.8% | 8.6% | 20.6% | 21.0% | 21.7% | 17.7% | 11.3% | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| This line only for 10-Year Event | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 100-Year Event CREDIT**: Reduce Detention By: | 10.5% | 3.0% | 6.8% | 6.9% | 7.0% | 5.7% | 4.0% | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| User Defined CUHP CREDIT: Reduce Detention By: | 4.4% | 1.8% | 3.3% | 3.4% | 4.1% | 3.2% | 2.7% | | | | | | | | |

| | |
|---|-------|
| Total Site Imperviousness: | 12.9% |
| Total Site Effective Imperviousness for WQCV Event: | 10.0% |
| Total Site Effective Imperviousness for 5-Year Event: | 12.1% |
| Total Site Effective Imperviousness for 100-Year Event: | 12.2% |
| Total Site Effective Imperviousness for Optional User Defined Storm CUHP: | 12.2% |

Notes:

* Use Green-Ampt average infiltration rate values from Table 3-3.

** Flood control detention volume credits based on empirical equations from Storage Chapter of USDCM.

*** Method assumes that 1-hour rainfall depth is equivalent to 1-hour intensity for calculation purposed

Design Procedure Form: Extended Detention Basin (EDB)

UD-BMP (Version 3.06, November 2016)

Sheet 1 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 30, 2017
Project: Flying Horse North Filing 1 (Pond 8) (Ultimate Build-out)
Location: Black Forest, CO

1. Basin Storage Volume

- A) Effective Imperviousness of Tributary Area, I_a
- B) Tributary Area's Imperviousness Ratio ($i = I_a / 100$)
- C) Contributing Watershed Area
- D) For Watersheds Outside of the Denver Region, Depth of Average Runoff Producing Storm
- E) Design Concept
(Select EURV when also designing for flood control)
- F) Design Volume (WQCV) Based on 40-hour Drain Time
($V_{DESIGN} = (1.0 * (0.91 * i^3 - 1.19 * i^2 + 0.78 * i) / 12 * \text{Area})$)
- G) For Watersheds Outside of the Denver Region, Water Quality Capture Volume (WQCV) Design Volume
($V_{WQCV \text{ OTHER}} = (d_6 * (V_{DESIGN} / 0.43))$)
- H) User Input of Water Quality Capture Volume (WQCV) Design Volume
(Only if a different WQCV Design Volume is desired)
- I) Predominant Watershed NRCS Soil Group
- J) Excess Urban Runoff Volume (EURV) Design Volume
 For HSG A: $EURV_A = 1.68 * i^{1.28}$
 For HSG B: $EURV_B = 1.36 * i^{1.08}$
 For HSG C/D: $EURV_{C/D} = 1.20 * i^{1.08}$

$I_a = 10.0$ %

$i = 0.100$

Area = 255.000 ac

$d_6 = 0.42$ in

Choose One

- ☐ Water Quality Capture Volume (WQCV)
☒ Excess Urban Runoff Volume (EURV)

$V_{DESIGN} = 1.424$ ac-ft

$V_{DESIGN \text{ OTHER}} = 1.391$ ac-ft

$V_{DESIGN \text{ USER}} =$ ac-ft

Choose One

- ☐ A
☒ B
☐ C / D

EURV = 2.404 ac-ft

2. Basin Shape: Length to Width Ratio

(A basin length to width ratio of at least 2:1 will improve TSS reduction.)

L : W = 2.0 : 1

3. Basin Side Slopes

- A) Basin Maximum Side Slopes
(Horizontal distance per unit vertical, 4:1 or flatter preferred)

Z = 4.00 ft / ft

4. Inlet

- A) Describe means of providing energy dissipation at concentrated inflow locations:

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 2 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 30, 2017
Project: Flying Horse North Filing 1 (Pond 8) (Ultimate Build-out)
Location: Black Forest, CO

5. Forebay

- A) Minimum Forebay Volume
($V_{FMIN} = \underline{3\%}$ of the WQCV)
- B) Actual Forebay Volume
- C) Forebay Depth
($D_F = \underline{30}$ inch maximum)
- D) Forebay Discharge
- i) Undetained 100-year Peak Discharge
- ii) Forebay Discharge Design Flow
($Q_F = 0.02 * Q_{100}$)
- E) Forebay Discharge Design

$$V_{FMIN} = \underline{0.042} \text{ ac-ft}$$

$$V_F = \underline{0.042} \text{ ac-ft}$$

$$D_F = \underline{18.0} \text{ in}$$

$$Q_{100} = \underline{390.00} \text{ cfs}$$

$$Q_F = \underline{7.80} \text{ cfs}$$

Choose One

☐ Berm With Pipe
☒ Wall with Rect. Notch
☐ Wall with V-Notch Weir

$$\text{Calculated } D_P = \underline{\hspace{1cm}} \text{ in}$$

$$\text{Calculated } W_N = \underline{18.9} \text{ in}$$

F) Discharge Pipe Size (minimum 8-inches)

G) Rectangular Notch Width

6. Trickle Channel

- A) Type of Trickle Channel
- F) Slope of Trickle Channel

Choose One

☒ Concrete
☐ Soft Bottom

$$S = \underline{0.0100} \text{ ft / ft}$$

7. Micropool and Outlet Structure

- A) Depth of Micropool (2.5-feet minimum)
- B) Surface Area of Micropool (10 ft² minimum)
- C) Outlet Type

$$D_M = \underline{2.5} \text{ ft}$$

$$A_M = \underline{384} \text{ sq ft}$$

Choose One

☒ Orifice Plate
☐ Other (Describe):

D) Smallest Dimension of Orifice Opening Based on Hydrograph Routing
(Use UD-Detention)

$$D_{\text{orifice}} = \underline{2.61} \text{ inches}$$

E) Total Outlet Area

$$A_{\text{ot}} = \underline{16.08} \text{ square inches}$$

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 3 of 4

Designer: Marc A. Whorton
 Company: Classic Consulting
 Date: November 30, 2017
 Project: Flying Horse North Filing 1 (Pond 8) (Ultimate Build-out)
 Location: Black Forest, CO

8. Initial Surge Volume

- A) Depth of Initial Surge Volume
(Minimum recommended depth is 4 inches)
- B) Minimum Initial Surge Volume
(Minimum volume of 0.3% of the WQCV)
- C) Initial Surge Provided Above Micropool

$D_{IS} =$ 6 in

$V_{IS} =$ 181.8 cu ft

$V_s =$ 192.0 cu ft

9. Trash Rack

- A) Water Quality Screen Open Area: $A_t = A_{ot} * 38.5 * (e^{-0.095D})$
- B) Type of Screen (If specifying an alternative to the materials recommended in the USDCM, indicate "other" and enter the ratio of the total open area to the total screen area for the material specified.)

Other (Y/N): N

- C) Ratio of Total Open Area to Total Area (only for type 'Other')

- D) Total Water Quality Screen Area (based on screen type)

- E) Depth of Design Volume (EURV or WQCV)
(Based on design concept chosen under 1E)

- F) Height of Water Quality Screen (H_{TR})

- G) Width of Water Quality Screen Opening ($W_{opening}$)
(Minimum of 12 inches is recommended)

$A_t =$ 483 square inches

Aluminum Amico-Klemp SR Series with Cross Rods 2" O.C.

User Ratio =

$A_{total} =$ 680 sq. in.

$H =$ 5.25 feet

$H_{TR} =$ 91 inches

$W_{opening} =$ 12.0 inches

Design Procedure Form: Extended Detention Basin (EDB)

Sheet 4 of 4

Designer: Marc A. Whorton
Company: Classic Consulting
Date: November 30, 2017
Project: Flying Horse North Filing 1 (Pond 8) (Ultimate Build-out)
Location: Black Forest, CO

10. Overflow Embankment

A) Describe embankment protection for 100-year and greater overtopping:

Soil Rip-Rap

B) Slope of Overflow Embankment
(Horizontal distance per unit vertical, 4:1 or flatter preferred)

4.00

11. Vegetation

Choose One

☐ Irrigated

☒ Not Irrigated

12. Access

A) Describe Sediment Removal Procedures


Notes:

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)

Basin ID: Pond 1

— 2014/15



Example zone Configuration (Retention Pond)

Selected BMP Type = **EDB**

| | | |
|--|--------|-------------|
| Watershed Area | 21.80 | acres |
| Watershed Length | 1,500 | ft |
| Watershed Slope | 0.010 | ft/ft |
| Watershed Imperviousness | 20.00% | percent |
| Percentage Hydrologic Soil Group A | 0.0% | percent |
| Percentage Hydrologic Soil Group B | 100.0% | percent |
| Percentage Hydrologic Soil Groups C/D | 0.0% | percent |
| Desired WQCV Drain Time | 40.0 | hours |
| Location for 1-hr Rainfall Depths = User Input | | |
| Water Quality Capture Volume (WQCV) | 0.210 | acre-feet |
| Excess Urban Runoff Volume (EURV) | 0.433 | acre-feet |
| 2-yr Runoff Volume ($P_1 = 1.19$ in) | 0.319 | 1.19 inches |
| 5-yr Runoff Volume ($P_1 = 1.5$ in) | 0.469 | 1.50 inches |
| 10-yr Runoff Volume ($P_1 = 1.75$ in) | 0.809 | 1.75 inches |
| 25-yr Runoff Volume ($P_1 = 2.2$ in) | 1.596 | 2.00 inches |
| 50-yr Runoff Volume ($P_1 = 2.25$ in) | 2.099 | 2.25 inches |
| 100-yr Runoff Volume ($P_1 = 2.52$ in) | 2.758 | 2.52 inches |
| 500-yr Runoff Volume ($P_1 = 3.39$ in) | 4.375 | 3.39 inches |
| Approximate 2-yr Detention Volume | 0.297 | acre-feet |
| Approximate 5-yr Detention Volume | 0.440 | acre-feet |
| Approximate 10-yr Detention Volume | 0.711 | acre-feet |
| Approximate 25-yr Detention Volume | 0.880 | acre-feet |
| Approximate 50-yr Detention Volume | 0.930 | acre-feet |
| Approximate 100-yr Detention Volume | 1.143 | acre-feet |

Zone 1 Volume (WQCV) = 0.210 acre feet


| | | |
|---|-------|-----------------|
| Zone 2 Volume (EURV - Zone 1) = | 0.223 | acre-feet |
| Zone 3 Volume (100-year - Zones 1 & 2) = | 0.710 | acre-feet |
| Total Detention Basin Volume = | 1.143 | acre-feet |
| Initial Surcharge Volume (ISV) = | user | ft ³ |
| Initial Surcharge Depth (ISD) = | user | ft |
| Total Available Detention Depth (H_{avail}) = | user | ft |
| Depth of Trickle Channel (H_{TC}) = | user | ft |
| Slope of Trickle Channel (S_{TC}) = | user | ft/ft |
| Slopes of Main Basin Sides (S_{mbw}) = | user | H:V |
| Basin Length-to-Width Ratio (R_{mbw}) = | user | |
| Initial Surcharge Area (A_{ISV}) = | user | ft ² |
| Surcharge Volume Length (L_{ISV}) = | user | ft |
| Surcharge Volume Width (W_{ISV}) = | user | ft |
| Depth of Basin Floor ($H_{b,floor}$) = | user | ft |
| Length of Basin Floor ($L_{b,floor}$) = | user | ft |
| Width of Basin Floor ($W_{b,floor}$) = | user | ft |
| Area of Basin Floor ($A_{b,floor}$) = | user | ft ² |
| Volume of Basin Floor ($V_{b,floor}$) = | user | ft ³ |
| Depth of Main Basin (H_{mbw}) = | user | ft |
| Length of Main Basin (L_{mbw}) = | user | ft |
| Width of Main Basin (W_{mbw}) = | user | ft |
| Area of Main Basin (A_{mbw}) = | user | ft ² |
| Volume of Main Basin (V_{mbw}) = | user | ft ³ |
| Calculated Total Basin Volume (V_{total}) = | user | acre-feet |

| | | | | | | | | | |
|--|--|----------|--|--|--|----------|--|--|--|
| | | Optional | | | | Optional | | | |
|--|--|----------|--|--|--|----------|--|--|--|

[illegible]

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)




Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Project: Flying Horse North Filing No. 1

Basin ID: Pond 1



Example Zone Configuration (Retention Pond)

| | Stage (ft) | Zone Volume (ac-ft) | Outlet Type |
|-------------------|------------|---------------------|----------------------|
| Zone 1 (WQCV) | 1.85 | 0.210 | Orifice Plate |
| Zone 2 (EURV) | 2.74 | 0.223 | Orifice Plate |
| Zone 3 (100-year) | 5.04 | 0.710 | Weir&Pipe (Restrict) |
| | | 1.143 | Total |

0

User Input: Orifice at Underdrain Outlet (typically used to drain WQCV in a Filtration BMP)

Underdrain Orifice Invert Depth = ft (distance below the filtration media surface)
Underdrain Orifice Diameter = inches

Calculated Parameters for Underdrain

Underdrain Orifice Area = ft²
Underdrain Orifice Centroid = feet

User Input: Orifice Plate with one or more orifices or Elliptical Slot Weir (typically used to drain WQCV and/or EURV in a sedimentation BMP)

Calculated Parameters for Plate

Invert of Lowest Orifice = ft (relative to basin bottom at Stage = 0 ft)
Depth at top of Zone using Orifice Plate = ft (relative to basin bottom at Stage = 0 ft)
Orifice Plate: Orifice Vertical Spacing = inches
Orifice Plate: Orifice Area per Row = inches

WQ Orifice Area per Row = ft²
Elliptical Half-Width = feet
Elliptical Slot Centroid = feet
Elliptical Slot Area = ft²

User Input: Stage and Total Area of Each Orifice Row (numbered from lowest to highest)

| | Row 1 (required) | Row 2 (optional) | Row 3 (optional) | Row 4 (optional) | Row 5 (optional) | Row 6 (optional) | Row 7 (optional) | Row 8 (optional) |
|--------------------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Stage of Orifice Centroid (ft) | 0.00 | 0.90 | 1.80 | 2.70 | | | | |
| Orifice Area (sq. inches) | 1.30 | 1.43 | 1.43 | 1.43 | | | | |

| | Row 9 (optional) | Row 10 (optional) | Row 11 (optional) | Row 12 (optional) | Row 13 (optional) | Row 14 (optional) | Row 15 (optional) | Row 16 (optional) |
|--------------------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Stage of Orifice Centroid (ft) | | | | | | | | |
| Orifice Area (sq. inches) | | | | | | | | |

User Input: Vertical Orifice (Circular or Rectangular)

Calculated Parameters for Vertical Orifice

| | Not Selected | Not Selected | | Not Selected | Not Selected |
|---|--------------|--------------|---|-----------------------------|--------------|
| Invert of Vertical Orifice = | N/A | N/A | ft (relative to basin bottom at Stage = 0 ft) | Vertical Orifice Area = | N/A |
| Depth at top of Zone using Vertical Orifice = | N/A | N/A | ft (relative to basin bottom at Stage = 0 ft) | Vertical Orifice Centroid = | N/A |
| Vertical Orifice Diameter = | N/A | N/A | inches | | |

User Input: Overflow Weir (Dropbox) and Grate (Flat or Sloped)

Calculated Parameters for Overflow Weir

| | Zone 3 Weir | Not Selected | | Zone 3 Weir | Not Selected |
|---|-------------|--------------|---|--|--------------|
| Overflow Weir Front Edge Height, H _o = | 2.75 | N/A | ft (relative to basin bottom at Stage = 0 ft) | Height of Grate Upper Edge, H ₁ = | 4.08 |
| Overflow Weir Front Edge Length = | 4.00 | N/A | feet | Over Flow Weir Slope Length = | 4.22 |
| Overflow Weir Slope = | 3.00 | N/A | H:V (enter zero for flat grate) | Grate Open Area / 100-yr Orifice Area = | 6.12 |
| Horiz. Length of Weir Sides = | 4.00 | N/A | feet | Overflow Grate Open Area w/o Debris = | 12.65 |
| Overflow Grate Open Area % = | 75% | N/A | % , grate open area/total area | Overflow Grate Open Area w/ Debris = | 6.32 |
| Debris Clogging % = | 50% | N/A | % | | |

User Input: Outlet Pipe w/ Flow Restriction Plate (Circular Orifice, Restrictor Plate, or Rectangular Orifice)

Calculated Parameters for Outlet Pipe w/ Flow Restriction Plate

| | Zone 3 Restrictor | Not Selected | | Zone 3 Restrictor | Not Selected |
|---|-------------------|--------------|--|--|--------------|
| Depth to Invert of Outlet Pipe = | 0.33 | N/A | ft (distance below basin bottom at Stage = 0 ft) | Outlet Orifice Area = | 2.07 |
| Outlet Pipe Diameter = | 24.00 | N/A | inches | Outlet Orifice Centroid = | 0.71 |
| Restrictor Plate Height Above Pipe Invert = | 15.00 | | inches | Half-Central Angle of Restrictor Plate on Pipe = | 1.82 |

User Input: Emergency Spillway (Rectangular or Trapezoidal)

Calculated Parameters for Spillway


| | | | | | |
|-------------------------------------|-------|---|----------------------------------|------|-------|
| Spillway Invert Stage = | 5.00 | ft (relative to basin bottom at Stage = 0 ft) | Spillway Design Flow Depth = | 0.69 | feet |
| Spillway Crest Length = | 25.00 | feet | Stage at Top of Freeboard = | 6.69 | feet |
| Spillway End Slopes = | 3.00 | H:V | Basin Area at Top of Freeboard = | 0.39 | acres |
| Freeboard above Max Water Surface = | 1.00 | feet | | | |

Routed Hydrograph Results

| | WQCV | EURV | 2 Year | 5 Year | 10 Year | 25 Year | 50 Year | 100 Year | 500 Year |
|---|-------|-------|--------|------------------|------------------|------------------|----------------|----------------|----------|
| Design Storm Return Period = | | | | | | | | | |
| One-Hour Rainfall Depth (in) = | 0.53 | 1.07 | 1.19 | 1.50 | 1.75 | 2.00 | 2.25 | 2.52 | 3.39 |
| Calculated Runoff Volume (acre-ft) = | 0.210 | 0.433 | 0.319 | 0.469 | 0.809 | 1.596 | 2.099 | 2.758 | 4.375 |
| OPTIONAL Override Runoff Volume (acre-ft) = | | | | | | | | | |
| Inflow Hydrograph Volume (acre-ft) = | 0.210 | 0.432 | 0.319 | 0.469 | 0.809 | 1.596 | 2.099 | 2.757 | 4.375 |
| Predevelopment Unit Peak Flow, q (cfs/acre) = | 0.00 | 0.00 | 0.01 | 0.02 | 0.16 | 0.55 | 0.77 | 1.04 | 1.66 |
| Predevelopment Peak Q (cfs) = | 0.0 | 0.0 | 0.2 | 0.4 | 3.5 | 12.0 | 16.7 | 22.6 | 36.2 |
| Peak Inflow Q (cfs) = | 3.0 | 6.1 | 4.5 | 6.6 | 11.4 | 22.3 | 29.2 | 38.2 | 60.2 |
| Peak Outflow Q (cfs) = | 0.1 | 0.2 | 0.1 | 0.2 | 3.8 | 13.7 | 19.3 | 21.2 | 50.1 |
| Ratio Peak Outflow to Predevelopment Q = | N/A | N/A | N/A | 0.5 | 1.1 | 1.1 | 1.2 | 0.9 | 1.4 |
| Structure Controlling Flow = | Plate | Plate | Plate | Overflow Grate 1 | Overflow Grate 1 | Overflow Grate 1 | Outlet Plate 1 | Outlet Plate 1 | Spillway |
| Max Velocity through Grate 1 (fps) = | N/A | N/A | N/A | 0.0 | 0.3 | 1.1 | 1.5 | 1.6 | 1.7 |
| Max Velocity through Grate 2 (fps) = | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Time to Drain 97% of Inflow Volume (hours) = | 41 | 55 | 49 | 57 | 55 | 47 | 44 | 40 | 33 |
| Time to Drain 99% of Inflow Volume (hours) = | 43 | 59 | 52 | 61 | 61 | 58 | 56 | 54 | 49 |
| Maximum Ponding Depth (ft) = | 1.77 | 2.62 | 2.20 | 2.75 | 3.28 | 3.84 | 4.13 | 4.91 | 5.50 |
| Area at Maximum Ponding Depth (acres) = | 0.21 | 0.26 | 0.25 | 0.27 | 0.29 | 0.30 | 0.32 | 0.35 | 0.37 |
| Maximum Volume Stored (acre-ft) = | 0.192 | 0.401 | 0.293 | 0.438 | 0.582 | 0.747 | 0.837 | 1.095 | 1.305 |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)



| S-A-V-D Chart Axis Override | X-axis | Left Y-Axis | Right Y-Axis |
|-----------------------------|--------|-------------|--------------|
| minimum bound | | | |
| maximum bound | | | |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Summary Stage-Area-Volume-Discharge Relationships

The user can create a summary S-A-V-D by entering the desired stage increments and the remainder of the table will populate automatically.

The user should graphically compare the summary S-A-V-D table to the full S-A-V-D table in the chart to confirm it captures all key transition points.


[illegible]

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)

Basin ID: POND 4

ZONE 1
ZONE 2



Example Zone Configuration (Retention Pond)

Selected BMP Type = **EDB**

| | | |
|--|--------|-----------|
| Watershed Area = | 134.10 | acres |
| Watershed Length = | 3,900 | ft |
| Watershed Slope = | 0.021 | ft/ft |
| Watershed Siltiness = | 8.00% | percent |
| Percentage Hydrologic Soil Group A = | 0.0% | percent |
| Percentage Hydrologic Soil Group B = | 100.0% | percent |
| Percentage Hydrologic Soil Groups C/D = | 0.0% | percent |
| Desired WQCV Drain Time = | 40.0 | hours |
| Location for 1-hr Rainfall Depths = User Input | | |
| Water Quality Capture Volume (WQCV) = | 0.617 | acre-feet |
| Excess Urban Runoff Volume (EURV) = | 0.990 | acre-feet |
| 2-yr Runoff Volume (P1 = 1.19 in.) = | 0.666 | acre-feet |
| 5-yr Runoff Volume (P1 = 1.5 in.) = | 1.055 | acre-feet |
| 10-yr Runoff Volume (P1 = 2.04 in.) = | 2.694 | acre-feet |
| 25-yr Runoff Volume (P1 = 2.4 in.) = | 7.789 | acre-feet |
| 50-yr Runoff Volume (P1 = 2.25 in.) = | 10.959 | acre-feet |
| 100-yr Runoff Volume (P1 = 2.5 in.) = | 15.099 | acre-feet |
| 500-yr Runoff Volume (P1 = 3.85 in.) = | 28.334 | acre-feet |
| Approximate 2-yr Detention Volume = | 0.618 | acre-feet |
| Approximate 5-yr Detention Volume = | 0.988 | acre-feet |
| Approximate 10-yr Detention Volume = | 2.274 | acre-feet |
| Approximate 25-yr Detention Volume = | 3.285 | acre-feet |
| Approximate 50-yr Detention Volume = | 3.412 | acre-feet |
| Approximate 100-yr Detention Volume = | 4.464 | acre-feet |

Optional User Override
1-hr Precipitation

| | |
|------|--------|
| 1.19 | inches |
| 1.50 | inches |
| 1.75 | inches |
| 2.00 | inches |
| 2.25 | inches |
| 2.52 | inches |
| 3.85 | inches |

Zone 1 Volume (WQCV) = 0.617 acre feet


| | | |
|---|-------|-----------|
| Zone 2 Volume ($V_{EUV} - \text{Zone 1}$) | 0.373 | acre-feet |
| Zone 3 Volume (100-year - Zones 1 & 2) | 3.474 | acre-feet |
| Total Detention Basin Volume | 4.464 | acre-feet |
| Initial Surge Depth (ISD) | user | ft |
| Initial Surge Depth (ISD) | user | ft |
| Total Available Detention Depth (H_{det}) | user | ft |
| Depth of Trickle Channel (H_{TC}) | user | ft |
| Depth of Trickle Channel (S_{TC}) | user | ft/ft |
| Slopes of Main Basin Sides (S_{mb}) | user | H:V |
| Basin Length-to-Width Ratio (R_{LW}) | user | |
| Initial Surge Area (A_{ISD}) | user | sq-ft |
| Surcharge Volume Length (L_{SV}) | user | ft |
| Surcharge Volume Width (W_{SV}) | user | ft |
| Depth of Basin Floor (H_{1100}) | user | ft |
| Length of Basin Floor (V_{1100}) | user | ft |
| Width of Basin Floor (W_{1100}) | user | ft |
| Area of Basin Floor (A_{1100}) | user | sq-ft |
| Volume of Basin Floor (V_{1100}) | user | cu-ft |
| Depth of Main Basin (H_{mb}) | user | ft |
| Length of Main Basin (L_{mb}) | user | ft |
| Volume of Main Basin (V_{mb}) | user | cu-ft |
| Width of Main Basin (W_{mb}) | user | ft |
| Area of Main Basin (A_{mb}) | user | sq-ft |
| Volume of Main Basin (V_{mb}) | user | cu-ft |
| Calculated Total Basin Volume (V_{mb}) | user | acre-feet |

| Step | Step | Step | Optional Override | Length | Width | Area | Optional Override | Area | Volume | Volume |
|------|------|------|----------------------|--------|-------|------|----------------------|------|--------|--------|
|------|------|------|----------------------|--------|-------|------|----------------------|------|--------|--------|

[illegible]

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)




Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Project: FLYING HORSE NORTH FILING 1

Basin ID: POND 4



Example Zone Configuration (Retention Pond)

| | Stage (ft) | Zone Volume (ac-ft) | Outlet Type |
|-------------------|------------|---------------------|----------------------|
| Zone 1 (WQCV) | 3.39 | 0.617 | Orifice Plate |
| Zone 2 (EURV) | 3.94 | 0.373 | Orifice Plate |
| Zone 3 (100-year) | 7.12 | 3.474 | Weir&Pipe (Restrict) |
| | | 4.464 | Total |

User Input: Orifice at Underdrain Outlet (typically used to drain WQCV in a Filtration BMP)

Underdrain Orifice Invert Depth = ft (distance below the filtration media surface)
Underdrain Orifice Diameter = inches

Calculated Parameters for Underdrain

Underdrain Orifice Area = ft²
Underdrain Orifice Centroid = feet

User Input: Orifice Plate with one or more orifices or Elliptical Slot Weir (typically used to drain WQCV and/or EURV in a sedimentation BMP)

Invert of Lowest Orifice = ft (relative to basin bottom at Stage = 0 ft)
Depth at top of Zone using Orifice Plate = ft (relative to basin bottom at Stage = 0 ft)
Orifice Plate: Orifice Vertical Spacing = inches
Orifice Plate: Orifice Area per Row = inches

Calculated Parameters for Plate

WQ Orifice Area per Row = ft²
Elliptical Half-Width = feet
Elliptical Slot Centroid = feet
Elliptical Slot Area = ft²

User Input: Stage and Total Area of Each Orifice Row (numbered from lowest to highest)

| | Row 1 (required) | Row 2 (optional) | Row 3 (optional) | Row 4 (optional) | Row 5 (optional) | Row 6 (optional) | Row 7 (optional) | Row 8 (optional) |
|--------------------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Stage of Orifice Centroid (ft) | 0.00 | 1.30 | 2.60 | 3.90 | | | | |
| Orifice Area (sq. inches) | 2.00 | 2.19 | 2.19 | 2.19 | | | | |

| | Row 9 (optional) | Row 10 (optional) | Row 11 (optional) | Row 12 (optional) | Row 13 (optional) | Row 14 (optional) | Row 15 (optional) | Row 16 (optional) |
|--------------------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Stage of Orifice Centroid (ft) | | | | | | | | |
| Orifice Area (sq. inches) | | | | | | | | |

User Input: Vertical Orifice (Circular or Rectangular)

Invert of Vertical Orifice = ft (relative to basin bottom at Stage = 0 ft)
Depth at top of Zone using Vertical Orifice = ft (relative to basin bottom at Stage = 0 ft)
Vertical Orifice Diameter = inches

Calculated Parameters for Vertical Orifice

Vertical Orifice Area = ft²
Vertical Orifice Centroid = feet

User Input: Overflow Weir (Dropbox) and Grate (Flat or Sloped)

Overflow Weir Front Edge Height, H_o = ft (relative to basin bottom at Stage = 0 ft)
Overflow Weir Front Edge Length = feet
Overflow Weir Slope = H:V (enter zero for flat grate)
Horiz. Length of Weir Sides = feet
Overflow Grate Open Area % = %, grate open area/total area
Debris Clogging % = %

Calculated Parameters for Overflow Weir

Height of Grate Upper Edge, H₁ = feet
Over Flow Weir Slope Length = feet
Grate Open Area / 100-yr Orifice Area = should be ≥ 4
Overflow Grate Open Area w/o Debris = ft²
Overflow Grate Open Area w/ Debris = ft²

User Input: Outlet Pipe w/ Flow Restriction Plate (Circular Orifice, Restrictor Plate, or Rectangular Orifice)

Depth to Invert of Outlet Pipe = ft (distance below basin bottom at Stage = 0 ft)
Outlet Pipe Diameter = inches
Restrictor Plate Height Above Pipe Invert = inches

Calculated Parameters for Outlet Pipe w/ Flow Restriction Plate

Outlet Orifice Area = ft²
Outlet Orifice Centroid = feet
Half-Central Angle of Restrictor Plate on Pipe = radians

User Input: Emergency Spillway (Rectangular or Trapezoidal)

Spillway Invert Stage = ft (relative to basin bottom at Stage = 0 ft)
Spillway Crest Length = feet
Spillway End Slopes = H:V
Freeboard above Max Water Surface = feet

Calculated Parameters for Spillway


Spillway Design Flow Depth = feet
Stage at Top of Freeboard = feet
Basin Area at Top of Freeboard = acres

Routed Hydrograph Results

| | WQCV | EURV | 2 Year | 5 Year | 10 Year | 25 Year | 50 Year | 100 Year | 500 Year |
|---|-------|-------|--------|--------|------------------|------------------|------------------|------------------|----------|
| Design Storm Return Period = | | | | | | | | | |
| One-Hour Rainfall Depth (in) = | 0.53 | 1.07 | 1.19 | 1.50 | 1.75 | 2.00 | 2.25 | 2.52 | 3.85 |
| Calculated Runoff Volume (acre-ft) = | 0.617 | 0.990 | 0.666 | 1.055 | 2.694 | 7.789 | 10.959 | 15.099 | 28.334 |
| OPTIONAL Override Runoff Volume (acre-ft) = | | | | | | | | | |
| Inflow Hydrograph Volume (acre-ft) = | 0.617 | 0.989 | 0.665 | 1.054 | 2.692 | 7.773 | 10.944 | 15.081 | 28.305 |
| Predevelopment Unit Peak Flow, q (cfs/acre) = | 0.00 | 0.00 | 0.01 | 0.02 | 0.18 | 0.60 | 0.84 | 1.13 | 2.05 |
| Predevelopment Peak Q (cfs) = | 0.0 | 0.0 | 1.5 | 2.5 | 24.1 | 81.1 | 112.3 | 151.7 | 275.3 |
| Peak Inflow Q (cfs) = | 9.5 | 15.1 | 10.2 | 16.1 | 40.7 | 114.9 | 160.1 | 217.9 | 396.7 |
| Peak Outflow Q (cfs) = | 0.3 | 0.3 | 0.3 | 0.4 | 15.5 | 74.5 | 106.2 | 142.2 | 334.4 |
| Ratio Peak Outflow to Predevelopment Q = | N/A | N/A | N/A | 0.1 | 0.6 | 0.9 | 0.9 | 0.9 | 1.2 |
| Structure Controlling Flow = | Plate | Plate | Plate | Plate | Overflow Grate 1 | Overflow Grate 1 | Overflow Grate 1 | Overflow Grate 1 | Spillway |
| Max Velocity through Grate 1 (fps) = | N/A | N/A | N/A | N/A | 0.5 | 2.4 | 3.4 | 4.6 | 5.6 |
| Max Velocity through Grate 2 (fps) = | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Time to Drain 97% of Inflow Volume (hours) = | 40 | 52 | 42 | 54 | 52 | 41 | 35 | 29 | 13 |
| Time to Drain 99% of Inflow Volume (hours) = | 42 | 56 | 44 | 58 | 59 | 53 | 50 | 47 | 38 |
| Maximum Ponding Depth (ft) = | 3.30 | 3.86 | 3.39 | 3.95 | 4.77 | 5.97 | 6.64 | 7.57 | 9.11 |
| Area at Maximum Ponding Depth (acres) = | 0.54 | 0.75 | 0.57 | 0.78 | 1.01 | 1.16 | 1.24 | 1.34 | 1.50 |
| Maximum Volume Stored (acre-ft) = | 0.569 | 0.930 | 0.614 | 0.991 | 1.752 | 3.046 | 3.850 | 5.061 | 7.242 |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)



| S-A-V-D Chart Axis Override | X-axis | Left Y-Axis | Right Y-Axis |
|-----------------------------|--------|-------------|--------------|
| minimum bound | | | |
| maximum bound | | | |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Summary Stage-Area-Volume-Discharge Relationships

The user can create a summary S-A-V-D by entering the desired stage increments and the remainder of the table will populate automatically.

The user should graphically compare the summary S-A-V-D table to the full S-A-V-D table in the chart to confirm it captures all key transition points.


[illegible]

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)

Basin ID: POND 8 (FULL BUILD-OUT)

— 30 sec —



Example Zone Configuration (Retention Pond)

Selected BMP Type = **EDB**

| | | | |
|--|--------|-----------|--|
| Watershed Area | 255.00 | acres | |
| Watershed Length | 5.900 | feet | |
| Watershed Slope | 0.017 | ft/ft | |
| Watershed Imperviousness | 10.00% | percent | |
| Percentage Hydrologic Soil Group A | 0.0% | percent | |
| Percentage Hydrologic Soil Group B | 100.0% | percent | |
| Percentage Hydrologic Soil Groups C/D | 0.0% | percent | |
| Desired WQCV Drain Time | 40.0 | hours | |
| Location for 1-hr Rainfall Depths = User Input | | | |
| Water Quality Capture Volume (WQCV) | 1,424 | acre-feet | Optional User Override 1.19 Precipitation |
| Excess Urban Runoff Volume (EURV) | 2,397 | acre-feet | |
| 2-yr Runoff Volume ($P1 = 1.19$) | 1,648 | acre-feet | 1.19 inches |
| 5-yr Runoff Volume ($P1 = 1.5$) | 2,564 | acre-feet | 1.50 inches |
| 10-yr Runoff Volume ($P1 = 1.75$) | 5,846 | acre-feet | 1.75 inches |
| 25-yr Runoff Volume ($P1 = 2.0$) | 15,453 | acre-feet | 2.00 inches |
| 50-yr Runoff Volume ($P1 = 2.25$) | 21,458 | acre-feet | 2.25 inches |
| 100-yr Runoff Volume ($P1 = 2.5$) | 29,303 | acre-feet | 2.52 inches |
| 500-yr Runoff Volume ($P1 = 3.85$) | 54,585 | acre-feet | 3.85 inches |
| Approximate 2-yr Detention Volume | 1,530 | acre-feet | |
| Approximate 5-yr Detention Volume | 2,400 | acre-feet | |
| Approximate 10-yr Detention Volume | 4,982 | acre-feet | |
| Approximate 25-yr Detention Volume | 6,957 | acre-feet | |
| Approximate 50-yr Detention Volume | 7,278 | acre-feet | |
| Approximate 100-yr Detention Volume | 9,408 | acre-feet | |


Zone 1 Volume (MOCV) = 1.434

| | | |
|---|-------|-----------------|
| Zone 2 Volume (EURV - Zone 1) | 0.973 | acre-feet |
| Zone 3 Volume (100-year - Zones 1 & 2) | 7.011 | acre-feet |
| Total Detention Basin Volume | 9.408 | acre-feet |
| Initial Surcharge Volume (ISV) | user | ft ³ |
| Initial Surcharge Depth (ISD) | user | ft |
| Total Available Detention Depth (H_{TAD}) | user | ft |
| Depth of Trickle Channel (H_{TC}) | user | ft |
| Slope of Trickle Channel (S_{TC}) | user | ft/ft |
| Slopes of Main Basin Sides (S_{mb}) | user | H:V |
| Basin Length-to-Width Ratio (R_{LW}) | user | |
| Initial Surcharge Area (A_{IS}) | user | ft ² |
| Surcharge Volume Length (L_{SV}) | user | ft |
| Surcharge Volume Width (W_{SV}) | user | ft |
| Depth of Basin Floor (H_{BF}) | user | ft |
| Length of Basin Floor (L_{BF}) | user | ft |
| Width of Basin Floor (W_{BF}) | user | ft |
| Area of Basin Floor (A_{BF}) | user | ft ² |
| Volume of Basin Floor (V_{BF}) | user | ft ³ |
| Depth of Main Basin (H_{MB}) | user | ft |
| Length of Main Basin (L_{MB}) | user | ft |
| Width of Main Basin (W_{MB}) | user | ft |
| Area of Main Basin (A_{MB}) | user | ft ² |
| Volume of Main Basin (V_{MB}) | user | ft ³ |
| Calculated Total Basin Volume (V_{TAD}) | user | acre-feet |

[illegible]

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)




Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Project: FLYING HORSE NORTH FILING 1

Basin ID: POND 8 (FULL BUILD-OUT)



Example Zone Configuration (Retention Pond)

| | Stage (ft) | Zone Volume (ac-ft) | Outlet Type |
|-------------------|------------|---------------------|----------------------|
| Zone 1 (WQCV) | 4.12 | 1.424 | Orifice Plate |
| Zone 2 (EURV) | 5.14 | 0.973 | Orifice Plate |
| Zone 3 (100-year) | 9.90 | 7.011 | Weir&Pipe (Restrict) |
| | | 9.408 | Total |

User Input: Orifice at Underdrain Outlet (typically used to drain WQCV in a Filtration BMP)

Underdrain Orifice Invert Depth = ft (distance below the filtration media surface)
Underdrain Orifice Diameter = inches

Calculated Parameters for Underdrain

Underdrain Orifice Area = ft²
Underdrain Orifice Centroid = feet

User Input: Orifice Plate with one or more orifices or Elliptical Slot Weir (typically used to drain WQCV and/or EURV in a sedimentation BMP)

Invert of Lowest Orifice = ft (relative to basin bottom at Stage = 0 ft)
Depth at top of Zone using Orifice Plate = ft (relative to basin bottom at Stage = 0 ft)
Orifice Plate: Orifice Vertical Spacing = inches
Orifice Plate: Orifice Area per Row = inches

Calculated Parameters for Plate

WQ Orifice Area per Row = ft²
Elliptical Half-Width = feet
Elliptical Slot Centroid = feet
Elliptical Slot Area = ft²

User Input: Stage and Total Area of Each Orifice Row (numbered from lowest to highest)

| | Row 1 (required) | Row 2 (optional) | Row 3 (optional) | Row 4 (optional) | Row 5 (optional) | Row 6 (optional) | Row 7 (optional) | Row 8 (optional) |
|--------------------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Stage of Orifice Centroid (ft) | 0.00 | 1.80 | 3.60 | | | | | |
| Orifice Area (sq. inches) | 5.35 | 5.35 | 5.35 | | | | | |

| | Row 9 (optional) | Row 10 (optional) | Row 11 (optional) | Row 12 (optional) | Row 13 (optional) | Row 14 (optional) | Row 15 (optional) | Row 16 (optional) |
|--------------------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Stage of Orifice Centroid (ft) | | | | | | | | |
| Orifice Area (sq. inches) | | | | | | | | |

User Input: Vertical Orifice (Circular or Rectangular)

Invert of Vertical Orifice = ft (relative to basin bottom at Stage = 0 ft)
Depth at top of Zone using Vertical Orifice = ft (relative to basin bottom at Stage = 0 ft)
Vertical Orifice Diameter = inches

Calculated Parameters for Vertical Orifice

Vertical Orifice Area = ft²
Vertical Orifice Centroid = feet

User Input: Overflow Weir (Dropbox) and Grate (Flat or Sloped)

Overflow Weir Front Edge Height, H_o = ft (relative to basin bottom at Stage = 0 ft)
Overflow Weir Front Edge Length = feet
Overflow Weir Slope = H:V (enter zero for flat grate)
Horiz. Length of Weir Sides = feet
Overflow Grate Open Area % = %
Debris Clogging % = %

Calculated Parameters for Overflow Weir

Height of Grate Upper Edge, H₁ = feet
Over Flow Weir Slope Length = feet
Grate Open Area / 100-yr Orifice Area = should be ≥ 4
Overflow Grate Open Area w/o Debris = ft²
Overflow Grate Open Area w/ Debris = ft²

User Input: Outlet Pipe w/ Flow Restriction Plate (Circular Orifice, Restrictor Plate, or Rectangular Orifice)

Depth to Invert of Outlet Pipe = ft (distance below basin bottom at Stage = 0 ft)
Outlet Pipe Diameter = inches
Restrictor Plate Height Above Pipe Invert = inches

Calculated Parameters for Outlet Pipe w/ Flow Restriction Plate

Outlet Orifice Area = ft²
Outlet Orifice Centroid = feet
Half-Central Angle of Restrictor Plate on Pipe = radians

User Input: Emergency Spillway (Rectangular or Trapezoidal)

Spillway Invert Stage = ft (relative to basin bottom at Stage = 0 ft)
Spillway Crest Length = feet
Spillway End Slopes = H:V
Freeboard above Max Water Surface = feet

Calculated Parameters for Spillway


Spillway Design Flow Depth = feet
Stage at Top of Freeboard = feet
Basin Area at Top of Freeboard = acres

Routed Hydrograph Results

| | WQCV | EURV | 2 Year | 5 Year | 10 Year | 25 Year | 50 Year | 100 Year | 500 Year |
|---|-------|-------|--------|--------|------------------|------------------|------------------|----------------|----------|
| Design Storm Return Period = | | | | | | | | | |
| One-Hour Rainfall Depth (in) = | 0.53 | 1.07 | 1.19 | 1.50 | 1.75 | 2.00 | 2.25 | 2.52 | 3.85 |
| Calculated Runoff Volume (acre-ft) = | 1.424 | 2.397 | 1.648 | 2.564 | 5.846 | 15.453 | 21.458 | 29.303 | 54.585 |
| OPTIONAL Override Runoff Volume (acre-ft) = | | | | | | | | | |
| Inflow Hydrograph Volume (acre-ft) = | 1.423 | 2.395 | 1.646 | 2.562 | 5.839 | 15.442 | 21.440 | 29.281 | 54.548 |
| Predevelopment Unit Peak Flow, q (cfs/acre) = | 0.00 | 0.00 | 0.01 | 0.02 | 0.17 | 0.57 | 0.79 | 1.07 | 1.95 |
| Predevelopment Peak Q (cfs) = | 0.0 | 0.0 | 2.6 | 4.5 | 42.9 | 145.9 | 202.2 | 273.7 | 497.4 |
| Peak Inflow Q (cfs) = | 20.6 | 34.5 | 23.8 | 36.9 | 82.8 | 212.4 | 290.8 | 390.0 | 677.9 |
| Peak Outflow Q (cfs) = | 0.7 | 0.9 | 0.8 | 1.0 | 34.7 | 147.2 | 203.6 | 252.9 | 625.6 |
| Ratio Peak Outflow to Predevelopment Q = | N/A | N/A | N/A | 0.2 | 0.8 | 1.0 | 1.0 | 0.9 | 1.3 |
| Structure Controlling Flow = | Plate | Plate | Plate | Plate | Overflow Grate 1 | Overflow Grate 1 | Overflow Grate 1 | Outlet Plate 1 | Spillway |
| Max Velocity through Grate 1 (fps) = | N/A | N/A | N/A | N/A | 0.7 | 2.9 | 4.1 | 5.1 | 5.5 |
| Max Velocity through Grate 2 (fps) = | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Time to Drain 97% of Inflow Volume (hours) = | 38 | 50 | 41 | 52 | 50 | 40 | 36 | 31 | 18 |
| Time to Drain 99% of Inflow Volume (hours) = | 40 | 53 | 43 | 55 | 56 | 51 | 48 | 46 | 39 |
| Maximum Ponding Depth (ft) = | 3.97 | 4.99 | 4.22 | 5.14 | 6.24 | 7.69 | 8.57 | 9.84 | 11.30 |
| Area at Maximum Ponding Depth (acres) = | 0.78 | 1.04 | 0.85 | 1.07 | 1.35 | 1.52 | 1.60 | 1.72 | 1.88 |
| Maximum Volume Stored (acre-ft) = | 1.303 | 2.231 | 1.515 | 2.389 | 3.733 | 5.835 | 7.192 | 9.319 | 11.929 |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)



| S-A-V-D Chart Axis Override | X-axis | Left Y-Axis | Right Y-Axis |
|-----------------------------|--------|-------------|--------------|
| minimum bound | | | |
| maximum bound | | | |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Summary Stage-Area-Volume-Discharge Relationships

The user can create a summary S-A-V-D by entering the desired stage increments and the remainder of the table will populate automatically.

The user should graphically compare the summary S-A-V-D table to the full S-A-V-D table in the chart to confirm it captures all key transition points.


[illegible]

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)

Project: FLYING HORSE NORTH FILING 1

Basin ID: POND 8 (FILING 1 ONLY INCL. GOLF COURSE)



Example Zone Configuration (Retention Pond)

Required Volume Calculation

| | | |
|---|------------|-------------|
| Selected BMP Type = | EDB | |
| Watershed Area = | 255.00 | acres |
| Watershed Length = | 6.000 | ft |
| Watershed Slope = | 0.006 | ft/ft |
| Watershed Imperviousness = | 5.00% | percent |
| Percentage Hydrologic Soil Group A = | 0.0% | percent |
| Percentage Hydrologic Soil Group B = | 100.0% | percent |
| Percentage Hydrologic Soil Groups C/D = | 0.0% | percent |
| Desired WQCV Drain Time = | 40.0 | hours |
| Location for 1-hr Rainfall Depths = | User Input | |
| Water Quality Capture Volume (WQCV) = | 0.768 | acre-feet |
| Excess Urban Runoff Volume (EURV) = | 1.134 | acre-feet |
| 2-yr Runoff Volume (P1 = 1.5 in.) = | 0.797 | 1.19 inches |
| 5-yr Runoff Volume (P1 = 1.75 in.) = | 1.186 | 1.50 inches |
| 10-yr Runoff Volume (P1 = 1.8 in.) = | 4.039 | 1.75 inches |
| 25-yr Runoff Volume (P1 = 2 in.) = | 13.847 | 2.00 inches |
| 50-yr Runoff Volume (P1 = 2.25 in.) = | 19.909 | 2.25 inches |
| 100-yr Runoff Volume (P1 = 2.52 in.) = | 27.825 | 2.52 inches |
| 500-yr Runoff Volume (P1 = 3.85 in.) = | 52.818 | 3.85 inches |
| Approximate 2-yr Detention Volume = | 0.673 | acre-feet |
| Approximate 5-yr Detention Volume = | 1.120 | acre-feet |
| Approximate 10-yr Detention Volume = | 3.339 | acre-feet |
| Approximate 25-yr Detention Volume = | 5.092 | acre-feet |
| Approximate 50-yr Detention Volume = | 5.177 | acre-feet |
| Approximate 100-yr Detention Volume = | 6.915 | acre-feet |


Stage-Storage Calculation

| | | |
|---|-------|-----------------|
| Zone 1 Volume (V_{WCV1}) = | 0.768 | acre-feet |
| Zone 2 Volume ($V_{EUV} - \text{Zone 1}$) = | 0.366 | acre-feet |
| Zone 3 Volume (100-year - Zones 1 & 2) = | 5.782 | acre-feet |
| Total Detention Basin Volume = | 6.915 | acre-feet |
| Initial Surcharge Volume (ISV) = | user | ft ³ |
| Initial Surcharge Depth (ISD) = | user | ft |
| Total Available Detention Depth (H_{avail}) = | user | ft |
| Depth of Trickle Channel (H_{TC}) = | user | ft |
| Slope of Trickle Channel (S_{TC}) = | user | ft/ft |
| Slopes of Main Basin Sides (S_{basin}) = | user | ft-V |
| Basin Length-to-Width Ratio ($R_{L/W}$) = | user | |
| Initial Surcharge Area (A_{ISV}) = | user | ft ² |
| Surcharge Volume Length (L_{ISV}) = | user | ft |
| Surcharge Volume Width (W_{ISV}) = | user | ft |
| Depth of Basin Floor ($H_{b,100yr}$) = | user | ft |
| Length of Basin Floor ($L_{b,100yr}$) = | user | ft |
| Width of Basin Floor ($W_{b,100yr}$) = | user | ft |
| Area of Basin Floor ($A_{b,100yr}$) = | user | ft ² |
| Volume of Basin Floor ($V_{b,100yr}$) = | user | ft ³ |
| Depth of Main Basin (H_{main}) = | user | ft |
| Length of Main Basin (L_{main}) = | user | ft |
| Width of Main Basin (W_{main}) = | user | ft |
| Area of Main Basin (A_{main}) = | user | ft ² |
| Volume of Main Basin (V_{main}) = | user | ft ³ |
| Calculated Total Basin Volume (V_{total}) = | user | acre-feet |

[illegible]

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)




Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Project: FLYING HORSE NORTH FILING 1

Basin ID: POND 8 (FILING 1 ONLY INCL. GOLF COURSE)



Example Zone Configuration (Retention Pond)

| | Stage (ft) | Zone Volume (ac-ft) | Outlet Type |
|-------------------|------------|---------------------|----------------------|
| Zone 1 (WQCV) | 3.18 | 0.768 | Orifice Plate |
| Zone 2 (EURV) | 3.74 | 0.366 | Orifice Plate |
| Zone 3 (100-year) | 8.39 | 5.782 | Weir&Pipe (Restrict) |
| | | 6.915 | Total |

User Input: Orifice at Underdrain Outlet (typically used to drain WQCV in a Filtration BMP)

Underdrain Orifice Invert Depth = ft (distance below the filtration media surface)
Underdrain Orifice Diameter = inches

Calculated Parameters for Underdrain

Underdrain Orifice Area = ft²
Underdrain Orifice Centroid = feet

User Input: Orifice Plate with one or more orifices or Elliptical Slot Weir (typically used to drain WQCV and/or EURV in a sedimentation BMP)

Invert of Lowest Orifice = ft (relative to basin bottom at Stage = 0 ft)
Depth at top of Zone using Orifice Plate = ft (relative to basin bottom at Stage = 0 ft)
Orifice Plate: Orifice Vertical Spacing = inches
Orifice Plate: Orifice Area per Row = inches

Calculated Parameters for Plate

WQ Orifice Area per Row = ft²
Elliptical Half-Width = feet
Elliptical Slot Centroid = feet
Elliptical Slot Area = ft²

User Input: Stage and Total Area of Each Orifice Row (numbered from lowest to highest)

| | Row 1 (required) | Row 2 (optional) | Row 3 (optional) | Row 4 (optional) | Row 5 (optional) | Row 6 (optional) | Row 7 (optional) | Row 8 (optional) |
|--------------------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Stage of Orifice Centroid (ft) | 0.00 | 1.80 | 3.60 | | | | | |
| Orifice Area (sq. inches) | 3.75 | 3.75 | 3.75 | | | | | |

| | Row 9 (optional) | Row 10 (optional) | Row 11 (optional) | Row 12 (optional) | Row 13 (optional) | Row 14 (optional) | Row 15 (optional) | Row 16 (optional) |
|--------------------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Stage of Orifice Centroid (ft) | | | | | | | | |
| Orifice Area (sq. inches) | | | | | | | | |

User Input: Vertical Orifice (Circular or Rectangular)

| | Not Selected | Not Selected | |
|---|--------------|--------------|---|
| Invert of Vertical Orifice = | N/A | N/A | ft (relative to basin bottom at Stage = 0 ft) |
| Depth at top of Zone using Vertical Orifice = | N/A | N/A | ft (relative to basin bottom at Stage = 0 ft) |
| Vertical Orifice Diameter = | N/A | N/A | inches |

Calculated Parameters for Vertical Orifice

| | Not Selected | Not Selected | |
|-----------------------------|--------------|--------------|-----------------|
| Vertical Orifice Area = | N/A | N/A | ft ² |
| Vertical Orifice Centroid = | N/A | N/A | feet |

User Input: Overflow Weir (Dropbox) and Grate (Flat or Sloped)

| | Zone 3 Weir | Not Selected | |
|---|-------------|--------------|---|
| Overflow Weir Front Edge Height, H _o = | 5.25 | N/A | ft (relative to basin bottom at Stage = 0 ft) |
| Overflow Weir Front Edge Length = | 16.00 | N/A | feet |
| Overflow Weir Slope = | 4.00 | N/A | H:V (enter zero for flat grate) |
| Horiz. Length of Weir Sides = | 4.00 | N/A | feet |
| Overflow Grate Open Area % = | 75% | N/A | %, grate open area/total area |
| Debris Clogging % = | 50% | N/A | % |

Calculated Parameters for Overflow Weir

| | Zone 3 Weir | Not Selected | |
|--|-------------|--------------|-----------------|
| Height of Grate Upper Edge, H ₁ = | 6.25 | N/A | feet |
| Over Flow Weir Slope Length = | 4.12 | N/A | feet |
| Grate Open Area / 100-yr Orifice Area = | 2.94 | N/A | should be ≥ 4 |
| Overflow Grate Open Area w/o Debris = | 49.48 | N/A | ft ² |
| Overflow Grate Open Area w/ Debris = | 24.74 | N/A | ft ² |

User Input: Outlet Pipe w/ Flow Restriction Plate (Circular Orifice, Restrictor Plate, or Rectangular Orifice)

| | Zone 3 Restrictor | Not Selected | |
|---|-------------------|--------------|--|
| Depth to Invert of Outlet Pipe = | 0.50 | N/A | ft (distance below basin bottom at Stage = 0 ft) |
| Outlet Pipe Diameter = | 60.00 | N/A | inches |
| Restrictor Plate Height Above Pipe Invert = | 48.00 | N/A | inches |

Calculated Parameters for Outlet Pipe w/ Flow Restriction Plate

| | Zone 3 Restrictor | Not Selected | |
|--|-------------------|--------------|-----------------|
| Outlet Orifice Area = | 16.84 | N/A | ft ² |
| Outlet Orifice Centroid = | 2.18 | N/A | feet |
| Half-Central Angle of Restrictor Plate on Pipe = | 2.21 | N/A | radians |

User Input: Emergency Spillway (Rectangular or Trapezoidal)

Spillway Invert Stage = ft (relative to basin bottom at Stage = 0 ft)
Spillway Crest Length = feet
Spillway End Slopes = H:V
Freeboard above Max Water Surface = feet

Calculated Parameters for Spillway


Spillway Design Flow Depth = feet
Stage at Top of Freeboard = feet
Basin Area at Top of Freeboard = acres

Routed Hydrograph Results

| | WQCV | EURV | 2 Year | 5 Year | 10 Year | 25 Year | 50 Year | 100 Year | 500 Year |
|---|-------|-------|--------|--------|------------------|------------------|------------------|----------------|----------|
| Design Storm Return Period = | | | | | | | | | |
| One-Hour Rainfall Depth (in) = | 0.53 | 1.07 | 1.19 | 1.50 | 1.75 | 2.00 | 2.25 | 2.52 | 3.85 |
| Calculated Runoff Volume (acre-ft) = | 0.768 | 1.134 | 0.728 | 1.198 | 4.039 | 13.847 | 19.909 | 27.825 | 52.818 |
| OPTIONAL Override Runoff Volume (acre-ft) = | | | | | | | | | |
| Inflow Hydrograph Volume (acre-ft) = | 0.768 | 1.133 | 0.728 | 1.197 | 4.038 | 13.842 | 19.906 | 27.823 | 52.817 |
| Predevelopment Unit Peak Flow, q (cfs/acre) = | 0.00 | 0.00 | 0.01 | 0.02 | 0.14 | 0.49 | 0.68 | 0.93 | 1.69 |
| Predevelopment Peak Q (cfs) = | 0.0 | 0.0 | 2.2 | 3.9 | 35.8 | 125.2 | 173.8 | 236.6 | 431.3 |
| Peak Inflow Q (cfs) = | 9.1 | 13.3 | 8.6 | 14.1 | 46.7 | 154.6 | 218.8 | 300.7 | 533.2 |
| Peak Outflow Q (cfs) = | 0.4 | 0.4 | 0.4 | 0.5 | 12.4 | 109.9 | 164.8 | 218.9 | 492.9 |
| Ratio Peak Outflow to Predevelopment Q = | N/A | N/A | N/A | 0.1 | 0.3 | 0.9 | 0.9 | 0.9 | 1.1 |
| Structure Controlling Flow = | Plate | Plate | Plate | Plate | Overflow Grate 1 | Overflow Grate 1 | Overflow Grate 1 | Outlet Plate 1 | Spillway |
| Max Velocity through Grate 1 (fps) = | N/A | N/A | N/A | N/A | 0.2 | 2.2 | 3.3 | 4.4 | 5.0 |
| Max Velocity through Grate 2 (fps) = | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Time to Drain 97% of Inflow Volume (hours) = | 38 | 48 | 37 | 49 | 74 | 58 | 52 | 44 | 25 |
| Time to Drain 99% of Inflow Volume (hours) = | 40 | 50 | 38 | 52 | 80 | 73 | 69 | 65 | 55 |
| Maximum Ponding Depth (ft) = | 3.05 | 3.61 | 2.98 | 3.70 | 5.77 | 7.28 | 7.98 | 8.97 | 11.03 |
| Area at Maximum Ponding Depth (acres) = | 0.55 | 0.69 | 0.53 | 0.71 | 1.23 | 1.48 | 1.55 | 1.64 | 1.85 |
| Maximum Volume Stored (acre-ft) = | 0.689 | 1.044 | 0.651 | 1.100 | 3.114 | 5.220 | 6.280 | 7.840 | 11.425 |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)



| S-A-V-D Chart Axis Override | X-axis | Left Y-Axis | Right Y-Axis |
|-----------------------------|--------|-------------|--------------|
| minimum bound | | | |
| maximum bound | | | |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Summary Stage-Area-Volume-Discharge Relationships

The user can create a summary S-A-V-D by entering the desired stage increments and the remainder of the table will populate automatically.


The user should graphically compare the summary S-A-V-D table to the full S-A-V-D table in the chart to confirm it captures all key transition points.

[illegible]

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)

Basin ID: Pond 12



Example Zone Configuration (Retention Pond)

Selected BMP Type = **EDB**

| | | |
|--|--------|-----------|
| Watershed Area | 57.60 | acres |
| Watershed Length | 3.000 | ft |
| Watershed Slope | 0.014 | ft/ft |
| Watershed Imperviousness | 12.00% | percent |
| Percentage Hydrologic Soil Group A | 0.0% | percent |
| Percentage Hydrologic Soil Group B | 100.0% | percent |
| Percentage Hydrologic Soil Groups C/D | 0.0% | percent |
| Desired WQCV Drain Time | 40.0 | hours |
| Location for 1-y Rainfall Depth = User Input | | |
| Water Quality Capture Volume (WQCV) | 0.375 | acre-feet |
| Excess Urban Runoff Volume (EURV) | 0.651 | acre-feet |
| 2-y Runoff Volume ($P_1 = 1.19$ in.) | 0.461 | acre-feet |
| 5-y Runoff Volume ($P_1 = 1.5$ in.) | 0.708 | acre-feet |
| 10-y Runoff Volume ($P_1 = 1.75$ in.) | 1.484 | acre-feet |
| 25-y Runoff Volume ($P_1 = 2$ in.) | 3.636 | acre-feet |
| 50-y Runoff Volume ($P_1 = 2.25$ in.) | 4.987 | acre-feet |
| 100-y Runoff Volume ($P_1 = 2.52$ in.) | 6.752 | acre-feet |
| 500-y Runoff Volume ($P_1 = 3.39$ in.) | 10.997 | acre-feet |
| Approximate 2-y Detention Volume | 0.429 | acre-feet |
| Approximate 5-y Detention Volume | 0.663 | acre-feet |
| Approximate 10-y Detention Volume | 1.275 | acre-feet |
| Approximate 25-y Detention Volume | 1.727 | acre-feet |
| Approximate 50-y Detention Volume | 1.814 | acre-feet |
| Approximate 100-y Detention Volume | 2.319 | acre-feet |

| Water Quality Capture Volume (WQCV) | 0.375 | acre-feet | Optional User Override 1-hr Precipitation |
|--------------------------------------|--------|-----------|--|
| Excess Runoff Volume (EURV) | 0.659 | acre-feet | |
| 2-yr Runoff Volume (P1 = 1.19 in.) | 0.461 | acre-feet | 1.19 inches |
| 5-yr Runoff Volume (P1 = 1.51 in.) | 0.708 | acre-feet | 1.50 inches |
| 10-yr Runoff Volume (P1 = 1.75 in.) | 1.484 | acre-feet | 1.75 inches |
| 25-yr Runoff Volume (P1 = 2 in.) | 3.636 | acre-feet | 2.00 inches |
| 50-yr Runoff Volume (P1 = 2.25 in.) | 4.987 | acre-feet | 2.25 inches |
| 100-yr Runoff Volume (P1 = 2.52 in.) | 6.752 | acre-feet | 2.52 inches |
| 500-yr Runoff Volume (P1 = 3.39 in.) | 10.997 | acre-feet | 3.39 inches |

Zone 1 Volume (WQCV) = 0.375 acre feet


| | | |
|---|-------|-----------|
| Zone 2 Volume ($V_{EUV} - \text{Zone 1}$) | 0.285 | acre-feet |
| Zone 3 Volume (100-year - Zones 1 & 2) | 1.660 | acre-feet |
| Total Detention Basin Volume | 2.319 | acre-feet |
| Initial Surge Depth (ISD) | user | ft |
| Initial Surge Depth Depth (H_{ISD}) | user | ft |
| Total Available Detention Depth (H_{DAV}) | user | ft |
| Depth of Trickle Channel (H_{TC}) | user | ft |
| Depth of Trickle Channel (S_{TC}) | user | ft/ft |
| Slopes of Main Basin Sides (S_{MB}) | user | H:V |
| Basin Length-to-Width Ratio (R_{BW}) | user | |
| Initial Surge Area (A_{ISD}) | user | sq-ft |
| Surcharge Volume Length (L_{SV}) | user | ft |
| Surcharge Volume Width (W_{SV}) | user | ft |
| Depth of Basin Floor (H_{1100}) | user | ft |
| Length of Basin Floor (V_{1100}) | user | ft |
| Width of Basin Floor (W_{1100}) | user | ft |
| Area of Basin Floor (A_{1100}) | user | sq-ft |
| Volume of Basin Floor (V_{1100}) | user | cu-ft |
| Depth of Main Basin (H_{MB}) | user | ft |
| Length of Main Basin (L_{MB}) | user | ft |
| Width of Main Basin (W_{MB}) | user | ft |
| Area of Main Basin (A_{MB}) | user | sq-ft |
| Volume of Main Basin (V_{MB}) | user | cu-ft |
| Calculated Total Basin Volume (V_{MB}) | user | acre-feet |

| Stress | Stressors | Stress | Optional Counselor | Length | Width | Area | Optional Counselor | Area | Volume | Volume |
|--------|-----------|--------|-----------------------|--------|-------|------|-----------------------|------|--------|--------|
|--------|-----------|--------|-----------------------|--------|-------|------|-----------------------|------|--------|--------|

[illegible]

DETENTION BASIN STAGE-STORAGE TABLE BUILDER

UD-Detention, Version 3.07 (February 2017)




Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

Project: Flying Horse North Filing No. 1

Basin ID: Pond 12



Example Zone Configuration (Retention Pond)

| | Stage (ft) | Zone Volume (ac-ft) | Outlet Type |
|-------------------|------------|---------------------|----------------------|
| Zone 1 (WQCV) | 1.56 | 0.375 | Orifice Plate |
| Zone 2 (EURV) | 2.15 | 0.285 | Orifice Plate |
| Zone 3 (100-year) | 4.90 | 1.660 | Weir&Pipe (Restrict) |
| | | 2.319 | Total |

0

User Input: Orifice at Underdrain Outlet (typically used to drain WQCV in a Filtration BMP)

Underdrain Orifice Invert Depth = ft (distance below the filtration media surface)
Underdrain Orifice Diameter = inches

Calculated Parameters for Underdrain

Underdrain Orifice Area = ft²
Underdrain Orifice Centroid = feet

User Input: Orifice Plate with one or more orifices or Elliptical Slot Weir (typically used to drain WQCV and/or EURV in a sedimentation BMP)

Calculated Parameters for Plate

Invert of Lowest Orifice = ft (relative to basin bottom at Stage = 0 ft)
Depth at top of Zone using Orifice Plate = ft (relative to basin bottom at Stage = 0 ft)
Orifice Plate: Orifice Vertical Spacing = inches
Orifice Plate: Orifice Area per Row = inches

WQ Orifice Area per Row = ft²
Elliptical Half-Width = feet
Elliptical Slot Centroid = feet
Elliptical Slot Area = ft²

User Input: Stage and Total Area of Each Orifice Row (numbered from lowest to highest)

| | Row 1 (required) | Row 2 (optional) | Row 3 (optional) | Row 4 (optional) | Row 5 (optional) | Row 6 (optional) | Row 7 (optional) | Row 8 (optional) |
|--------------------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Stage of Orifice Centroid (ft) | 0.00 | 0.80 | 1.60 | | | | | |
| Orifice Area (sq. inches) | 2.41 | 2.79 | 2.79 | | | | | |

| | Row 9 (optional) | Row 10 (optional) | Row 11 (optional) | Row 12 (optional) | Row 13 (optional) | Row 14 (optional) | Row 15 (optional) | Row 16 (optional) |
|--------------------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Stage of Orifice Centroid (ft) | | | | | | | | |
| Orifice Area (sq. inches) | | | | | | | | |

User Input: Vertical Orifice (Circular or Rectangular)

Calculated Parameters for Vertical Orifice

| | Not Selected | Not Selected | |
|---|--------------|--------------|---|
| Invert of Vertical Orifice = | N/A | N/A | ft (relative to basin bottom at Stage = 0 ft) |
| Depth at top of Zone using Vertical Orifice = | N/A | N/A | ft (relative to basin bottom at Stage = 0 ft) |
| Vertical Orifice Diameter = | N/A | N/A | inches |

Vertical Orifice Area = ft²
Vertical Orifice Centroid = feet

User Input: Overflow Weir (Dropbox) and Grate (Flat or Sloped)

Calculated Parameters for Overflow Weir

| | Zone 3 Weir | Not Selected | |
|---|-------------|--------------|---|
| Overflow Weir Front Edge Height, H _o = | 2.25 | N/A | ft (relative to basin bottom at Stage = 0 ft) |
| Overflow Weir Front Edge Length = | 6.00 | N/A | feet |
| Overflow Weir Slope = | 4.00 | N/A | H:V (enter zero for flat grate) |
| Horiz. Length of Weir Sides = | 4.00 | N/A | feet |
| Overflow Grate Open Area % = | 75% | N/A | %, grate open area/total area |
| Debris Clogging % = | 50% | N/A | % |

Height of Grate Upper Edge, H₁ = feet
Over Flow Weir Slope Length = feet
Grate Open Area / 100-yr Orifice Area = should be ≥ 4
Overflow Grate Open Area w/o Debris = ft²
Overflow Grate Open Area w/ Debris = ft²

User Input: Outlet Pipe w/ Flow Restriction Plate (Circular Orifice, Restrictor Plate, or Rectangular Orifice)

Calculated Parameters for Outlet Pipe w/ Flow Restriction Plate

| | Zone 3 Restrictor | Not Selected | |
|---|-------------------|--------------|--|
| Depth to Invert of Outlet Pipe = | 0.50 | N/A | ft (distance below basin bottom at Stage = 0 ft) |
| Outlet Pipe Diameter = | 30.00 | N/A | inches |
| Restrictor Plate Height Above Pipe Invert = | 24.00 | | inches |

Outlet Orifice Area = ft²
Outlet Orifice Centroid = feet
Half-Central Angle of Restrictor Plate on Pipe = radians

User Input: Emergency Spillway (Rectangular or Trapezoidal)

Calculated Parameters for Spillway

Spillway Invert Stage = ft (relative to basin bottom at Stage = 0 ft)
Spillway Crest Length = feet
Spillway End Slopes = H:V
Freeboard above Max Water Surface = feet


Spillway Design Flow Depth = feet
Stage at Top of Freeboard = feet
Basin Area at Top of Freeboard = acres

Routed Hydrograph Results

| | WQCV | EURV | 2 Year | 5 Year | 10 Year | 25 Year | 50 Year | 100 Year | 500 Year |
|---|-------|-------|--------|--------|------------------|------------------|----------------|----------------|----------|
| Design Storm Return Period = | | | | | | | | | |
| One-Hour Rainfall Depth (in) = | 0.53 | 1.07 | 1.19 | 1.50 | 1.75 | 2.00 | 2.25 | 2.52 | 3.39 |
| Calculated Runoff Volume (acre-ft) = | 0.375 | 0.659 | 0.461 | 0.708 | 1.484 | 3.636 | 4.987 | 6.752 | 10.997 |
| OPTIONAL Override Runoff Volume (acre-ft) = | | | | | | | | | |
| Inflow Hydrograph Volume (acre-ft) = | 0.374 | 0.659 | 0.461 | 0.707 | 1.483 | 3.636 | 4.986 | 6.752 | 10.992 |
| Predevelopment Unit Peak Flow, q (cfs/acre) = | 0.00 | 0.00 | 0.01 | 0.02 | 0.14 | 0.50 | 0.70 | 0.95 | 1.52 |
| Predevelopment Peak Q (cfs) = | 0.0 | 0.0 | 0.5 | 0.9 | 8.3 | 28.9 | 40.1 | 54.6 | 87.5 |
| Peak Inflow Q (cfs) = | 4.9 | 8.6 | 6.1 | 9.2 | 19.2 | 46.5 | 63.4 | 85.2 | 136.7 |
| Peak Outflow Q (cfs) = | 0.2 | 0.3 | 0.2 | 0.3 | 6.8 | 30.4 | 38.7 | 44.5 | 105.6 |
| Ratio Peak Outflow to Predevelopment Q = | N/A | N/A | N/A | 0.3 | 0.8 | 1.1 | 1.0 | 0.8 | 1.2 |
| Structure Controlling Flow = | Plate | Plate | Plate | Plate | Overflow Grate 1 | Overflow Grate 1 | Outlet Plate 1 | Outlet Plate 1 | Spillway |
| Max Velocity through Grate 1 (fps) = | N/A | N/A | N/A | N/A | 0.3 | 1.6 | 2.1 | 2.4 | 2.6 |
| Max Velocity through Grate 2 (fps) = | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Time to Drain 97% of Inflow Volume (hours) = | 43 | 55 | 47 | 56 | 56 | 44 | 40 | 35 | 26 |
| Time to Drain 99% of Inflow Volume (hours) = | 45 | 58 | 50 | 60 | 62 | 58 | 55 | 52 | 45 |
| Maximum Ponding Depth (ft) = | 1.49 | 2.04 | 1.66 | 2.13 | 2.84 | 3.65 | 4.23 | 5.40 | 6.38 |
| Area at Maximum Ponding Depth (acres) = | 0.46 | 0.50 | 0.47 | 0.51 | 0.55 | 0.61 | 0.65 | 0.74 | 0.82 |
| Maximum Volume Stored (acre-ft) = | 0.339 | 0.608 | 0.423 | 0.653 | 1.030 | 1.501 | 1.861 | 2.685 | 3.448 |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)



| S-A-V-D Chart Axis Override | X-axis | Left Y-Axis | Right Y-Axis |
|-----------------------------|--------|-------------|--------------|
| minimum bound | | | |
| maximum bound | | | |

Detention Basin Outlet Structure Design

UD-Detention, Version 3.07 (February 2017)

The user can create a summary S-A-V-D by entering the desired stage increments and the remainder of the table will populate automatically.

The user should graphically compare the summary S-A-V-D table to the full S-A-V-D table in the chart to confirm it captures all key transition points.

| Stage | Area | Area | Volume | Volume | Total |
|-------|------|------|--------|--------|-------|
|-------|------|------|--------|--------|-------|

[illegible]

Project Summary

| | |
|----------|-----------------------------------|
| Title | Flying Horse North Filing No.1 |
| Engineer | MAW |
| Company | CCES |
| Date | 4/4/2018 |

| | |
|-------|--------|
| Notes | 2 Year |
|-------|--------|

Table of Contents

| | | |
|-------------------|---|----|
| | Master Network Summary | 2 |
| Colo Springs 2015 | Time-Depth Curve, 2 years | 10 |
| FH North Pond 1 | | |
| | Elevation-Area Volume Curve, 2 years | 11 |
| FH North Pond 12 | | |
| | Elevation-Area Volume Curve, 2 years | 12 |
| FH North Pond 4 | | |
| | Elevation-Area Volume Curve, 2 years | 13 |
| FH North Pond 8 | | |
| | Elevation-Area Volume Curve, 2 years | 14 |
| FH North Pond 1 | | |
| | Composite Rating Curve, 2 years | 15 |
| FH North Pond 12 | | |
| | Composite Rating Curve, 2 years | 16 |
| FH North Pond 4 | | |
| | Composite Rating Curve, 2 years | 17 |
| FH North Pond 8 | | |
| | Composite Rating Curve, 2 years | 19 |
| FH North Pond 1 | | |
| | Elevation-Volume-Flow Table (Pond), 2 years | 21 |
| FH North Pond 12 | | |
| | Elevation-Volume-Flow Table (Pond), 2 years | 22 |
| FH North Pond 4 | | |
| | Elevation-Volume-Flow Table (Pond), 2 years | 23 |
| FH North Pond 8 | | |
| | Elevation-Volume-Flow Table (Pond), 2 years | 24 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|---------------------|-----------------------|----------------------------|---------------------------------|-------------------------|-----------------------------------|
| Area to HFR Pond 16 | Post-Development 2 YR | 2 | 4.331 | 12.250 | 20.25 |
| Area to Pond 1 | Post-Development 2 YR | 2 | 0.379 | 12.100 | 3.10 |
| BS-10 | Post-Development 2 YR | 2 | 0.416 | 12.050 | 5.95 |
| BS-11 | Post-Development 2 YR | 2 | 0.083 | 12.000 | 1.45 |
| BS-12 | Post-Development 2 YR | 2 | 0.104 | 12.100 | 0.78 |
| BS-13 | Post-Development 2 YR | 2 | 0.511 | 12.100 | 4.88 |
| BS-14 | Post-Development 2 YR | 2 | 0.263 | 12.100 | 2.48 |
| BS-15 | Post-Development 2 YR | 2 | 0.127 | 12.050 | 1.58 |
| BS-16 | Post-Development 2 YR | 2 | 0.445 | 12.150 | 3.42 |
| BS-17 | Post-Development 2 YR | 2 | 0.278 | 12.100 | 3.02 |
| BS-18 | Post-Development 2 YR | 2 | 0.499 | 12.100 | 3.50 |
| BS-19 | Post-Development 2 YR | 2 | 0.161 | 12.050 | 2.08 |
| BS-1A | Post-Development 2 YR | 2 | 0.047 | 12.100 | 0.36 |
| BS-1B | Post-Development 2 YR | 2 | 0.093 | 12.100 | 0.43 |
| BS-2 | Post-Development 2 YR | 2 | 0.176 | 12.000 | 2.90 |
| BS-20 | Post-Development 2 YR | 2 | 1.164 | 12.150 | 7.43 |
| BS-21 | Post-Development 2 YR | 2 | 1.202 | 12.200 | 7.78 |
| BS-22 | Post-Development 2 YR | 2 | 0.372 | 12.100 | 3.72 |
| BS-23 | Post-Development 2 YR | 2 | 0.657 | 12.150 | 4.49 |
| BS-23A | Post-Development 2 YR | 2 | 0.463 | 12.050 | 5.48 |
| BS-24 | Post-Development 2 YR | 2 | 0.114 | 12.100 | 0.59 |
| BS-25 | Post-Development 2 YR | 2 | 0.115 | 12.150 | 0.36 |
| BS-26 | Post-Development 2 YR | 2 | 0.016 | 14.250 | 0.04 |
| BS-27 | Post-Development 2 YR | 2 | 0.315 | 12.100 | 2.10 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|--------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| BS-28 | Post-Development 2 YR | 2 | 0.462 | 12.200 | 2.21 |
| BS-29 | Post-Development 2 YR | 2 | 0.329 | 12.200 | 1.43 |
| BS-2A | Post-Development 2 YR | 2 | 0.074 | 12.000 | 1.22 |
| BS-2B | Post-Development 2 YR | 2 | 0.083 | 12.000 | 1.40 |
| BS-3 | Post-Development 2 YR | 2 | 0.084 | 12.100 | 0.60 |
| BS-30 | Post-Development 2 YR | 2 | 0.091 | 12.100 | 0.65 |
| BS-31 | Post-Development 2 YR | 2 | 0.082 | 12.150 | 0.31 |
| BS-32 | Post-Development 2 YR | 2 | 0.061 | 12.100 | 0.25 |
| BS-33 | Post-Development 2 YR | 2 | 0.116 | 12.100 | 0.81 |
| BS-4 | Post-Development 2 YR | 2 | 0.222 | 12.100 | 1.86 |
| BS-5 | Post-Development 2 YR | 2 | 0.152 | 12.100 | 1.13 |
| BS-6 | Post-Development 2 YR | 2 | 0.111 | 12.000 | 1.93 |
| BS-7 | Post-Development 2 YR | 2 | 0.268 | 12.000 | 4.43 |
| BS-8 | Post-Development 2 YR | 2 | 0.093 | 12.000 | 1.55 |
| BS-9 | Post-Development 2 YR | 2 | 0.139 | 12.000 | 2.29 |
| CC-10 | Post-Development 2 YR | 2 | 0.839 | 12.350 | 2.56 |
| CC-11 | Post-Development 2 YR | 2 | 0.197 | 12.100 | 0.90 |
| CC-12 | Post-Development 2 YR | 2 | 0.165 | 12.150 | 0.98 |
| CC-13A | Post-Development 2 YR | 2 | 0.261 | 12.200 | 1.39 |
| CC-13B | Post-Development 2 YR | 2 | 0.344 | 12.200 | 1.84 |
| CC-13C | Post-Development 2 YR | 2 | 0.134 | 12.100 | 0.89 |
| CC-13D | Post-Development 2 YR | 2 | 0.254 | 12.150 | 1.54 |
| CC-14 | Post-Development 2 YR | 2 | 0.062 | 12.100 | 0.43 |
| CC-15 | Post-Development 2 YR | 2 | 0.173 | 12.100 | 1.08 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------------------------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| CC-16 | Post-Development 2 YR | 2 | 0.220 | 12.150 | 1.19 |
| CC-17 | Post-Development 2 YR | 2 | 0.337 | 12.200 | 1.66 |
| CC-18 | Post-Development 2 YR | 2 | 0.100 | 12.150 | 0.67 |
| CC-19 | Post-Development 2 YR | 2 | 0.050 | 12.150 | 0.30 |
| CC-1A | Post-Development 2 YR | 2 | 0.133 | 12.100 | 0.84 |
| CC-1B | Post-Development 2 YR | 2 | 0.166 | 12.150 | 0.98 |
| CC-20 | Post-Development 2 YR | 2 | 0.532 | 12.150 | 3.23 |
| CC-21 | Post-Development 2 YR | 2 | 0.048 | 12.300 | 0.12 |
| CC-22 | Post-Development 2 YR | 2 | 0.187 | 12.150 | 1.13 |
| CC-23 | Post-Development 2 YR | 2 | 0.074 | 12.200 | 0.37 |
| CC-24 | Post-Development 2 YR | 2 | 0.536 | 12.150 | 3.25 |
| CC-25 | Post-Development 2 YR | 2 | 0.047 | 12.100 | 0.30 |
| CC-26 | Post-Development 2 YR | 2 | 0.226 | 12.150 | 1.35 |
| CC-27 | Post-Development 2 YR | 2 | 0.237 | 12.200 | 1.15 |
| CC-28 | Post-Development 2 YR | 2 | 1.917 | 12.500 | 6.47 |
| CC-2A | Post-Development 2 YR | 2 | 0.149 | 12.100 | 0.99 |
| CC-2B | Post-Development 2 YR | 2 | 0.282 | 12.100 | 1.87 |
| CC-2C | Post-Development 2 YR | 2 | 0.087 | 12.100 | 0.65 |
| CC-3 | Post-Development 2 YR | 2 | 0.551 | 12.350 | 1.80 |
| CC-4A | Post-Development 2 YR | 2 | 2.341 | 12.200 | 15.39 |
| CC-4B | Post-Development 2 YR | 2 | 0.316 | 12.100 | 3.95 |
| CC-4C (Pre-Development) | Post-Development 2 YR | 2 | 0.057 | 12.100 | 0.15 |
| CC-5 | Post-Development 2 YR | 2 | 0.303 | 12.150 | 1.81 |
| CC-6 | Post-Development 2 YR | 2 | 0.376 | 12.150 | 2.28 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|--------------------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| CC-7 | Post-Development 2 YR | 2 | 0.249 | 12.150 | 1.38 |
| CC-8 | Post-Development 2 YR | 2 | 0.104 | 12.150 | 0.63 |
| CC-9 | Post-Development 2 YR | 2 | 0.076 | 12.100 | 0.55 |
| EX-24 | Post-Development 2 YR | 2 | 0.086 | 14.250 | 0.21 |
| EX-DP-3 (Pre-Dev.) | Post-Development 2 YR | 2 | 0.235 | 14.300 | 0.54 |
| OS-10 | Post-Development 2 YR | 2 | 0.072 | 12.050 | 0.73 |
| OS-11 | Post-Development 2 YR | 2 | 0.420 | 12.200 | 2.36 |
| OS-12 | Post-Development 2 YR | 2 | 0.678 | 12.300 | 2.17 |
| OS-13 | Post-Development 2 YR | 2 | 0.384 | 12.250 | 1.37 |
| OS-14 | Post-Development 2 YR | 2 | 0.238 | 12.250 | 0.68 |
| OS-15 | Post-Development 2 YR | 2 | 0.829 | 12.250 | 3.30 |
| OS-16 | Post-Development 2 YR | 2 | 0.061 | 12.100 | 0.38 |
| OS-17 | Post-Development 2 YR | 2 | 0.214 | 12.100 | 1.56 |
| OS-18 | Post-Development 2 YR | 2 | 0.176 | 12.100 | 1.26 |
| OS-1A | Post-Development 2 YR | 2 | 0.060 | 12.100 | 0.43 |
| OS-1B | Post-Development 2 YR | 2 | 0.076 | 12.100 | 0.52 |
| OS-2 | Post-Development 2 YR | 2 | 0.022 | 12.300 | 0.05 |
| OS-3 | Post-Development 2 YR | 2 | 0.138 | 12.100 | 1.01 |
| OS-4 | Post-Development 2 YR | 2 | 0.445 | 12.100 | 2.84 |
| OS-5 | Post-Development 2 YR | 2 | 0.400 | 12.250 | 1.87 |
| OS-6 | Post-Development 2 YR | 2 | 0.125 | 12.100 | 0.86 |
| OS-7 | Post-Development 2 YR | 2 | 0.068 | 12.100 | 0.51 |
| OS-8 | Post-Development 2 YR | 2 | 0.264 | 12.100 | 2.12 |
| OS-9 | Post-Development 2 YR | 2 | 0.064 | 14.350 | 0.13 |

Subsection: Master Network Summary

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|-----------------------|----------------------------|---------------------------------|-------------------------|-----------------------------------|
| DP-1 | Post-Development 2 YR | 2 | 0.143 | 12.050 | 1.61 |
| DP-10 | Post-Development 2 YR | 2 | 1.530 | 12.100 | 11.95 |
| DP-11 | Post-Development 2 YR | 2 | 0.445 | 12.150 | 3.42 |
| DP-12 | Post-Development 2 YR | 2 | 0.572 | 12.150 | 4.24 |
| DP-13 | Post-Development 2 YR | 2 | 1.520 | 14.500 | 3.35 |
| DP-16 | Post-Development 2 YR | 2 | 4.050 | 12.200 | 24.96 |
| DP-17 | Post-Development 2 YR | 2 | 2.080 | 16.550 | 3.36 |
| DP-18 | Post-Development 2 YR | 2 | 1.058 | 12.150 | 5.03 |
| DP-19 | Post-Development 2 YR | 2 | 1.520 | 12.100 | 3.82 |
| DP-2 | Post-Development 2 YR | 2 | 0.365 | 12.100 | 3.23 |
| DP-20 | Post-Development 2 YR | 2 | 0.810 | 12.300 | 2.70 |
| DP-21 | Post-Development 2 YR | 2 | 0.532 | 12.150 | 2.10 |
| DP-22 | Post-Development 2 YR | 2 | 0.814 | 12.150 | 3.73 |
| DP-23 | Post-Development 2 YR | 2 | 0.789 | 12.350 | 2.47 |
| DP-24 | Post-Development 2 YR | 2 | 0.360 | 12.150 | 1.94 |
| DP-25 | Post-Development 2 YR | 2 | 0.313 | 23.950 | 0.35 |
| DP-26 | Post-Development 2 YR | 2 | 0.943 | 12.300 | 2.98 |
| DP-27 | Post-Development 2 YR | 2 | 0.705 | 12.150 | 4.29 |
| DP-28 | Post-Development 2 YR | 2 | 1.090 | 12.250 | 4.59 |
| DP-29 | Post-Development 2 YR | 2 | 1.552 | 12.350 | 5.78 |
| DP-3 | Post-Development 2 YR | 2 | 0.572 | 12.150 | 1.43 |
| DP-30 | Post-Development 2 YR | 2 | 0.100 | 12.150 | 0.67 |
| DP-31 | Post-Development 2 YR | 2 | 0.150 | 12.150 | 0.94 |
| DP-32 | Post-Development 2 YR | 2 | 0.398 | 12.200 | 1.99 |

Subsection: Master Network Summary

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| DP-33 | Post-Development 2 YR | 2 | 0.610 | 12.150 | 3.60 |
| DP-34 | Post-Development 2 YR | 2 | 2.819 | 13.250 | 5.98 |
| DP-4 | Post-Development 2 YR | 2 | 0.176 | 12.000 | 2.90 |
| DP-5 | Post-Development 2 YR | 2 | 0.150 | 12.050 | 1.54 |
| DP-6 | Post-Development 2 YR | 2 | 0.106 | 12.100 | 0.64 |
| DP-7 | Post-Development 2 YR | 2 | 0.290 | 12.100 | 2.14 |
| DP-8 | Post-Development 2 YR | 2 | 5.527 | 12.350 | 20.94 |
| DP-9 | Post-Development 2 YR | 2 | 0.172 | 12.100 | 1.29 |
| J-75 | Post-Development 2 YR | 2 | 2.535 | 12.450 | 8.58 |
| O-100 | Post-Development 2 YR | 2 | 0.197 | 12.100 | 0.90 |
| O-101 | Post-Development 2 YR | 2 | 0.254 | 12.150 | 1.54 |
| O-102 | Post-Development 2 YR | 2 | 0.062 | 12.100 | 0.43 |
| O-108 | Post-Development 2 YR | 2 | 0.235 | 12.150 | 1.24 |
| O-110 | Post-Development 2 YR | 2 | 0.047 | 12.100 | 0.30 |
| O-122 | Post-Development 2 YR | 2 | 0.047 | 12.100 | 0.36 |
| O-125 | Post-Development 2 YR | 2 | 0.165 | 12.150 | 0.98 |
| O-126 | Post-Development 2 YR | 2 | 2.733 | 12.200 | 18.53 |
| O-127 | Post-Development 2 YR | 2 | 0.426 | 12.000 | 7.22 |
| O-129 | Post-Development 2 YR | 2 | 0.400 | 12.250 | 1.87 |
| O-137 | Post-Development 2 YR | 2 | 0.086 | 14.250 | 0.21 |
| O-138 | Post-Development 2 YR | 2 | 0.235 | 14.300 | 0.54 |
| O-73 | Post-Development 2 YR | 2 | 0.114 | 12.100 | 0.59 |
| O-74 | Post-Development 2 YR | 2 | 0.115 | 12.150 | 0.36 |
| O-75 | Post-Development 2 YR | 2 | 0.016 | 14.250 | 0.04 |

Subsection: Master Network Summary

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| O-80 | Post-Development 2 YR | 2 | 0.082 | 12.150 | 0.31 |
| O-81 | Post-Development 2 YR | 2 | 0.061 | 12.100 | 0.25 |
| O-82 | Post-Development 2 YR | 2 | 0.116 | 12.100 | 0.81 |
| O-86 | Post-Development 2 YR | 2 | 0.166 | 12.150 | 0.98 |
| O-96 | Post-Development 2 YR | 2 | 0.087 | 12.100 | 0.65 |
| O-98 | Post-Development 2 YR | 2 | 0.249 | 12.150 | 1.38 |

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|--|------------------------------------|
| Exist. HFR Pond 16 (IN) | Post-Development 2 YR | 2 | 4.331 | 12.250 | 20.25 | (N/A) | (N/A) |
| Exist. HFR Pond 16 (OUT) | Post-Development 2 YR | 2 | 4.273 | 12.400 | 17.00 | 7,455.39 | 0.222 |
| FH North Pond 1 (IN) | Post-Development 2 YR | 2 | 0.379 | 12.100 | 3.10 | (N/A) | (N/A) |
| FH North Pond 1 (OUT) | Post-Development 2 YR | 2 | 0.373 | 13.350 | 0.62 | 7,391.48 | 0.086 |
| FH North Pond 12 (IN) | Post-Development 2 YR | 2 | 0.736 | 12.150 | 4.19 | (N/A) | (N/A) |
| FH North Pond 12 (OUT) | Post-Development 2 YR | 2 | 0.313 | 23.950 | 0.35 | 7,546.37 | 0.421 |
| FH North Pond 4 (IN) | Post-Development 2 YR | 2 | 2.442 | 12.150 | 18.30 | (N/A) | (N/A) |
| FH North Pond 4 (OUT) | Post-Development 2 YR | 2 | 1.520 | 14.500 | 3.35 | 7,425.62 | 1.002 |
| FH North Pond 8 (IN) | Post-Development 2 YR | 2 | 4.509 | 12.200 | 27.90 | (N/A) | (N/A) |

Subsection: Master Network Summary

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|-----------------------|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| FH North Pond 8 (OUT) | Post-Development 2 YR | 2 | 2.080 | 16.550 | 3.36 | 7,374.84 | 2.484 |
| Golf Course Pond 6 (IN) | Post-Development 2 YR | 2 | 2.366 | 12.200 | 15.07 | (N/A) | (N/A) |
| Golf Course Pond 6 (OUT) | Post-Development 2 YR | 2 | 2.363 | 12.200 | 14.50 | 7,436.08 | 2.505 |
| Golf Course Pond 7 (IN) | Post-Development 2 YR | 2 | 2.896 | 12.200 | 17.89 | (N/A) | (N/A) |
| Golf Course Pond 7 (OUT) | Post-Development 2 YR | 2 | 2.896 | 12.200 | 17.64 | 7,424.09 | 1.477 |

Subsection: Time-Depth Curve
Label: Colo Springs 2015

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Time-Depth Curve: TYPE II 24 HOUR

| | |
|--------------|-----------------|
| Label | TYPE II 24 HOUR |
| Start Time | 0.000 hours |
| Increment | 0.250 hours |
| End Time | 24.000 hours |
| Return Event | 2 years |

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.250 hours

Time on left represents time for first value in each row.

| Time (hours) | Depth (in) | Depth (in) | Depth (in) | Depth (in) | Depth (in) |
|-----------------|---------------|---------------|---------------|---------------|---------------|
| 0.000 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1.250 | 0.0 | 0.0 | 0.0 | 0.0 | 0.1 |
| 2.500 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |
| 3.750 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |
| 5.000 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 |
| 6.250 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| 7.500 | 0.2 | 0.2 | 0.3 | 0.3 | 0.3 |
| 8.750 | 0.3 | 0.3 | 0.3 | 0.3 | 0.4 |
| 10.000 | 0.4 | 0.4 | 0.4 | 0.5 | 0.5 |
| 11.250 | 0.5 | 0.6 | 0.8 | 1.4 | 1.5 |
| 12.500 | 1.5 | 1.6 | 1.6 | 1.7 | 1.7 |
| 13.750 | 1.7 | 1.7 | 1.8 | 1.8 | 1.8 |
| 15.000 | 1.8 | 1.8 | 1.8 | 1.9 | 1.9 |
| 16.250 | 1.9 | 1.9 | 1.9 | 1.9 | 1.9 |
| 17.500 | 1.9 | 1.9 | 1.9 | 1.9 | 2.0 |
| 18.750 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| 20.000 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| 21.250 | 2.0 | 2.0 | 2.0 | 2.1 | 2.1 |
| 22.500 | 2.1 | 2.1 | 2.1 | 2.1 | 2.1 |
| 23.750 | 2.1 | 2.1 | (N/A) | (N/A) | (N/A) |

Subsection: Elevation-Area Volume Curve
 Label: FH North Pond 1

Return Event: 2 years
 Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,390.00 | 0.0000 | 0.004 | 0.000 | 0.000 | 0.000 |
| 7,392.00 | 0.0000 | 0.242 | 0.277 | 0.185 | 0.185 |
| 7,394.00 | 0.0000 | 0.311 | 0.827 | 0.552 | 0.736 |
| 7,396.00 | 0.0000 | 0.387 | 1.045 | 0.697 | 1.433 |

Subsection: Elevation-Area Volume Curve
 Label: FH North Pond 12

Return Event: 2 years
 Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,544.50 | 0.0000 | 0.002 | 0.000 | 0.000 | 0.000 |
| 7,546.00 | 0.0000 | 0.462 | 0.494 | 0.247 | 0.247 |
| 7,548.00 | 0.0000 | 0.600 | 1.588 | 1.059 | 1.306 |
| 7,550.00 | 0.0000 | 0.749 | 2.019 | 1.346 | 2.652 |
| 7,552.00 | 0.0000 | 0.905 | 2.477 | 1.652 | 4.304 |

Subsection: Elevation-Area Volume Curve
 Label: FH North Pond 4

Return Event: 2 years
 Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,421.50 | 0.0000 | 0.004 | 0.000 | 0.000 | 0.000 |
| 7,422.00 | 0.0000 | 0.004 | 0.012 | 0.002 | 0.002 |
| 7,424.00 | 0.0000 | 0.248 | 0.283 | 0.189 | 0.191 |
| 7,426.00 | 0.0000 | 0.981 | 1.722 | 1.148 | 1.339 |
| 7,428.00 | 0.0000 | 1.226 | 3.304 | 2.202 | 3.542 |
| 7,430.00 | 0.0000 | 1.432 | 3.983 | 2.655 | 6.197 |
| 7,432.00 | 0.0000 | 1.651 | 4.621 | 3.080 | 9.277 |

Subsection: Elevation-Area Volume Curve
Label: FH North Pond 8

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,369.00 | 0.0000 | 0.009 | 0.000 | 0.000 | 0.000 |
| 7,370.00 | 0.0000 | 0.009 | 0.027 | 0.009 | 0.009 |
| 7,372.00 | 0.0000 | 0.415 | 0.485 | 0.323 | 0.332 |
| 7,374.00 | 0.0000 | 0.918 | 1.950 | 1.300 | 1.633 |
| 7,376.00 | 0.0000 | 1.411 | 3.467 | 2.311 | 3.944 |
| 7,378.00 | 0.0000 | 1.594 | 4.505 | 3.003 | 6.947 |
| 7,380.00 | 0.0000 | 1.788 | 5.070 | 3.380 | 10.327 |
| 7,382.00 | 0.0000 | 2.032 | 5.726 | 3.817 | 14.145 |

Subsection: Composite Rating Curve
Label: FH North Pond 1

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,390.00 | 0.00 | (N/A) | 0.00 |
| 7,390.50 | 0.21 | (N/A) | 0.00 |
| 7,391.00 | 0.42 | (N/A) | 0.00 |
| 7,391.50 | 0.63 | (N/A) | 0.00 |
| 7,392.00 | 0.84 | (N/A) | 0.00 |
| 7,392.50 | 1.05 | (N/A) | 0.00 |
| 7,392.75 | 1.15 | (N/A) | 0.00 |
| 7,393.00 | 2.70 | (N/A) | 0.00 |
| 7,393.50 | 9.09 | (N/A) | 0.00 |
| 7,394.00 | 18.16 | (N/A) | 0.00 |
| 7,394.50 | 29.05 | (N/A) | 0.00 |
| 7,395.00 | 41.22 | (N/A) | 0.00 |
| 7,395.50 | 47.14 | (N/A) | 0.00 |
| 7,396.00 | 48.76 | (N/A) | 0.00 |

Contributing Structures

| |
|---|
| (no Q: Riser - 1,Orifice - 1,Culvert - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Composite Rating Curve
Label: FH North Pond 12

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,544.50 | 0.00 | (N/A) | 0.00 |
| 7,545.00 | 0.09 | (N/A) | 0.00 |
| 7,545.50 | 0.19 | (N/A) | 0.00 |
| 7,546.00 | 0.28 | (N/A) | 0.00 |
| 7,546.50 | 0.37 | (N/A) | 0.00 |
| 7,546.75 | 0.42 | (N/A) | 0.00 |
| 7,547.00 | 1.93 | (N/A) | 0.00 |
| 7,547.50 | 8.19 | (N/A) | 0.00 |
| 7,548.00 | 17.12 | (N/A) | 0.00 |
| 7,548.50 | 27.99 | (N/A) | 0.00 |
| 7,549.00 | 33.62 | (N/A) | 0.00 |
| 7,549.50 | 35.86 | (N/A) | 0.00 |
| 7,550.00 | 37.97 | (N/A) | 0.00 |
| 7,550.50 | 39.96 | (N/A) | 0.00 |
| 7,551.00 | 41.87 | (N/A) | 0.00 |
| 7,551.50 | 43.69 | (N/A) | 0.00 |
| 7,552.00 | 45.43 | (N/A) | 0.00 |

Contributing Structures

| |
|---|
| (no Q: Riser - 1,Orifice - 1,Culvert - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Composite Rating Curve
Label: FH North Pond 4

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,421.50 | 0.00 | (N/A) | 0.00 |
| 7,422.00 | 0.09 | (N/A) | 0.00 |
| 7,422.50 | 0.19 | (N/A) | 0.00 |
| 7,423.00 | 0.29 | (N/A) | 0.00 |
| 7,423.50 | 0.38 | (N/A) | 0.00 |
| 7,424.00 | 0.48 | (N/A) | 0.00 |
| 7,424.50 | 0.57 | (N/A) | 0.00 |
| 7,425.00 | 0.67 | (N/A) | 0.00 |
| 7,425.50 | 0.77 | (N/A) | 0.00 |
| 7,426.00 | 11.42 | (N/A) | 0.00 |
| 7,426.50 | 30.84 | (N/A) | 0.00 |
| 7,427.00 | 55.96 | (N/A) | 0.00 |
| 7,427.50 | 85.67 | (N/A) | 0.00 |
| 7,428.00 | 119.35 | (N/A) | 0.00 |
| 7,428.50 | 156.50 | (N/A) | 0.00 |
| 7,429.00 | 196.62 | (N/A) | 0.00 |
| 7,429.50 | 205.78 | (N/A) | 0.00 |
| 7,430.00 | 211.74 | (N/A) | 0.00 |
| 7,430.50 | 217.53 | (N/A) | 0.00 |
| 7,431.00 | 223.18 | (N/A) | 0.00 |
| 7,431.50 | 228.71 | (N/A) | 0.00 |
| 7,432.00 | 234.08 | (N/A) | 0.00 |

Contributing Structures

(no Q: Riser - 1, Orifice - 1, Culvert - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)

Subsection: Composite Rating Curve
Label: FH North Pond 4

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Contributing Structures |
|---|
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,369.00 | 0.00 | (N/A) | 0.00 |
| 7,369.25 | 0.00 | (N/A) | 0.00 |
| 7,369.50 | 0.00 | (N/A) | 0.00 |
| 7,370.00 | 0.12 | (N/A) | 0.00 |
| 7,370.50 | 0.23 | (N/A) | 0.00 |
| 7,371.00 | 0.35 | (N/A) | 0.00 |
| 7,371.50 | 0.47 | (N/A) | 0.00 |
| 7,372.00 | 0.58 | (N/A) | 0.00 |
| 7,372.50 | 0.69 | (N/A) | 0.00 |
| 7,373.00 | 0.81 | (N/A) | 0.00 |
| 7,373.50 | 0.92 | (N/A) | 0.00 |
| 7,374.00 | 1.04 | (N/A) | 0.00 |
| 7,374.50 | 1.15 | (N/A) | 0.00 |
| 7,374.75 | 1.21 | (N/A) | 0.00 |
| 7,375.00 | 7.17 | (N/A) | 0.00 |
| 7,375.50 | 32.24 | (N/A) | 0.00 |
| 7,376.00 | 68.01 | (N/A) | 0.00 |
| 7,376.50 | 112.00 | (N/A) | 0.00 |
| 7,377.00 | 162.75 | (N/A) | 0.00 |
| 7,377.50 | 219.40 | (N/A) | 0.00 |
| 7,378.00 | 254.44 | (N/A) | 0.00 |
| 7,378.50 | 266.12 | (N/A) | 0.00 |
| 7,379.00 | 277.33 | (N/A) | 0.00 |
| 7,379.50 | 288.06 | (N/A) | 0.00 |
| 7,380.00 | 298.45 | (N/A) | 0.00 |
| 7,380.50 | 308.47 | (N/A) | 0.00 |
| 7,381.00 | 318.15 | (N/A) | 0.00 |
| 7,381.50 | 327.59 | (N/A) | 0.00 |
| 7,382.00 | 336.74 | (N/A) | 0.00 |

Contributing Structures

(no Q: Riser - 1,Orifice - 1,Culvert - 1)
 (no Q: Riser - 1,Orifice - 1,Culvert - 1)
 (no Q: Riser - 1,Orifice - 1,Culvert - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Contributing Structures |
|--|
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |

Subsection: Elevation-Volume-Flow Table (Pond)
 Label: FH North Pond 1

Return Event: 2 years
 Storm Event: TYPE II 24 HOUR

| Infiltration | |
|------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,390.00 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|----------------|------------------------------|-----------------|--------------|-----------------------------------|-----------------------------------|-------------------------------|
| 7,390.00 | 0.00 | 0.000 | 0.004 | 0.00 | 0.00 | 0.00 |
| 7,390.50 | 0.21 | 0.007 | 0.029 | 0.00 | 0.21 | 3.74 |
| 7,391.00 | 0.42 | 0.033 | 0.077 | 0.00 | 0.42 | 16.33 |
| 7,391.50 | 0.63 | 0.088 | 0.148 | 0.00 | 0.63 | 43.31 |
| 7,392.00 | 0.84 | 0.185 | 0.242 | 0.00 | 0.84 | 90.25 |
| 7,392.50 | 1.05 | 0.310 | 0.258 | 0.00 | 1.05 | 151.00 |
| 7,392.75 | 1.15 | 0.375 | 0.267 | 0.00 | 1.15 | 182.89 |
| 7,393.00 | 2.70 | 0.443 | 0.275 | 0.00 | 2.70 | 217.24 |
| 7,393.50 | 9.09 | 0.585 | 0.293 | 0.00 | 9.09 | 292.39 |
| 7,394.00 | 18.16 | 0.736 | 0.311 | 0.00 | 18.16 | 374.53 |
| 7,394.50 | 29.05 | 0.896 | 0.329 | 0.00 | 29.05 | 462.88 |
| 7,395.00 | 41.22 | 1.066 | 0.348 | 0.00 | 41.22 | 556.98 |
| 7,395.50 | 47.14 | 1.244 | 0.367 | 0.00 | 47.14 | 649.42 |
| 7,396.00 | 48.76 | 1.433 | 0.387 | 0.00 | 48.76 | 742.29 |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 12

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,544.50 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,544.50 | 0.00 | 0.000 | 0.002 | 0.00 | 0.00 | 0.00 |
| 7,545.00 | 0.09 | 0.013 | 0.066 | 0.00 | 0.09 | 6.48 |
| 7,545.50 | 0.19 | 0.081 | 0.219 | 0.00 | 0.19 | 39.23 |
| 7,546.00 | 0.28 | 0.247 | 0.462 | 0.00 | 0.28 | 119.92 |
| 7,546.50 | 0.37 | 0.486 | 0.495 | 0.00 | 0.37 | 235.77 |
| 7,546.75 | 0.42 | 0.612 | 0.512 | 0.00 | 0.42 | 296.70 |
| 7,547.00 | 1.93 | 0.742 | 0.529 | 0.00 | 1.93 | 361.15 |
| 7,547.50 | 8.19 | 1.015 | 0.564 | 0.00 | 8.19 | 499.59 |
| 7,548.00 | 17.12 | 1.306 | 0.600 | 0.00 | 17.12 | 649.32 |
| 7,548.50 | 27.99 | 1.615 | 0.636 | 0.00 | 27.99 | 809.69 |
| 7,549.00 | 33.62 | 1.942 | 0.672 | 0.00 | 33.62 | 973.58 |
| 7,549.50 | 35.86 | 2.288 | 0.710 | 0.00 | 35.86 | 1,143.10 |
| 7,550.00 | 37.97 | 2.652 | 0.749 | 0.00 | 37.97 | 1,321.75 |
| 7,550.50 | 39.96 | 3.036 | 0.787 | 0.00 | 39.96 | 1,509.54 |
| 7,551.00 | 41.87 | 3.439 | 0.825 | 0.00 | 41.87 | 1,706.45 |
| 7,551.50 | 43.69 | 3.862 | 0.865 | 0.00 | 43.69 | 1,912.72 |
| 7,552.00 | 45.43 | 4.304 | 0.905 | 0.00 | 45.43 | 2,128.56 |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 4

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,421.50 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,421.50 | 0.00 | 0.000 | 0.004 | 0.00 | 0.00 | 0.00 |
| 7,422.00 | 0.09 | 0.002 | 0.004 | 0.00 | 0.09 | 1.06 |
| 7,422.50 | 0.19 | 0.009 | 0.030 | 0.00 | 0.19 | 4.74 |
| 7,423.00 | 0.29 | 0.035 | 0.079 | 0.00 | 0.29 | 17.47 |
| 7,423.50 | 0.38 | 0.092 | 0.152 | 0.00 | 0.38 | 44.96 |
| 7,424.00 | 0.48 | 0.191 | 0.248 | 0.00 | 0.48 | 92.92 |
| 7,424.50 | 0.57 | 0.348 | 0.386 | 0.00 | 0.57 | 169.09 |
| 7,425.00 | 0.67 | 0.582 | 0.554 | 0.00 | 0.67 | 282.28 |
| 7,425.50 | 0.77 | 0.907 | 0.752 | 0.00 | 0.77 | 439.80 |
| 7,426.00 | 11.42 | 1.339 | 0.981 | 0.00 | 11.42 | 659.57 |
| 7,426.50 | 30.84 | 1.844 | 1.040 | 0.00 | 30.84 | 923.46 |
| 7,427.00 | 55.96 | 2.379 | 1.100 | 0.00 | 55.96 | 1,207.47 |
| 7,427.50 | 85.67 | 2.945 | 1.162 | 0.00 | 85.67 | 1,510.87 |
| 7,428.00 | 119.35 | 3.542 | 1.226 | 0.00 | 119.35 | 1,833.49 |
| 7,428.50 | 156.50 | 4.167 | 1.276 | 0.00 | 156.50 | 2,173.36 |
| 7,429.00 | 196.62 | 4.818 | 1.327 | 0.00 | 196.62 | 2,528.43 |
| 7,429.50 | 205.78 | 5.494 | 1.379 | 0.00 | 205.78 | 2,864.99 |
| 7,430.00 | 211.74 | 6.197 | 1.432 | 0.00 | 211.74 | 3,211.06 |
| 7,430.50 | 217.53 | 6.926 | 1.485 | 0.00 | 217.53 | 3,569.83 |
| 7,431.00 | 223.18 | 7.682 | 1.540 | 0.00 | 223.18 | 3,941.46 |
| 7,431.50 | 228.71 | 8.466 | 1.595 | 0.00 | 228.71 | 4,326.23 |
| 7,432.00 | 234.08 | 9.277 | 1.651 | 0.00 | 234.08 | 4,724.32 |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 8

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,369.00 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,369.00 | 0.00 | 0.000 | 0.009 | 0.00 | 0.00 | 0.00 |
| 7,369.25 | 0.00 | 0.002 | 0.009 | 0.00 | 0.00 | 1.09 |
| 7,369.50 | 0.00 | 0.004 | 0.009 | 0.00 | 0.00 | 2.18 |
| 7,370.00 | 0.12 | 0.009 | 0.009 | 0.00 | 0.12 | 4.47 |
| 7,370.50 | 0.23 | 0.023 | 0.054 | 0.00 | 0.23 | 11.44 |
| 7,371.00 | 0.35 | 0.069 | 0.137 | 0.00 | 0.35 | 33.85 |
| 7,371.50 | 0.47 | 0.166 | 0.257 | 0.00 | 0.47 | 80.81 |
| 7,372.00 | 0.58 | 0.332 | 0.415 | 0.00 | 0.58 | 161.47 |
| 7,372.50 | 0.69 | 0.566 | 0.522 | 0.00 | 0.69 | 274.74 |
| 7,373.00 | 0.81 | 0.857 | 0.642 | 0.00 | 0.81 | 415.47 |
| 7,373.50 | 0.92 | 1.210 | 0.774 | 0.00 | 0.92 | 586.62 |
| 7,374.00 | 1.04 | 1.633 | 0.918 | 0.00 | 1.04 | 791.20 |
| 7,374.50 | 1.15 | 2.120 | 1.031 | 0.00 | 1.15 | 1,027.05 |
| 7,374.75 | 1.21 | 2.385 | 1.091 | 0.00 | 1.21 | 1,155.47 |
| 7,375.00 | 7.17 | 2.665 | 1.151 | 0.00 | 7.17 | 1,297.03 |
| 7,375.50 | 32.24 | 3.272 | 1.278 | 0.00 | 32.24 | 1,615.90 |
| 7,376.00 | 68.01 | 3.944 | 1.411 | 0.00 | 68.01 | 1,976.89 |
| 7,376.50 | 112.00 | 4.661 | 1.456 | 0.00 | 112.00 | 2,367.74 |
| 7,377.00 | 162.75 | 5.400 | 1.501 | 0.00 | 162.75 | 2,776.25 |
| 7,377.50 | 219.40 | 6.162 | 1.547 | 0.00 | 219.40 | 3,201.72 |
| 7,378.00 | 254.44 | 6.947 | 1.594 | 0.00 | 254.44 | 3,616.84 |
| 7,378.50 | 266.12 | 7.756 | 1.641 | 0.00 | 266.12 | 4,020.00 |
| 7,379.00 | 277.33 | 8.589 | 1.690 | 0.00 | 277.33 | 4,434.25 |
| 7,379.50 | 288.06 | 9.446 | 1.738 | 0.00 | 288.06 | 4,859.76 |
| 7,380.00 | 298.45 | 10.327 | 1.788 | 0.00 | 298.45 | 5,296.84 |
| 7,380.50 | 308.47 | 11.236 | 1.848 | 0.00 | 308.47 | 5,746.74 |
| 7,381.00 | 318.15 | 12.175 | 1.908 | 0.00 | 318.15 | 6,210.82 |
| 7,381.50 | 327.59 | 13.144 | 1.970 | 0.00 | 327.59 | 6,689.43 |
| 7,382.00 | 336.74 | 14.145 | 2.032 | 0.00 | 336.74 | 7,182.75 |

Index

C

Colo Springs 2015 (Time-Depth Curve, 2 years)...10

F

FH North Pond 1 (Composite Rating Curve, 2 years)...15

FH North Pond 1 (Elevation-Area Volume Curve, 2 years)...11

FH North Pond 1 (Elevation-Volume-Flow Table (Pond), 2 years)...21

FH North Pond 12 (Composite Rating Curve, 2 years)...16

FH North Pond 12 (Elevation-Area Volume Curve, 2 years)...12

FH North Pond 12 (Elevation-Volume-Flow Table (Pond), 2 years)...22

FH North Pond 4 (Composite Rating Curve, 2 years)...17, 18

FH North Pond 4 (Elevation-Area Volume Curve, 2 years)...13

FH North Pond 4 (Elevation-Volume-Flow Table (Pond), 2 years)...23

FH North Pond 8 (Composite Rating Curve, 2 years)...19, 20

FH North Pond 8 (Elevation-Area Volume Curve, 2 years)...14

FH North Pond 8 (Elevation-Volume-Flow Table (Pond), 2 years)...24

M

Master Network Summary...2, 3, 4, 5, 6, 7, 8, 9

Project Summary

| | |
|----------|-----------------------------------|
| Title | Flying Horse North Filing No.1 |
| Engineer | MAW |
| Company | CCES |
| Date | 4/4/2018 |

| | |
|-------|--------|
| Notes | 5 Year |
|-------|--------|

Table of Contents

| | | |
|-------------------|---|----|
| | Master Network Summary | 2 |
| Colo Springs 2015 | Time-Depth Curve, 5 years | 10 |
| FH North Pond 1 | | |
| | Elevation-Area Volume Curve, 5 years | 11 |
| FH North Pond 12 | | |
| | Elevation-Area Volume Curve, 5 years | 12 |
| FH North Pond 4 | | |
| | Elevation-Area Volume Curve, 5 years | 13 |
| FH North Pond 8 | | |
| | Elevation-Area Volume Curve, 5 years | 14 |
| FH North Pond 1 | | |
| | Composite Rating Curve, 5 years | 15 |
| FH North Pond 12 | | |
| | Composite Rating Curve, 5 years | 16 |
| FH North Pond 4 | | |
| | Composite Rating Curve, 5 years | 17 |
| FH North Pond 8 | | |
| | Composite Rating Curve, 5 years | 19 |
| FH North Pond 1 | | |
| | Elevation-Volume-Flow Table (Pond), 5 years | 21 |
| FH North Pond 12 | | |
| | Elevation-Volume-Flow Table (Pond), 5 years | 22 |
| FH North Pond 4 | | |
| | Elevation-Volume-Flow Table (Pond), 5 years | 23 |
| FH North Pond 8 | | |
| | Elevation-Volume-Flow Table (Pond), 5 years | 24 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|---------------------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| Area to HFR Pond 16 | Post-Development 5 YR | 5 | 9.990 | 12.200 | 77.31 |
| Area to Pond 1 | Post-Development 5 YR | 5 | 0.813 | 12.100 | 9.36 |
| BS-10 | Post-Development 5 YR | 5 | 0.610 | 12.050 | 8.66 |
| BS-11 | Post-Development 5 YR | 5 | 0.122 | 12.000 | 2.08 |
| BS-12 | Post-Development 5 YR | 5 | 0.240 | 12.050 | 3.01 |
| BS-13 | Post-Development 5 YR | 5 | 1.054 | 12.050 | 12.78 |
| BS-14 | Post-Development 5 YR | 5 | 0.545 | 12.050 | 6.57 |
| BS-15 | Post-Development 5 YR | 5 | 0.250 | 12.050 | 3.66 |
| BS-16 | Post-Development 5 YR | 5 | 0.912 | 12.150 | 9.19 |
| BS-17 | Post-Development 5 YR | 5 | 0.553 | 12.050 | 7.36 |
| BS-18 | Post-Development 5 YR | 5 | 1.121 | 12.100 | 12.38 |
| BS-19 | Post-Development 5 YR | 5 | 0.312 | 12.050 | 4.62 |
| BS-1A | Post-Development 5 YR | 5 | 0.109 | 12.050 | 1.39 |
| BS-1B | Post-Development 5 YR | 5 | 0.232 | 12.050 | 2.37 |
| BS-2 | Post-Development 5 YR | 5 | 0.258 | 12.000 | 4.20 |
| BS-20 | Post-Development 5 YR | 5 | 2.565 | 12.150 | 24.57 |
| BS-21 | Post-Development 5 YR | 5 | 2.579 | 12.150 | 23.92 |
| BS-22 | Post-Development 5 YR | 5 | 0.762 | 12.050 | 9.63 |
| BS-23 | Post-Development 5 YR | 5 | 1.401 | 12.150 | 13.59 |
| BS-23A | Post-Development 5 YR | 5 | 0.874 | 12.050 | 11.98 |
| BS-24 | Post-Development 5 YR | 5 | 0.285 | 12.050 | 3.25 |
| BS-25 | Post-Development 5 YR | 5 | 0.301 | 12.100 | 2.68 |
| BS-26 | Post-Development 5 YR | 5 | 0.048 | 12.100 | 0.40 |
| BS-27 | Post-Development 5 YR | 5 | 0.727 | 12.100 | 7.95 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|--------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| BS-28 | Post-Development 5 YR | 5 | 1.090 | 12.150 | 9.31 |
| BS-29 | Post-Development 5 YR | 5 | 0.790 | 12.150 | 6.49 |
| BS-2A | Post-Development 5 YR | 5 | 0.109 | 12.000 | 1.77 |
| BS-2B | Post-Development 5 YR | 5 | 0.122 | 12.000 | 2.02 |
| BS-3 | Post-Development 5 YR | 5 | 0.194 | 12.050 | 2.25 |
| BS-30 | Post-Development 5 YR | 5 | 0.209 | 12.050 | 2.43 |
| BS-31 | Post-Development 5 YR | 5 | 0.209 | 12.100 | 1.94 |
| BS-32 | Post-Development 5 YR | 5 | 0.156 | 12.100 | 1.55 |
| BS-33 | Post-Development 5 YR | 5 | 0.271 | 12.050 | 3.18 |
| BS-4 | Post-Development 5 YR | 5 | 0.478 | 12.100 | 5.54 |
| BS-5 | Post-Development 5 YR | 5 | 0.350 | 12.050 | 4.38 |
| BS-6 | Post-Development 5 YR | 5 | 0.163 | 12.000 | 2.76 |
| BS-7 | Post-Development 5 YR | 5 | 0.394 | 12.000 | 6.40 |
| BS-8 | Post-Development 5 YR | 5 | 0.136 | 12.000 | 2.24 |
| BS-9 | Post-Development 5 YR | 5 | 0.204 | 12.000 | 3.31 |
| CC-10 | Post-Development 5 YR | 5 | 2.140 | 12.200 | 14.13 |
| CC-11 | Post-Development 5 YR | 5 | 0.490 | 12.100 | 4.95 |
| CC-12 | Post-Development 5 YR | 5 | 0.380 | 12.100 | 3.88 |
| CC-13A | Post-Development 5 YR | 5 | 0.601 | 12.150 | 5.42 |
| CC-13B | Post-Development 5 YR | 5 | 0.794 | 12.150 | 7.17 |
| CC-13C | Post-Development 5 YR | 5 | 0.309 | 12.100 | 3.38 |
| CC-13D | Post-Development 5 YR | 5 | 0.586 | 12.100 | 6.17 |
| CC-14 | Post-Development 5 YR | 5 | 0.144 | 12.100 | 1.59 |
| CC-15 | Post-Development 5 YR | 5 | 0.399 | 12.100 | 4.27 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------------------------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| CC-16 | Post-Development 5 YR | 5 | 0.507 | 12.150 | 4.64 |
| CC-17 | Post-Development 5 YR | 5 | 0.777 | 12.150 | 6.47 |
| CC-18 | Post-Development 5 YR | 5 | 0.219 | 12.100 | 2.15 |
| CC-19 | Post-Development 5 YR | 5 | 0.115 | 12.100 | 1.21 |
| CC-1A | Post-Development 5 YR | 5 | 0.306 | 12.100 | 3.28 |
| CC-1B | Post-Development 5 YR | 5 | 0.386 | 12.100 | 4.02 |
| CC-20 | Post-Development 5 YR | 5 | 1.225 | 12.100 | 12.89 |
| CC-21 | Post-Development 5 YR | 5 | 0.133 | 12.100 | 1.17 |
| CC-22 | Post-Development 5 YR | 5 | 0.430 | 12.100 | 4.53 |
| CC-23 | Post-Development 5 YR | 5 | 0.173 | 12.150 | 1.48 |
| CC-24 | Post-Development 5 YR | 5 | 1.235 | 12.100 | 12.99 |
| CC-25 | Post-Development 5 YR | 5 | 0.109 | 12.100 | 1.17 |
| CC-26 | Post-Development 5 YR | 5 | 0.521 | 12.100 | 5.31 |
| CC-27 | Post-Development 5 YR | 5 | 0.558 | 12.150 | 4.88 |
| CC-28 | Post-Development 5 YR | 5 | 4.534 | 12.350 | 24.70 |
| CC-2A | Post-Development 5 YR | 5 | 0.343 | 12.100 | 3.76 |
| CC-2B | Post-Development 5 YR | 5 | 0.649 | 12.100 | 7.10 |
| CC-2C | Post-Development 5 YR | 5 | 0.200 | 12.050 | 2.50 |
| CC-3 | Post-Development 5 YR | 5 | 1.375 | 12.250 | 8.79 |
| CC-4A | Post-Development 5 YR | 5 | 4.709 | 12.200 | 38.97 |
| CC-4B | Post-Development 5 YR | 5 | 0.554 | 12.100 | 7.31 |
| CC-4C (Pre-Development) | Post-Development 5 YR | 5 | 0.159 | 12.050 | 1.81 |
| CC-5 | Post-Development 5 YR | 5 | 0.698 | 12.100 | 7.13 |
| CC-6 | Post-Development 5 YR | 5 | 0.867 | 12.100 | 9.12 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|--------------------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| CC-7 | Post-Development 5 YR | 5 | 0.573 | 12.100 | 5.35 |
| CC-8 | Post-Development 5 YR | 5 | 0.240 | 12.100 | 2.53 |
| CC-9 | Post-Development 5 YR | 5 | 0.175 | 12.050 | 2.08 |
| EX-24 | Post-Development 5 YR | 5 | 0.255 | 12.050 | 2.17 |
| EX-DP-3 (Pre-Dev.) | Post-Development 5 YR | 5 | 0.693 | 12.100 | 4.76 |
| OS-10 | Post-Development 5 YR | 5 | 0.154 | 12.050 | 2.13 |
| OS-11 | Post-Development 5 YR | 5 | 0.938 | 12.150 | 8.20 |
| OS-12 | Post-Development 5 YR | 5 | 1.720 | 12.200 | 11.85 |
| OS-13 | Post-Development 5 YR | 5 | 0.961 | 12.150 | 7.35 |
| OS-14 | Post-Development 5 YR | 5 | 0.624 | 12.150 | 4.61 |
| OS-15 | Post-Development 5 YR | 5 | 1.997 | 12.200 | 14.76 |
| OS-16 | Post-Development 5 YR | 5 | 0.140 | 12.100 | 1.50 |
| OS-17 | Post-Development 5 YR | 5 | 0.493 | 12.050 | 5.88 |
| OS-18 | Post-Development 5 YR | 5 | 0.406 | 12.050 | 4.72 |
| OS-1A | Post-Development 5 YR | 5 | 0.137 | 12.050 | 1.60 |
| OS-1B | Post-Development 5 YR | 5 | 0.175 | 12.100 | 1.94 |
| OS-2 | Post-Development 5 YR | 5 | 0.062 | 12.100 | 0.55 |
| OS-3 | Post-Development 5 YR | 5 | 0.318 | 12.050 | 3.80 |
| OS-4 | Post-Development 5 YR | 5 | 1.026 | 12.100 | 11.02 |
| OS-5 | Post-Development 5 YR | 5 | 0.922 | 12.200 | 7.14 |
| OS-6 | Post-Development 5 YR | 5 | 0.287 | 12.100 | 3.18 |
| OS-7 | Post-Development 5 YR | 5 | 0.156 | 12.050 | 1.96 |
| OS-8 | Post-Development 5 YR | 5 | 0.556 | 12.100 | 6.22 |
| OS-9 | Post-Development 5 YR | 5 | 0.188 | 12.200 | 0.99 |

Subsection: Master Network Summary

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| DP-1 | Post-Development 5 YR | 5 | 0.260 | 12.050 | 3.37 |
| DP-10 | Post-Development 5 YR | 5 | 3.247 | 12.100 | 34.85 |
| DP-11 | Post-Development 5 YR | 5 | 0.912 | 12.150 | 9.19 |
| DP-12 | Post-Development 5 YR | 5 | 1.161 | 12.100 | 11.23 |
| DP-13 | Post-Development 5 YR | 5 | 4.192 | 12.600 | 15.02 |
| DP-16 | Post-Development 5 YR | 5 | 8.729 | 12.150 | 78.46 |
| DP-17 | Post-Development 5 YR | 5 | 7.095 | 12.800 | 23.12 |
| DP-18 | Post-Development 5 YR | 5 | 2.495 | 12.100 | 21.62 |
| DP-19 | Post-Development 5 YR | 5 | 3.616 | 12.100 | 16.76 |
| DP-2 | Post-Development 5 YR | 5 | 0.737 | 12.050 | 8.76 |
| DP-20 | Post-Development 5 YR | 5 | 2.026 | 12.150 | 14.26 |
| DP-21 | Post-Development 5 YR | 5 | 1.304 | 12.150 | 10.47 |
| DP-22 | Post-Development 5 YR | 5 | 1.951 | 12.100 | 16.60 |
| DP-23 | Post-Development 5 YR | 5 | 1.999 | 12.200 | 13.04 |
| DP-24 | Post-Development 5 YR | 5 | 0.857 | 12.100 | 8.41 |
| DP-25 | Post-Development 5 YR | 5 | 1.084 | 14.200 | 1.85 |
| DP-26 | Post-Development 5 YR | 5 | 2.380 | 12.200 | 15.93 |
| DP-27 | Post-Development 5 YR | 5 | 1.624 | 12.100 | 17.16 |
| DP-28 | Post-Development 5 YR | 5 | 2.598 | 12.150 | 19.79 |
| DP-29 | Post-Development 5 YR | 5 | 3.678 | 12.200 | 26.59 |
| DP-3 | Post-Development 5 YR | 5 | 1.262 | 12.100 | 5.77 |
| DP-30 | Post-Development 5 YR | 5 | 0.219 | 12.100 | 2.15 |
| DP-31 | Post-Development 5 YR | 5 | 0.334 | 12.150 | 3.22 |
| DP-32 | Post-Development 5 YR | 5 | 0.917 | 12.150 | 7.77 |

Subsection: Master Network Summary

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|-----------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| DP-33 | Post-Development 5 YR | 5 | 1.407 | 12.100 | 14.38 |
| DP-34 | Post-Development 5 YR | 5 | 6.776 | 12.650 | 23.53 |
| DP-4 | Post-Development 5 YR | 5 | 0.258 | 12.000 | 4.20 |
| DP-5 | Post-Development 5 YR | 5 | 0.283 | 12.050 | 3.52 |
| DP-6 | Post-Development 5 YR | 5 | 0.256 | 12.050 | 2.77 |
| DP-7 | Post-Development 5 YR | 5 | 0.668 | 12.050 | 8.18 |
| DP-8 | Post-Development 5 YR | 5 | 12.227 | 12.300 | 70.39 |
| DP-9 | Post-Development 5 YR | 5 | 0.397 | 12.050 | 4.97 |
| J-75 | Post-Development 5 YR | 5 | 5.958 | 12.300 | 32.44 |
| O-100 | Post-Development 5 YR | 5 | 0.490 | 12.100 | 4.95 |
| O-101 | Post-Development 5 YR | 5 | 0.586 | 12.100 | 6.17 |
| O-102 | Post-Development 5 YR | 5 | 0.144 | 12.100 | 1.59 |
| O-108 | Post-Development 5 YR | 5 | 0.563 | 12.100 | 5.70 |
| O-110 | Post-Development 5 YR | 5 | 0.109 | 12.100 | 1.17 |
| O-122 | Post-Development 5 YR | 5 | 0.109 | 12.050 | 1.39 |
| O-125 | Post-Development 5 YR | 5 | 0.380 | 12.100 | 3.88 |
| O-126 | Post-Development 5 YR | 5 | 5.438 | 12.150 | 44.99 |
| O-127 | Post-Development 5 YR | 5 | 0.625 | 12.000 | 10.39 |
| O-129 | Post-Development 5 YR | 5 | 0.922 | 12.200 | 7.14 |
| O-137 | Post-Development 5 YR | 5 | 0.255 | 12.050 | 2.17 |
| O-138 | Post-Development 5 YR | 5 | 0.693 | 12.100 | 4.76 |
| O-73 | Post-Development 5 YR | 5 | 0.285 | 12.050 | 3.25 |
| O-74 | Post-Development 5 YR | 5 | 0.301 | 12.100 | 2.68 |
| O-75 | Post-Development 5 YR | 5 | 0.048 | 12.100 | 0.40 |

Subsection: Master Network Summary

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|-----------------------|----------------------|---------------------------|----------------------|--------------------------------|
| O-80 | Post-Development 5 YR | 5 | 0.209 | 12.100 | 1.94 |
| O-81 | Post-Development 5 YR | 5 | 0.156 | 12.100 | 1.55 |
| O-82 | Post-Development 5 YR | 5 | 0.271 | 12.050 | 3.18 |
| O-86 | Post-Development 5 YR | 5 | 0.386 | 12.100 | 4.02 |
| O-96 | Post-Development 5 YR | 5 | 0.200 | 12.050 | 2.50 |
| O-98 | Post-Development 5 YR | 5 | 0.573 | 12.100 | 5.35 |

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|-----------------------|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| Exist. HFR Pond 16 (IN) | Post-Development 5 YR | 5 | 9.990 | 12.200 | 77.31 | (N/A) | (N/A) |
| Exist. HFR Pond 16 (OUT) | Post-Development 5 YR | 5 | 9.910 | 12.350 | 60.95 | 7,456.98 | 0.761 |
| FH North Pond 1 (IN) | Post-Development 5 YR | 5 | 0.813 | 12.100 | 9.36 | (N/A) | (N/A) |
| FH North Pond 1 (OUT) | Post-Development 5 YR | 5 | 0.774 | 13.700 | 1.01 | 7,392.43 | 0.291 |
| FH North Pond 12 (IN) | Post-Development 5 YR | 5 | 1.723 | 12.100 | 17.34 | (N/A) | (N/A) |
| FH North Pond 12 (OUT) | Post-Development 5 YR | 5 | 1.084 | 14.200 | 1.85 | 7,546.99 | 0.735 |
| FH North Pond 4 (IN) | Post-Development 5 YR | 5 | 5.146 | 12.100 | 52.30 | (N/A) | (N/A) |
| FH North Pond 4 (OUT) | Post-Development 5 YR | 5 | 4.192 | 12.600 | 15.02 | 7,426.09 | 1.431 |
| FH North Pond 8 (IN) | Post-Development 5 YR | 5 | 9.596 | 12.150 | 84.97 | (N/A) | (N/A) |

Subsection: Master Network Summary

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|-----------------------|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| FH North Pond 8 (OUT) | Post-Development 5 YR | 5 | 7.095 | 12.800 | 23.12 | 7,375.32 | 3.044 |
| Golf Course Pond 6 (IN) | Post-Development 5 YR | 5 | 5.144 | 12.150 | 48.48 | (N/A) | (N/A) |
| Golf Course Pond 6 (OUT) | Post-Development 5 YR | 5 | 5.138 | 12.200 | 46.40 | 7,436.24 | 2.611 |
| Golf Course Pond 7 (IN) | Post-Development 5 YR | 5 | 6.211 | 12.150 | 55.75 | (N/A) | (N/A) |
| Golf Course Pond 7 (OUT) | Post-Development 5 YR | 5 | 6.211 | 12.200 | 54.75 | 7,424.29 | 1.551 |

Subsection: Time-Depth Curve
Label: Colo Springs 2015

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Time-Depth Curve: TYPE II 24 HOUR

| | |
|--------------|-----------------|
| Label | TYPE II 24 HOUR |
| Start Time | 0.000 hours |
| Increment | 0.250 hours |
| End Time | 24.000 hours |
| Return Event | 5 years |

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.250 hours

Time on left represents time for first value in each row.

| Time (hours) | Depth (in) | Depth (in) | Depth (in) | Depth (in) | Depth (in) |
|-----------------|---------------|---------------|---------------|---------------|---------------|
| 0.000 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1.250 | 0.0 | 0.0 | 0.1 | 0.1 | 0.1 |
| 2.500 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |
| 3.750 | 0.1 | 0.1 | 0.1 | 0.2 | 0.2 |
| 5.000 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| 6.250 | 0.2 | 0.2 | 0.3 | 0.3 | 0.3 |
| 7.500 | 0.3 | 0.3 | 0.3 | 0.3 | 0.4 |
| 8.750 | 0.4 | 0.4 | 0.4 | 0.4 | 0.5 |
| 10.000 | 0.5 | 0.5 | 0.5 | 0.6 | 0.6 |
| 11.250 | 0.7 | 0.8 | 1.0 | 1.8 | 1.9 |
| 12.500 | 2.0 | 2.0 | 2.1 | 2.1 | 2.2 |
| 13.750 | 2.2 | 2.2 | 2.3 | 2.3 | 2.3 |
| 15.000 | 2.3 | 2.3 | 2.3 | 2.4 | 2.4 |
| 16.250 | 2.4 | 2.4 | 2.4 | 2.4 | 2.5 |
| 17.500 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 |
| 18.750 | 2.5 | 2.5 | 2.5 | 2.6 | 2.6 |
| 20.000 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 |
| 21.250 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 |
| 22.500 | 2.7 | 2.7 | 2.7 | 2.7 | 2.7 |
| 23.750 | 2.7 | 2.7 | (N/A) | (N/A) | (N/A) |

Subsection: Elevation-Area Volume Curve
 Label: FH North Pond 1

Return Event: 5 years
 Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,390.00 | 0.0000 | 0.004 | 0.000 | 0.000 | 0.000 |
| 7,392.00 | 0.0000 | 0.242 | 0.277 | 0.185 | 0.185 |
| 7,394.00 | 0.0000 | 0.311 | 0.827 | 0.552 | 0.736 |
| 7,396.00 | 0.0000 | 0.387 | 1.045 | 0.697 | 1.433 |

Subsection: Elevation-Area Volume Curve
 Label: FH North Pond 12

Return Event: 5 years
 Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,544.50 | 0.0000 | 0.002 | 0.000 | 0.000 | 0.000 |
| 7,546.00 | 0.0000 | 0.462 | 0.494 | 0.247 | 0.247 |
| 7,548.00 | 0.0000 | 0.600 | 1.588 | 1.059 | 1.306 |
| 7,550.00 | 0.0000 | 0.749 | 2.019 | 1.346 | 2.652 |
| 7,552.00 | 0.0000 | 0.905 | 2.477 | 1.652 | 4.304 |

Subsection: Elevation-Area Volume Curve
Label: FH North Pond 4

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,421.50 | 0.0000 | 0.004 | 0.000 | 0.000 | 0.000 |
| 7,422.00 | 0.0000 | 0.004 | 0.012 | 0.002 | 0.002 |
| 7,424.00 | 0.0000 | 0.248 | 0.283 | 0.189 | 0.191 |
| 7,426.00 | 0.0000 | 0.981 | 1.722 | 1.148 | 1.339 |
| 7,428.00 | 0.0000 | 1.226 | 3.304 | 2.202 | 3.542 |
| 7,430.00 | 0.0000 | 1.432 | 3.983 | 2.655 | 6.197 |
| 7,432.00 | 0.0000 | 1.651 | 4.621 | 3.080 | 9.277 |

Subsection: Elevation-Area Volume Curve
Label: FH North Pond 8

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1 + A2 + sq (A1 * A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|--------------------------------------|-------------------|---------------------------|
| 7,369.00 | 0.0000 | 0.009 | 0.000 | 0.000 | 0.000 |
| 7,370.00 | 0.0000 | 0.009 | 0.027 | 0.009 | 0.009 |
| 7,372.00 | 0.0000 | 0.415 | 0.485 | 0.323 | 0.332 |
| 7,374.00 | 0.0000 | 0.918 | 1.950 | 1.300 | 1.633 |
| 7,376.00 | 0.0000 | 1.411 | 3.467 | 2.311 | 3.944 |
| 7,378.00 | 0.0000 | 1.594 | 4.505 | 3.003 | 6.947 |
| 7,380.00 | 0.0000 | 1.788 | 5.070 | 3.380 | 10.327 |
| 7,382.00 | 0.0000 | 2.032 | 5.726 | 3.817 | 14.145 |

Subsection: Composite Rating Curve
Label: FH North Pond 1

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,390.00 | 0.00 | (N/A) | 0.00 |
| 7,390.50 | 0.21 | (N/A) | 0.00 |
| 7,391.00 | 0.42 | (N/A) | 0.00 |
| 7,391.50 | 0.63 | (N/A) | 0.00 |
| 7,392.00 | 0.84 | (N/A) | 0.00 |
| 7,392.50 | 1.05 | (N/A) | 0.00 |
| 7,392.75 | 1.15 | (N/A) | 0.00 |
| 7,393.00 | 2.70 | (N/A) | 0.00 |
| 7,393.50 | 9.09 | (N/A) | 0.00 |
| 7,394.00 | 18.16 | (N/A) | 0.00 |
| 7,394.50 | 29.05 | (N/A) | 0.00 |
| 7,395.00 | 41.22 | (N/A) | 0.00 |
| 7,395.50 | 47.14 | (N/A) | 0.00 |
| 7,396.00 | 48.76 | (N/A) | 0.00 |

Contributing Structures

| |
|---|
| (no Q: Riser - 1,Orifice - 1,Culvert - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Composite Rating Curve
Label: FH North Pond 12

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,544.50 | 0.00 | (N/A) | 0.00 |
| 7,545.00 | 0.09 | (N/A) | 0.00 |
| 7,545.50 | 0.19 | (N/A) | 0.00 |
| 7,546.00 | 0.28 | (N/A) | 0.00 |
| 7,546.50 | 0.37 | (N/A) | 0.00 |
| 7,546.75 | 0.42 | (N/A) | 0.00 |
| 7,547.00 | 1.93 | (N/A) | 0.00 |
| 7,547.50 | 8.19 | (N/A) | 0.00 |
| 7,548.00 | 17.12 | (N/A) | 0.00 |
| 7,548.50 | 27.99 | (N/A) | 0.00 |
| 7,549.00 | 33.62 | (N/A) | 0.00 |
| 7,549.50 | 35.86 | (N/A) | 0.00 |
| 7,550.00 | 37.97 | (N/A) | 0.00 |
| 7,550.50 | 39.96 | (N/A) | 0.00 |
| 7,551.00 | 41.87 | (N/A) | 0.00 |
| 7,551.50 | 43.69 | (N/A) | 0.00 |
| 7,552.00 | 45.43 | (N/A) | 0.00 |

Contributing Structures

| |
|---|
| (no Q: Riser - 1,Orifice - 1,Culvert - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Composite Rating Curve
Label: FH North Pond 4

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,421.50 | 0.00 | (N/A) | 0.00 |
| 7,422.00 | 0.09 | (N/A) | 0.00 |
| 7,422.50 | 0.19 | (N/A) | 0.00 |
| 7,423.00 | 0.29 | (N/A) | 0.00 |
| 7,423.50 | 0.38 | (N/A) | 0.00 |
| 7,424.00 | 0.48 | (N/A) | 0.00 |
| 7,424.50 | 0.57 | (N/A) | 0.00 |
| 7,425.00 | 0.67 | (N/A) | 0.00 |
| 7,425.50 | 0.77 | (N/A) | 0.00 |
| 7,426.00 | 11.42 | (N/A) | 0.00 |
| 7,426.50 | 30.84 | (N/A) | 0.00 |
| 7,427.00 | 55.96 | (N/A) | 0.00 |
| 7,427.50 | 85.67 | (N/A) | 0.00 |
| 7,428.00 | 119.35 | (N/A) | 0.00 |
| 7,428.50 | 156.50 | (N/A) | 0.00 |
| 7,429.00 | 196.62 | (N/A) | 0.00 |
| 7,429.50 | 205.78 | (N/A) | 0.00 |
| 7,430.00 | 211.74 | (N/A) | 0.00 |
| 7,430.50 | 217.53 | (N/A) | 0.00 |
| 7,431.00 | 223.18 | (N/A) | 0.00 |
| 7,431.50 | 228.71 | (N/A) | 0.00 |
| 7,432.00 | 234.08 | (N/A) | 0.00 |

Contributing Structures

(no Q: Riser - 1,Orifice - 1,Culvert - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Culvert - 1 (no Q: Orifice - 1)
Riser - 1,Culvert - 1 (no Q: Orifice - 1)
Riser - 1,Culvert - 1 (no Q: Orifice - 1)
Riser - 1,Culvert - 1 (no Q: Orifice - 1)
Riser - 1,Culvert - 1 (no Q: Orifice - 1)

Subsection: Composite Rating Curve
Label: FH North Pond 4

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Contributing Structures |
|---|
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,369.00 | 0.00 | (N/A) | 0.00 |
| 7,369.25 | 0.00 | (N/A) | 0.00 |
| 7,369.50 | 0.00 | (N/A) | 0.00 |
| 7,370.00 | 0.12 | (N/A) | 0.00 |
| 7,370.50 | 0.23 | (N/A) | 0.00 |
| 7,371.00 | 0.35 | (N/A) | 0.00 |
| 7,371.50 | 0.47 | (N/A) | 0.00 |
| 7,372.00 | 0.58 | (N/A) | 0.00 |
| 7,372.50 | 0.69 | (N/A) | 0.00 |
| 7,373.00 | 0.81 | (N/A) | 0.00 |
| 7,373.50 | 0.92 | (N/A) | 0.00 |
| 7,374.00 | 1.04 | (N/A) | 0.00 |
| 7,374.50 | 1.15 | (N/A) | 0.00 |
| 7,374.75 | 1.21 | (N/A) | 0.00 |
| 7,375.00 | 7.17 | (N/A) | 0.00 |
| 7,375.50 | 32.24 | (N/A) | 0.00 |
| 7,376.00 | 68.01 | (N/A) | 0.00 |
| 7,376.50 | 112.00 | (N/A) | 0.00 |
| 7,377.00 | 162.75 | (N/A) | 0.00 |
| 7,377.50 | 219.40 | (N/A) | 0.00 |
| 7,378.00 | 254.44 | (N/A) | 0.00 |
| 7,378.50 | 266.12 | (N/A) | 0.00 |
| 7,379.00 | 277.33 | (N/A) | 0.00 |
| 7,379.50 | 288.06 | (N/A) | 0.00 |
| 7,380.00 | 298.45 | (N/A) | 0.00 |
| 7,380.50 | 308.47 | (N/A) | 0.00 |
| 7,381.00 | 318.15 | (N/A) | 0.00 |
| 7,381.50 | 327.59 | (N/A) | 0.00 |
| 7,382.00 | 336.74 | (N/A) | 0.00 |

Contributing Structures

(no Q: Riser - 1,Orifice - 1,Culvert - 1)
 (no Q: Riser - 1,Orifice - 1,Culvert - 1)
 (no Q: Riser - 1,Orifice - 1,Culvert - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Contributing Structures |
|--|
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 1

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,390.00 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,390.00 | 0.00 | 0.000 | 0.004 | 0.00 | 0.00 | 0.00 |
| 7,390.50 | 0.21 | 0.007 | 0.029 | 0.00 | 0.21 | 3.74 |
| 7,391.00 | 0.42 | 0.033 | 0.077 | 0.00 | 0.42 | 16.33 |
| 7,391.50 | 0.63 | 0.088 | 0.148 | 0.00 | 0.63 | 43.31 |
| 7,392.00 | 0.84 | 0.185 | 0.242 | 0.00 | 0.84 | 90.25 |
| 7,392.50 | 1.05 | 0.310 | 0.258 | 0.00 | 1.05 | 151.00 |
| 7,392.75 | 1.15 | 0.375 | 0.267 | 0.00 | 1.15 | 182.89 |
| 7,393.00 | 2.70 | 0.443 | 0.275 | 0.00 | 2.70 | 217.24 |
| 7,393.50 | 9.09 | 0.585 | 0.293 | 0.00 | 9.09 | 292.39 |
| 7,394.00 | 18.16 | 0.736 | 0.311 | 0.00 | 18.16 | 374.53 |
| 7,394.50 | 29.05 | 0.896 | 0.329 | 0.00 | 29.05 | 462.88 |
| 7,395.00 | 41.22 | 1.066 | 0.348 | 0.00 | 41.22 | 556.98 |
| 7,395.50 | 47.14 | 1.244 | 0.367 | 0.00 | 47.14 | 649.42 |
| 7,396.00 | 48.76 | 1.433 | 0.387 | 0.00 | 48.76 | 742.29 |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 12

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,544.50 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,544.50 | 0.00 | 0.000 | 0.002 | 0.00 | 0.00 | 0.00 |
| 7,545.00 | 0.09 | 0.013 | 0.066 | 0.00 | 0.09 | 6.48 |
| 7,545.50 | 0.19 | 0.081 | 0.219 | 0.00 | 0.19 | 39.23 |
| 7,546.00 | 0.28 | 0.247 | 0.462 | 0.00 | 0.28 | 119.92 |
| 7,546.50 | 0.37 | 0.486 | 0.495 | 0.00 | 0.37 | 235.77 |
| 7,546.75 | 0.42 | 0.612 | 0.512 | 0.00 | 0.42 | 296.70 |
| 7,547.00 | 1.93 | 0.742 | 0.529 | 0.00 | 1.93 | 361.15 |
| 7,547.50 | 8.19 | 1.015 | 0.564 | 0.00 | 8.19 | 499.59 |
| 7,548.00 | 17.12 | 1.306 | 0.600 | 0.00 | 17.12 | 649.32 |
| 7,548.50 | 27.99 | 1.615 | 0.636 | 0.00 | 27.99 | 809.69 |
| 7,549.00 | 33.62 | 1.942 | 0.672 | 0.00 | 33.62 | 973.58 |
| 7,549.50 | 35.86 | 2.288 | 0.710 | 0.00 | 35.86 | 1,143.10 |
| 7,550.00 | 37.97 | 2.652 | 0.749 | 0.00 | 37.97 | 1,321.75 |
| 7,550.50 | 39.96 | 3.036 | 0.787 | 0.00 | 39.96 | 1,509.54 |
| 7,551.00 | 41.87 | 3.439 | 0.825 | 0.00 | 41.87 | 1,706.45 |
| 7,551.50 | 43.69 | 3.862 | 0.865 | 0.00 | 43.69 | 1,912.72 |
| 7,552.00 | 45.43 | 4.304 | 0.905 | 0.00 | 45.43 | 2,128.56 |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 4

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,421.50 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,421.50 | 0.00 | 0.000 | 0.004 | 0.00 | 0.00 | 0.00 |
| 7,422.00 | 0.09 | 0.002 | 0.004 | 0.00 | 0.09 | 1.06 |
| 7,422.50 | 0.19 | 0.009 | 0.030 | 0.00 | 0.19 | 4.74 |
| 7,423.00 | 0.29 | 0.035 | 0.079 | 0.00 | 0.29 | 17.47 |
| 7,423.50 | 0.38 | 0.092 | 0.152 | 0.00 | 0.38 | 44.96 |
| 7,424.00 | 0.48 | 0.191 | 0.248 | 0.00 | 0.48 | 92.92 |
| 7,424.50 | 0.57 | 0.348 | 0.386 | 0.00 | 0.57 | 169.09 |
| 7,425.00 | 0.67 | 0.582 | 0.554 | 0.00 | 0.67 | 282.28 |
| 7,425.50 | 0.77 | 0.907 | 0.752 | 0.00 | 0.77 | 439.80 |
| 7,426.00 | 11.42 | 1.339 | 0.981 | 0.00 | 11.42 | 659.57 |
| 7,426.50 | 30.84 | 1.844 | 1.040 | 0.00 | 30.84 | 923.46 |
| 7,427.00 | 55.96 | 2.379 | 1.100 | 0.00 | 55.96 | 1,207.47 |
| 7,427.50 | 85.67 | 2.945 | 1.162 | 0.00 | 85.67 | 1,510.87 |
| 7,428.00 | 119.35 | 3.542 | 1.226 | 0.00 | 119.35 | 1,833.49 |
| 7,428.50 | 156.50 | 4.167 | 1.276 | 0.00 | 156.50 | 2,173.36 |
| 7,429.00 | 196.62 | 4.818 | 1.327 | 0.00 | 196.62 | 2,528.43 |
| 7,429.50 | 205.78 | 5.494 | 1.379 | 0.00 | 205.78 | 2,864.99 |
| 7,430.00 | 211.74 | 6.197 | 1.432 | 0.00 | 211.74 | 3,211.06 |
| 7,430.50 | 217.53 | 6.926 | 1.485 | 0.00 | 217.53 | 3,569.83 |
| 7,431.00 | 223.18 | 7.682 | 1.540 | 0.00 | 223.18 | 3,941.46 |
| 7,431.50 | 228.71 | 8.466 | 1.595 | 0.00 | 228.71 | 4,326.23 |
| 7,432.00 | 234.08 | 9.277 | 1.651 | 0.00 | 234.08 | 4,724.32 |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 8

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,369.00 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,369.00 | 0.00 | 0.000 | 0.009 | 0.00 | 0.00 | 0.00 |
| 7,369.25 | 0.00 | 0.002 | 0.009 | 0.00 | 0.00 | 1.09 |
| 7,369.50 | 0.00 | 0.004 | 0.009 | 0.00 | 0.00 | 2.18 |
| 7,370.00 | 0.12 | 0.009 | 0.009 | 0.00 | 0.12 | 4.47 |
| 7,370.50 | 0.23 | 0.023 | 0.054 | 0.00 | 0.23 | 11.44 |
| 7,371.00 | 0.35 | 0.069 | 0.137 | 0.00 | 0.35 | 33.85 |
| 7,371.50 | 0.47 | 0.166 | 0.257 | 0.00 | 0.47 | 80.81 |
| 7,372.00 | 0.58 | 0.332 | 0.415 | 0.00 | 0.58 | 161.47 |
| 7,372.50 | 0.69 | 0.566 | 0.522 | 0.00 | 0.69 | 274.74 |
| 7,373.00 | 0.81 | 0.857 | 0.642 | 0.00 | 0.81 | 415.47 |
| 7,373.50 | 0.92 | 1.210 | 0.774 | 0.00 | 0.92 | 586.62 |
| 7,374.00 | 1.04 | 1.633 | 0.918 | 0.00 | 1.04 | 791.20 |
| 7,374.50 | 1.15 | 2.120 | 1.031 | 0.00 | 1.15 | 1,027.05 |
| 7,374.75 | 1.21 | 2.385 | 1.091 | 0.00 | 1.21 | 1,155.47 |
| 7,375.00 | 7.17 | 2.665 | 1.151 | 0.00 | 7.17 | 1,297.03 |
| 7,375.50 | 32.24 | 3.272 | 1.278 | 0.00 | 32.24 | 1,615.90 |
| 7,376.00 | 68.01 | 3.944 | 1.411 | 0.00 | 68.01 | 1,976.89 |
| 7,376.50 | 112.00 | 4.661 | 1.456 | 0.00 | 112.00 | 2,367.74 |
| 7,377.00 | 162.75 | 5.400 | 1.501 | 0.00 | 162.75 | 2,776.25 |
| 7,377.50 | 219.40 | 6.162 | 1.547 | 0.00 | 219.40 | 3,201.72 |
| 7,378.00 | 254.44 | 6.947 | 1.594 | 0.00 | 254.44 | 3,616.84 |
| 7,378.50 | 266.12 | 7.756 | 1.641 | 0.00 | 266.12 | 4,020.00 |
| 7,379.00 | 277.33 | 8.589 | 1.690 | 0.00 | 277.33 | 4,434.25 |
| 7,379.50 | 288.06 | 9.446 | 1.738 | 0.00 | 288.06 | 4,859.76 |
| 7,380.00 | 298.45 | 10.327 | 1.788 | 0.00 | 298.45 | 5,296.84 |
| 7,380.50 | 308.47 | 11.236 | 1.848 | 0.00 | 308.47 | 5,746.74 |
| 7,381.00 | 318.15 | 12.175 | 1.908 | 0.00 | 318.15 | 6,210.82 |
| 7,381.50 | 327.59 | 13.144 | 1.970 | 0.00 | 327.59 | 6,689.43 |
| 7,382.00 | 336.74 | 14.145 | 2.032 | 0.00 | 336.74 | 7,182.75 |

Index

C

Colo Springs 2015 (Time-Depth Curve, 5 years)...10

F

FH North Pond 1 (Composite Rating Curve, 5 years)...15

FH North Pond 1 (Elevation-Area Volume Curve, 5 years)...11

FH North Pond 1 (Elevation-Volume-Flow Table (Pond), 5 years)...21

FH North Pond 12 (Composite Rating Curve, 5 years)...16

FH North Pond 12 (Elevation-Area Volume Curve, 5 years)...12

FH North Pond 12 (Elevation-Volume-Flow Table (Pond), 5 years)...22

FH North Pond 4 (Composite Rating Curve, 5 years)...17, 18

FH North Pond 4 (Elevation-Area Volume Curve, 5 years)...13

FH North Pond 4 (Elevation-Volume-Flow Table (Pond), 5 years)...23

FH North Pond 8 (Composite Rating Curve, 5 years)...19, 20

FH North Pond 8 (Elevation-Area Volume Curve, 5 years)...14

FH North Pond 8 (Elevation-Volume-Flow Table (Pond), 5 years)...24

M

Master Network Summary...2, 3, 4, 5, 6, 7, 8, 9

| Project Summary | |
|-----------------|-----------------------------------|
| Title | Flying Horse North Filing No.1 |
| Engineer | MAW |
| Company | CCES |
| Date | 4/4/2018 |

| | |
|-------|----------|
| Notes | 100 Year |
|-------|----------|

Table of Contents

| | | |
|-------------------|---|----|
| | Master Network Summary | 2 |
| Colo Springs 2015 | Time-Depth Curve, 100 years | 10 |
| FH North Pond 1 | | |
| | Elevation-Area Volume Curve, 100 years | 11 |
| FH North Pond 12 | | |
| | Elevation-Area Volume Curve, 100 years | 12 |
| FH North Pond 4 | | |
| | Elevation-Area Volume Curve, 100 years | 13 |
| FH North Pond 8 | | |
| | Elevation-Area Volume Curve, 100 years | 14 |
| FH North Pond 1 | | |
| | Composite Rating Curve, 100 years | 15 |
| FH North Pond 12 | | |
| | Composite Rating Curve, 100 years | 16 |
| FH North Pond 4 | | |
| | Composite Rating Curve, 100 years | 17 |
| FH North Pond 8 | | |
| | Composite Rating Curve, 100 years | 19 |
| FH North Pond 1 | | |
| | Elevation-Volume-Flow Table (Pond), 100 years | 21 |
| FH North Pond 12 | | |
| | Elevation-Volume-Flow Table (Pond), 100 years | 22 |
| FH North Pond 4 | | |
| | Elevation-Volume-Flow Table (Pond), 100 years | 23 |
| FH North Pond 8 | | |
| | Elevation-Volume-Flow Table (Pond), 100 years | 24 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|---------------------|----------------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| Area to HFR Pond 16 | Post-Development 100 YR | 100 | 37.106 | 12.150 | 400.62 |
| Area to Pond 1 | Post-Development 100 YR | 100 | 2.793 | 12.050 | 38.16 |
| BS-10 | Post-Development 100 YR | 100 | 1.269 | 12.050 | 17.46 |
| BS-11 | Post-Development 100 YR | 100 | 0.254 | 12.000 | 4.09 |
| BS-12 | Post-Development 100 YR | 100 | 0.892 | 12.050 | 13.83 |
| BS-13 | Post-Development 100 YR | 100 | 3.477 | 12.050 | 49.97 |
| BS-14 | Post-Development 100 YR | 100 | 1.807 | 12.050 | 25.95 |
| BS-15 | Post-Development 100 YR | 100 | 0.781 | 12.050 | 12.22 |
| BS-16 | Post-Development 100 YR | 100 | 2.975 | 12.100 | 35.70 |
| BS-17 | Post-Development 100 YR | 100 | 1.747 | 12.050 | 25.96 |
| BS-18 | Post-Development 100 YR | 100 | 4.050 | 12.050 | 56.04 |
| BS-19 | Post-Development 100 YR | 100 | 0.955 | 12.050 | 14.95 |
| BS-1A | Post-Development 100 YR | 100 | 0.405 | 12.050 | 6.29 |
| BS-1B | Post-Development 100 YR | 100 | 0.933 | 12.050 | 13.83 |
| BS-2 | Post-Development 100 YR | 100 | 0.536 | 12.000 | 8.36 |
| BS-20 | Post-Development 100 YR | 100 | 9.086 | 12.100 | 112.39 |
| BS-21 | Post-Development 100 YR | 100 | 8.877 | 12.100 | 103.01 |
| BS-22 | Post-Development 100 YR | 100 | 2.489 | 12.050 | 36.51 |
| BS-23 | Post-Development 100 YR | 100 | 4.789 | 12.100 | 58.24 |
| BS-23A | Post-Development 100 YR | 100 | 2.590 | 12.050 | 38.30 |
| BS-24 | Post-Development 100 YR | 100 | 1.143 | 12.050 | 17.59 |
| BS-25 | Post-Development 100 YR | 100 | 1.263 | 12.050 | 17.27 |
| BS-26 | Post-Development 100 YR | 100 | 0.223 | 12.050 | 3.35 |
| BS-27 | Post-Development 100 YR | 100 | 2.696 | 12.050 | 38.80 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|--------|----------------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| BS-28 | Post-Development 100 YR | 100 | 4.139 | 12.100 | 49.40 |
| BS-29 | Post-Development 100 YR | 100 | 3.050 | 12.100 | 35.94 |
| BS-2A | Post-Development 100 YR | 100 | 0.226 | 12.000 | 3.52 |
| BS-2B | Post-Development 100 YR | 100 | 0.254 | 12.000 | 4.00 |
| BS-3 | Post-Development 100 YR | 100 | 0.718 | 12.050 | 10.78 |
| BS-30 | Post-Development 100 YR | 100 | 0.776 | 12.050 | 11.65 |
| BS-31 | Post-Development 100 YR | 100 | 0.858 | 12.050 | 11.80 |
| BS-32 | Post-Development 100 YR | 100 | 0.637 | 12.050 | 9.41 |
| BS-33 | Post-Development 100 YR | 100 | 1.016 | 12.050 | 15.33 |
| BS-4 | Post-Development 100 YR | 100 | 1.652 | 12.050 | 23.58 |
| BS-5 | Post-Development 100 YR | 100 | 1.298 | 12.050 | 20.12 |
| BS-6 | Post-Development 100 YR | 100 | 0.339 | 12.000 | 5.44 |
| BS-7 | Post-Development 100 YR | 100 | 0.818 | 12.000 | 12.76 |
| BS-8 | Post-Development 100 YR | 100 | 0.282 | 12.000 | 4.45 |
| BS-9 | Post-Development 100 YR | 100 | 0.423 | 12.000 | 6.60 |
| CC-10 | Post-Development 100 YR | 100 | 8.756 | 12.150 | 91.86 |
| CC-11 | Post-Development 100 YR | 100 | 1.960 | 12.050 | 28.14 |
| CC-12 | Post-Development 100 YR | 100 | 1.411 | 12.100 | 18.67 |
| CC-13A | Post-Development 100 YR | 100 | 2.230 | 12.100 | 27.30 |
| CC-13B | Post-Development 100 YR | 100 | 2.947 | 12.100 | 36.07 |
| CC-13C | Post-Development 100 YR | 100 | 1.146 | 12.050 | 16.49 |
| CC-13D | Post-Development 100 YR | 100 | 2.175 | 12.050 | 29.20 |
| CC-14 | Post-Development 100 YR | 100 | 0.532 | 12.050 | 7.76 |
| CC-15 | Post-Development 100 YR | 100 | 1.481 | 12.050 | 20.37 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-----------------------------|----------------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| CC-16 | Post-Development 100 YR | 100 | 1.884 | 12.100 | 23.58 |
| CC-17 | Post-Development 100 YR | 100 | 2.885 | 12.100 | 32.77 |
| CC-18 | Post-Development 100 YR | 100 | 0.769 | 12.100 | 9.73 |
| CC-19 | Post-Development 100 YR | 100 | 0.428 | 12.050 | 5.75 |
| CC-1A | Post-Development 100 YR | 100 | 1.134 | 12.050 | 15.97 |
| CC-1B | Post-Development 100 YR | 100 | 1.444 | 12.050 | 19.35 |
| CC-20 | Post-Development 100 YR | 100 | 4.547 | 12.050 | 61.04 |
| CC-21 | Post-Development 100 YR | 100 | 0.585 | 12.050 | 8.51 |
| CC-22 | Post-Development 100 YR | 100 | 1.597 | 12.050 | 21.44 |
| CC-23 | Post-Development 100 YR | 100 | 0.650 | 12.100 | 7.71 |
| CC-24 | Post-Development 100 YR | 100 | 4.581 | 12.050 | 61.51 |
| CC-25 | Post-Development 100 YR | 100 | 0.405 | 12.050 | 5.70 |
| CC-26 | Post-Development 100 YR | 100 | 1.932 | 12.100 | 25.56 |
| CC-27 | Post-Development 100 YR | 100 | 2.121 | 12.100 | 25.82 |
| CC-28 | Post-Development 100 YR | 100 | 17.270 | 12.300 | 136.30 |
| CC-2A | Post-Development 100 YR | 100 | 1.273 | 12.050 | 18.32 |
| CC-2B | Post-Development 100 YR | 100 | 2.407 | 12.050 | 34.64 |
| CC-2C | Post-Development 100 YR | 100 | 0.742 | 12.050 | 11.50 |
| CC-3 | Post-Development 100 YR | 100 | 5.511 | 12.150 | 54.50 |
| CC-4A | Post-Development 100 YR | 100 | 15.367 | 12.150 | 155.93 |
| CC-4B | Post-Development 100 YR | 100 | 1.493 | 12.050 | 20.60 |
| CC-4C (Pre- Development) | Post-Development 100 YR | 100 | 0.699 | 12.000 | 11.16 |
| CC-5 | Post-Development 100 YR | 100 | 2.591 | 12.100 | 34.28 |
| CC-6 | Post-Development 100 YR | 100 | 3.216 | 12.050 | 43.18 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|--------------------|----------------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| CC-7 | Post-Development 100 YR | 100 | 2.127 | 12.100 | 27.04 |
| CC-8 | Post-Development 100 YR | 100 | 0.891 | 12.050 | 11.96 |
| CC-9 | Post-Development 100 YR | 100 | 0.648 | 12.050 | 9.80 |
| EX-24 | Post-Development 100 YR | 100 | 1.178 | 12.050 | 17.75 |
| EX-DP-3 (Pre-Dev.) | Post-Development 100 YR | 100 | 3.210 | 12.100 | 41.28 |
| OS-10 | Post-Development 100 YR | 100 | 0.528 | 12.050 | 8.23 |
| OS-11 | Post-Development 100 YR | 100 | 3.372 | 12.100 | 38.66 |
| OS-12 | Post-Development 100 YR | 100 | 7.008 | 12.150 | 75.81 |
| OS-13 | Post-Development 100 YR | 100 | 3.863 | 12.100 | 44.96 |
| OS-14 | Post-Development 100 YR | 100 | 2.622 | 12.100 | 31.03 |
| OS-15 | Post-Development 100 YR | 100 | 7.742 | 12.150 | 84.16 |
| OS-16 | Post-Development 100 YR | 100 | 0.521 | 12.050 | 7.16 |
| OS-17 | Post-Development 100 YR | 100 | 1.829 | 12.050 | 27.65 |
| OS-18 | Post-Development 100 YR | 100 | 1.506 | 12.050 | 22.60 |
| OS-1A | Post-Development 100 YR | 100 | 0.510 | 12.050 | 7.65 |
| OS-1B | Post-Development 100 YR | 100 | 0.648 | 12.050 | 9.44 |
| OS-2 | Post-Development 100 YR | 100 | 0.274 | 12.050 | 3.98 |
| OS-3 | Post-Development 100 YR | 100 | 1.181 | 12.050 | 17.85 |
| OS-4 | Post-Development 100 YR | 100 | 3.807 | 12.050 | 53.61 |
| OS-5 | Post-Development 100 YR | 100 | 3.426 | 12.150 | 36.99 |
| OS-6 | Post-Development 100 YR | 100 | 1.065 | 12.050 | 15.51 |
| OS-7 | Post-Development 100 YR | 100 | 0.579 | 12.050 | 8.98 |
| OS-8 | Post-Development 100 YR | 100 | 1.872 | 12.100 | 24.73 |
| OS-9 | Post-Development 100 YR | 100 | 0.871 | 12.150 | 9.05 |

Subsection: Master Network Summary

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|----------------------------|----------------------------|---------------------------------|-------------------------|-----------------------------------|
| DP-1 | Post-Development 100 YR | 100 | 0.764 | 12.050 | 11.13 |
| DP-10 | Post-Development 100 YR | 100 | 11.054 | 12.050 | 143.30 |
| DP-11 | Post-Development 100 YR | 100 | 2.975 | 12.100 | 35.70 |
| DP-12 | Post-Development 100 YR | 100 | 3.754 | 12.100 | 44.11 |
| DP-13 | Post-Development 100 YR | 100 | 16.350 | 12.250 | 139.15 |
| DP-16 | Post-Development 100 YR | 100 | 30.220 | 12.100 | 361.52 |
| DP-17 | Post-Development 100 YR | 100 | 30.083 | 12.300 | 255.78 |
| DP-18 | Post-Development 100 YR | 100 | 9.471 | 12.100 | 115.49 |
| DP-19 | Post-Development 100 YR | 100 | 13.817 | 12.100 | 125.58 |
| DP-2 | Post-Development 100 YR | 100 | 2.416 | 12.050 | 34.63 |
| DP-20 | Post-Development 100 YR | 100 | 8.142 | 12.100 | 88.44 |
| DP-21 | Post-Development 100 YR | 100 | 5.136 | 12.100 | 61.96 |
| DP-22 | Post-Development 100 YR | 100 | 7.540 | 12.100 | 92.42 |
| DP-23 | Post-Development 100 YR | 100 | 8.133 | 12.150 | 84.40 |
| DP-24 | Post-Development 100 YR | 100 | 3.290 | 12.050 | 44.82 |
| DP-25 | Post-Development 100 YR | 100 | 5.764 | 12.300 | 32.88 |
| DP-26 | Post-Development 100 YR | 100 | 9.647 | 12.150 | 101.89 |
| DP-27 | Post-Development 100 YR | 100 | 6.028 | 12.050 | 81.42 |
| DP-28 | Post-Development 100 YR | 100 | 9.972 | 12.150 | 110.17 |
| DP-29 | Post-Development 100 YR | 100 | 14.023 | 12.150 | 154.97 |
| DP-3 | Post-Development 100 YR | 100 | 4.441 | 12.100 | 38.98 |
| DP-30 | Post-Development 100 YR | 100 | 0.769 | 12.100 | 9.73 |
| DP-31 | Post-Development 100 YR | 100 | 1.197 | 12.100 | 15.22 |
| DP-32 | Post-Development 100 YR | 100 | 3.406 | 12.100 | 39.76 |

Subsection: Master Network Summary

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|----------------------------|-------------------------|---------------------------------|-------------------------|-----------------------------------|
| DP-33 | Post-Development 100 YR | 100 | 5.231 | 12.100 | 69.08 |
| DP-34 | Post-Development 100 YR | 100 | 26.136 | 12.400 | 167.92 |
| DP-4 | Post-Development 100 YR | 100 | 0.536 | 12.000 | 8.36 |
| DP-5 | Post-Development 100 YR | 100 | 0.874 | 12.050 | 12.59 |
| DP-6 | Post-Development 100 YR | 100 | 0.992 | 12.050 | 14.76 |
| DP-7 | Post-Development 100 YR | 100 | 2.479 | 12.050 | 37.97 |
| DP-8 | Post-Development 100 YR | 100 | 43.909 | 12.350 | 284.14 |
| DP-9 | Post-Development 100 YR | 100 | 1.472 | 12.050 | 22.81 |
| J-75 | Post-Development 100 YR | 100 | 22.558 | 12.250 | 180.87 |
| O-100 | Post-Development 100 YR | 100 | 1.960 | 12.050 | 28.14 |
| O-101 | Post-Development 100 YR | 100 | 2.175 | 12.050 | 29.20 |
| O-102 | Post-Development 100 YR | 100 | 0.532 | 12.050 | 7.76 |
| O-108 | Post-Development 100 YR | 100 | 2.182 | 12.050 | 29.95 |
| O-110 | Post-Development 100 YR | 100 | 0.405 | 12.050 | 5.70 |
| O-122 | Post-Development 100 YR | 100 | 0.405 | 12.050 | 6.29 |
| O-125 | Post-Development 100 YR | 100 | 1.411 | 12.100 | 18.67 |
| O-126 | Post-Development 100 YR | 100 | 17.508 | 12.150 | 178.97 |
| O-127 | Post-Development 100 YR | 100 | 1.298 | 12.000 | 20.57 |
| O-129 | Post-Development 100 YR | 100 | 3.426 | 12.150 | 36.99 |
| O-137 | Post-Development 100 YR | 100 | 1.178 | 12.050 | 17.75 |
| O-138 | Post-Development 100 YR | 100 | 3.210 | 12.100 | 41.28 |
| O-73 | Post-Development 100 YR | 100 | 1.143 | 12.050 | 17.59 |
| O-74 | Post-Development 100 YR | 100 | 1.263 | 12.050 | 17.27 |
| O-75 | Post-Development 100 YR | 100 | 0.223 | 12.050 | 3.35 |

Subsection: Master Network Summary

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|-------------------------|----------------------|---------------------------|----------------------|--------------------------------|
| O-80 | Post-Development 100 YR | 100 | 0.858 | 12.050 | 11.80 |
| O-81 | Post-Development 100 YR | 100 | 0.637 | 12.050 | 9.41 |
| O-82 | Post-Development 100 YR | 100 | 1.016 | 12.050 | 15.33 |
| O-86 | Post-Development 100 YR | 100 | 1.444 | 12.050 | 19.35 |
| O-96 | Post-Development 100 YR | 100 | 0.742 | 12.050 | 11.50 |
| O-98 | Post-Development 100 YR | 100 | 2.127 | 12.100 | 27.04 |

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|-------------------------|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| Exist. HFR Pond 16 (IN) | Post-Development 100 YR | 100 | 37.106 | 12.150 | 400.62 | (N/A) | (N/A) |
| Exist. HFR Pond 16 (OUT) | Post-Development 100 YR | 100 | 36.950 | 12.350 | 258.25 | 7,462.42 | 6.804 |
| FH North Pond 1 (IN) | Post-Development 100 YR | 100 | 2.793 | 12.050 | 38.16 | (N/A) | (N/A) |
| FH North Pond 1 (OUT) | Post-Development 100 YR | 100 | 2.517 | 12.250 | 20.41 | 7,394.10 | 0.769 |
| FH North Pond 12 (IN) | Post-Development 100 YR | 100 | 6.505 | 12.100 | 86.17 | (N/A) | (N/A) |
| FH North Pond 12 (OUT) | Post-Development 100 YR | 100 | 5.764 | 12.300 | 32.88 | 7,548.93 | 1.898 |
| FH North Pond 4 (IN) | Post-Development 100 YR | 100 | 17.420 | 12.100 | 217.23 | (N/A) | (N/A) |
| FH North Pond 4 (OUT) | Post-Development 100 YR | 100 | 16.350 | 12.250 | 139.15 | 7,428.27 | 3.872 |
| FH North Pond 8 (IN) | Post-Development 100 YR | 100 | 32.794 | 12.150 | 383.43 | (N/A) | (N/A) |

Subsection: Master Network Summary

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|-------------------------|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| FH North Pond 8 (OUT) | Post-Development 100 YR | 100 | 30.083 | 12.300 | 255.78 | 7,378.06 | 7.039 |
| Golf Course Pond 6 (IN) | Post-Development 100 YR | 100 | 17.962 | 12.100 | 215.40 | (N/A) | (N/A) |
| Golf Course Pond 6 (OUT) | Post-Development 100 YR | 100 | 17.947 | 12.150 | 212.28 | 7,436.83 | 3.002 |
| Golf Course Pond 7 (IN) | Post-Development 100 YR | 100 | 21.391 | 12.100 | 253.17 | (N/A) | (N/A) |
| Golf Course Pond 7 (OUT) | Post-Development 100 YR | 100 | 21.391 | 12.150 | 250.27 | 7,424.94 | 1.819 |

Subsection: Time-Depth Curve
Label: Colo Springs 2015

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Time-Depth Curve: TYPE II 24 HOUR

| | |
|--------------|-----------------|
| Label | TYPE II 24 HOUR |
| Start Time | 0.000 hours |
| Increment | 0.250 hours |
| End Time | 24.000 hours |
| Return Event | 100 years |

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.250 hours

Time on left represents time for first value in each row.

| Time (hours) | Depth (in) | Depth (in) | Depth (in) | Depth (in) | Depth (in) |
|-----------------|---------------|---------------|---------------|---------------|---------------|
| 0.000 | 0.0 | 0.0 | 0.0 | 0.0 | 0.1 |
| 1.250 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |
| 2.500 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 |
| 3.750 | 0.2 | 0.2 | 0.2 | 0.3 | 0.3 |
| 5.000 | 0.3 | 0.3 | 0.3 | 0.3 | 0.4 |
| 6.250 | 0.4 | 0.4 | 0.4 | 0.5 | 0.5 |
| 7.500 | 0.5 | 0.5 | 0.6 | 0.6 | 0.6 |
| 8.750 | 0.6 | 0.7 | 0.7 | 0.7 | 0.8 |
| 10.000 | 0.8 | 0.9 | 0.9 | 1.0 | 1.1 |
| 11.250 | 1.2 | 1.3 | 1.8 | 3.0 | 3.3 |
| 12.500 | 3.4 | 3.5 | 3.6 | 3.6 | 3.7 |
| 13.750 | 3.7 | 3.8 | 3.8 | 3.9 | 3.9 |
| 15.000 | 3.9 | 4.0 | 4.0 | 4.0 | 4.1 |
| 16.250 | 4.1 | 4.1 | 4.1 | 4.2 | 4.2 |
| 17.500 | 4.2 | 4.2 | 4.2 | 4.3 | 4.3 |
| 18.750 | 4.3 | 4.3 | 4.3 | 4.4 | 4.4 |
| 20.000 | 4.4 | 4.4 | 4.4 | 4.4 | 4.4 |
| 21.250 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 |
| 22.500 | 4.5 | 4.5 | 4.5 | 4.6 | 4.6 |
| 23.750 | 4.6 | 4.6 | (N/A) | (N/A) | (N/A) |

Subsection: Elevation-Area Volume Curve
 Label: FH North Pond 1

Return Event: 100 years
 Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,390.00 | 0.0000 | 0.004 | 0.000 | 0.000 | 0.000 |
| 7,392.00 | 0.0000 | 0.242 | 0.277 | 0.185 | 0.185 |
| 7,394.00 | 0.0000 | 0.311 | 0.827 | 0.552 | 0.736 |
| 7,396.00 | 0.0000 | 0.387 | 1.045 | 0.697 | 1.433 |

Subsection: Elevation-Area Volume Curve
 Label: FH North Pond 12

Return Event: 100 years
 Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1 + A2 + sq (A1 * A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|--------------------------------------|-------------------|---------------------------|
| 7,544.50 | 0.0000 | 0.002 | 0.000 | 0.000 | 0.000 |
| 7,546.00 | 0.0000 | 0.462 | 0.494 | 0.247 | 0.247 |
| 7,548.00 | 0.0000 | 0.600 | 1.588 | 1.059 | 1.306 |
| 7,550.00 | 0.0000 | 0.749 | 2.019 | 1.346 | 2.652 |
| 7,552.00 | 0.0000 | 0.905 | 2.477 | 1.652 | 4.304 |

Subsection: Elevation-Area Volume Curve
 Label: FH North Pond 4

Return Event: 100 years
 Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,421.50 | 0.0000 | 0.004 | 0.000 | 0.000 | 0.000 |
| 7,422.00 | 0.0000 | 0.004 | 0.012 | 0.002 | 0.002 |
| 7,424.00 | 0.0000 | 0.248 | 0.283 | 0.189 | 0.191 |
| 7,426.00 | 0.0000 | 0.981 | 1.722 | 1.148 | 1.339 |
| 7,428.00 | 0.0000 | 1.226 | 3.304 | 2.202 | 3.542 |
| 7,430.00 | 0.0000 | 1.432 | 3.983 | 2.655 | 6.197 |
| 7,432.00 | 0.0000 | 1.651 | 4.621 | 3.080 | 9.277 |

Subsection: Elevation-Area Volume Curve
Label: FH North Pond 8

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,369.00 | 0.0000 | 0.009 | 0.000 | 0.000 | 0.000 |
| 7,370.00 | 0.0000 | 0.009 | 0.027 | 0.009 | 0.009 |
| 7,372.00 | 0.0000 | 0.415 | 0.485 | 0.323 | 0.332 |
| 7,374.00 | 0.0000 | 0.918 | 1.950 | 1.300 | 1.633 |
| 7,376.00 | 0.0000 | 1.411 | 3.467 | 2.311 | 3.944 |
| 7,378.00 | 0.0000 | 1.594 | 4.505 | 3.003 | 6.947 |
| 7,380.00 | 0.0000 | 1.788 | 5.070 | 3.380 | 10.327 |
| 7,382.00 | 0.0000 | 2.032 | 5.726 | 3.817 | 14.145 |

Subsection: Composite Rating Curve
Label: FH North Pond 1

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,390.00 | 0.00 | (N/A) | 0.00 |
| 7,390.50 | 0.21 | (N/A) | 0.00 |
| 7,391.00 | 0.42 | (N/A) | 0.00 |
| 7,391.50 | 0.63 | (N/A) | 0.00 |
| 7,392.00 | 0.84 | (N/A) | 0.00 |
| 7,392.50 | 1.05 | (N/A) | 0.00 |
| 7,392.75 | 1.15 | (N/A) | 0.00 |
| 7,393.00 | 2.70 | (N/A) | 0.00 |
| 7,393.50 | 9.09 | (N/A) | 0.00 |
| 7,394.00 | 18.16 | (N/A) | 0.00 |
| 7,394.50 | 29.05 | (N/A) | 0.00 |
| 7,395.00 | 41.22 | (N/A) | 0.00 |
| 7,395.50 | 47.14 | (N/A) | 0.00 |
| 7,396.00 | 48.76 | (N/A) | 0.00 |

Contributing Structures

| |
|---|
| (no Q: Riser - 1,Orifice - 1,Culvert - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Composite Rating Curve
Label: FH North Pond 12

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,544.50 | 0.00 | (N/A) | 0.00 |
| 7,545.00 | 0.09 | (N/A) | 0.00 |
| 7,545.50 | 0.19 | (N/A) | 0.00 |
| 7,546.00 | 0.28 | (N/A) | 0.00 |
| 7,546.50 | 0.37 | (N/A) | 0.00 |
| 7,546.75 | 0.42 | (N/A) | 0.00 |
| 7,547.00 | 1.93 | (N/A) | 0.00 |
| 7,547.50 | 8.19 | (N/A) | 0.00 |
| 7,548.00 | 17.12 | (N/A) | 0.00 |
| 7,548.50 | 27.99 | (N/A) | 0.00 |
| 7,549.00 | 33.62 | (N/A) | 0.00 |
| 7,549.50 | 35.86 | (N/A) | 0.00 |
| 7,550.00 | 37.97 | (N/A) | 0.00 |
| 7,550.50 | 39.96 | (N/A) | 0.00 |
| 7,551.00 | 41.87 | (N/A) | 0.00 |
| 7,551.50 | 43.69 | (N/A) | 0.00 |
| 7,552.00 | 45.43 | (N/A) | 0.00 |

Contributing Structures

| |
|---|
| (no Q: Riser - 1,Orifice - 1,Culvert - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Orifice - 1,Culvert - 1 (no Q: Riser - 1) |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Composite Rating Curve
Label: FH North Pond 4

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,421.50 | 0.00 | (N/A) | 0.00 |
| 7,422.00 | 0.09 | (N/A) | 0.00 |
| 7,422.50 | 0.19 | (N/A) | 0.00 |
| 7,423.00 | 0.29 | (N/A) | 0.00 |
| 7,423.50 | 0.38 | (N/A) | 0.00 |
| 7,424.00 | 0.48 | (N/A) | 0.00 |
| 7,424.50 | 0.57 | (N/A) | 0.00 |
| 7,425.00 | 0.67 | (N/A) | 0.00 |
| 7,425.50 | 0.77 | (N/A) | 0.00 |
| 7,426.00 | 11.42 | (N/A) | 0.00 |
| 7,426.50 | 30.84 | (N/A) | 0.00 |
| 7,427.00 | 55.96 | (N/A) | 0.00 |
| 7,427.50 | 85.67 | (N/A) | 0.00 |
| 7,428.00 | 119.35 | (N/A) | 0.00 |
| 7,428.50 | 156.50 | (N/A) | 0.00 |
| 7,429.00 | 196.62 | (N/A) | 0.00 |
| 7,429.50 | 205.78 | (N/A) | 0.00 |
| 7,430.00 | 211.74 | (N/A) | 0.00 |
| 7,430.50 | 217.53 | (N/A) | 0.00 |
| 7,431.00 | 223.18 | (N/A) | 0.00 |
| 7,431.50 | 228.71 | (N/A) | 0.00 |
| 7,432.00 | 234.08 | (N/A) | 0.00 |

Contributing Structures

(no Q: Riser - 1, Orifice - 1, Culvert - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Orifice - 1, Culvert - 1 (no Q: Riser - 1)
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Orifice - 1, Culvert - 1
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)
 Riser - 1, Culvert - 1 (no Q: Orifice - 1)

Subsection: Composite Rating Curve
Label: FH North Pond 4

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Contributing Structures |
|---|
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,369.00 | 0.00 | (N/A) | 0.00 |
| 7,369.25 | 0.00 | (N/A) | 0.00 |
| 7,369.50 | 0.00 | (N/A) | 0.00 |
| 7,370.00 | 0.12 | (N/A) | 0.00 |
| 7,370.50 | 0.23 | (N/A) | 0.00 |
| 7,371.00 | 0.35 | (N/A) | 0.00 |
| 7,371.50 | 0.47 | (N/A) | 0.00 |
| 7,372.00 | 0.58 | (N/A) | 0.00 |
| 7,372.50 | 0.69 | (N/A) | 0.00 |
| 7,373.00 | 0.81 | (N/A) | 0.00 |
| 7,373.50 | 0.92 | (N/A) | 0.00 |
| 7,374.00 | 1.04 | (N/A) | 0.00 |
| 7,374.50 | 1.15 | (N/A) | 0.00 |
| 7,374.75 | 1.21 | (N/A) | 0.00 |
| 7,375.00 | 7.17 | (N/A) | 0.00 |
| 7,375.50 | 32.24 | (N/A) | 0.00 |
| 7,376.00 | 68.01 | (N/A) | 0.00 |
| 7,376.50 | 112.00 | (N/A) | 0.00 |
| 7,377.00 | 162.75 | (N/A) | 0.00 |
| 7,377.50 | 219.40 | (N/A) | 0.00 |
| 7,378.00 | 254.44 | (N/A) | 0.00 |
| 7,378.50 | 266.12 | (N/A) | 0.00 |
| 7,379.00 | 277.33 | (N/A) | 0.00 |
| 7,379.50 | 288.06 | (N/A) | 0.00 |
| 7,380.00 | 298.45 | (N/A) | 0.00 |
| 7,380.50 | 308.47 | (N/A) | 0.00 |
| 7,381.00 | 318.15 | (N/A) | 0.00 |
| 7,381.50 | 327.59 | (N/A) | 0.00 |
| 7,382.00 | 336.74 | (N/A) | 0.00 |

Contributing Structures

(no Q: Riser - 1,Orifice - 1,Culvert - 1)
 (no Q: Riser - 1,Orifice - 1,Culvert - 1)
 (no Q: Riser - 1,Orifice - 1,Culvert - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)
 Orifice - 1,Culvert - 1 (no Q: Riser - 1)

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Contributing Structures |
|--|
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 1

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,390.00 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|----------------|------------------------------|-----------------|--------------|-----------------------------------|-----------------------------------|-------------------------------|
| 7,390.00 | 0.00 | 0.000 | 0.004 | 0.00 | 0.00 | 0.00 |
| 7,390.50 | 0.21 | 0.007 | 0.029 | 0.00 | 0.21 | 3.74 |
| 7,391.00 | 0.42 | 0.033 | 0.077 | 0.00 | 0.42 | 16.33 |
| 7,391.50 | 0.63 | 0.088 | 0.148 | 0.00 | 0.63 | 43.31 |
| 7,392.00 | 0.84 | 0.185 | 0.242 | 0.00 | 0.84 | 90.25 |
| 7,392.50 | 1.05 | 0.310 | 0.258 | 0.00 | 1.05 | 151.00 |
| 7,392.75 | 1.15 | 0.375 | 0.267 | 0.00 | 1.15 | 182.89 |
| 7,393.00 | 2.70 | 0.443 | 0.275 | 0.00 | 2.70 | 217.24 |
| 7,393.50 | 9.09 | 0.585 | 0.293 | 0.00 | 9.09 | 292.39 |
| 7,394.00 | 18.16 | 0.736 | 0.311 | 0.00 | 18.16 | 374.53 |
| 7,394.50 | 29.05 | 0.896 | 0.329 | 0.00 | 29.05 | 462.88 |
| 7,395.00 | 41.22 | 1.066 | 0.348 | 0.00 | 41.22 | 556.98 |
| 7,395.50 | 47.14 | 1.244 | 0.367 | 0.00 | 47.14 | 649.42 |
| 7,396.00 | 48.76 | 1.433 | 0.387 | 0.00 | 48.76 | 742.29 |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 12

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,544.50 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,544.50 | 0.00 | 0.000 | 0.002 | 0.00 | 0.00 | 0.00 |
| 7,545.00 | 0.09 | 0.013 | 0.066 | 0.00 | 0.09 | 6.48 |
| 7,545.50 | 0.19 | 0.081 | 0.219 | 0.00 | 0.19 | 39.23 |
| 7,546.00 | 0.28 | 0.247 | 0.462 | 0.00 | 0.28 | 119.92 |
| 7,546.50 | 0.37 | 0.486 | 0.495 | 0.00 | 0.37 | 235.77 |
| 7,546.75 | 0.42 | 0.612 | 0.512 | 0.00 | 0.42 | 296.70 |
| 7,547.00 | 1.93 | 0.742 | 0.529 | 0.00 | 1.93 | 361.15 |
| 7,547.50 | 8.19 | 1.015 | 0.564 | 0.00 | 8.19 | 499.59 |
| 7,548.00 | 17.12 | 1.306 | 0.600 | 0.00 | 17.12 | 649.32 |
| 7,548.50 | 27.99 | 1.615 | 0.636 | 0.00 | 27.99 | 809.69 |
| 7,549.00 | 33.62 | 1.942 | 0.672 | 0.00 | 33.62 | 973.58 |
| 7,549.50 | 35.86 | 2.288 | 0.710 | 0.00 | 35.86 | 1,143.10 |
| 7,550.00 | 37.97 | 2.652 | 0.749 | 0.00 | 37.97 | 1,321.75 |
| 7,550.50 | 39.96 | 3.036 | 0.787 | 0.00 | 39.96 | 1,509.54 |
| 7,551.00 | 41.87 | 3.439 | 0.825 | 0.00 | 41.87 | 1,706.45 |
| 7,551.50 | 43.69 | 3.862 | 0.865 | 0.00 | 43.69 | 1,912.72 |
| 7,552.00 | 45.43 | 4.304 | 0.905 | 0.00 | 45.43 | 2,128.56 |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 4

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,421.50 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,421.50 | 0.00 | 0.000 | 0.004 | 0.00 | 0.00 | 0.00 |
| 7,422.00 | 0.09 | 0.002 | 0.004 | 0.00 | 0.09 | 1.06 |
| 7,422.50 | 0.19 | 0.009 | 0.030 | 0.00 | 0.19 | 4.74 |
| 7,423.00 | 0.29 | 0.035 | 0.079 | 0.00 | 0.29 | 17.47 |
| 7,423.50 | 0.38 | 0.092 | 0.152 | 0.00 | 0.38 | 44.96 |
| 7,424.00 | 0.48 | 0.191 | 0.248 | 0.00 | 0.48 | 92.92 |
| 7,424.50 | 0.57 | 0.348 | 0.386 | 0.00 | 0.57 | 169.09 |
| 7,425.00 | 0.67 | 0.582 | 0.554 | 0.00 | 0.67 | 282.28 |
| 7,425.50 | 0.77 | 0.907 | 0.752 | 0.00 | 0.77 | 439.80 |
| 7,426.00 | 11.42 | 1.339 | 0.981 | 0.00 | 11.42 | 659.57 |
| 7,426.50 | 30.84 | 1.844 | 1.040 | 0.00 | 30.84 | 923.46 |
| 7,427.00 | 55.96 | 2.379 | 1.100 | 0.00 | 55.96 | 1,207.47 |
| 7,427.50 | 85.67 | 2.945 | 1.162 | 0.00 | 85.67 | 1,510.87 |
| 7,428.00 | 119.35 | 3.542 | 1.226 | 0.00 | 119.35 | 1,833.49 |
| 7,428.50 | 156.50 | 4.167 | 1.276 | 0.00 | 156.50 | 2,173.36 |
| 7,429.00 | 196.62 | 4.818 | 1.327 | 0.00 | 196.62 | 2,528.43 |
| 7,429.50 | 205.78 | 5.494 | 1.379 | 0.00 | 205.78 | 2,864.99 |
| 7,430.00 | 211.74 | 6.197 | 1.432 | 0.00 | 211.74 | 3,211.06 |
| 7,430.50 | 217.53 | 6.926 | 1.485 | 0.00 | 217.53 | 3,569.83 |
| 7,431.00 | 223.18 | 7.682 | 1.540 | 0.00 | 223.18 | 3,941.46 |
| 7,431.50 | 228.71 | 8.466 | 1.595 | 0.00 | 228.71 | 4,326.23 |
| 7,432.00 | 234.08 | 9.277 | 1.651 | 0.00 | 234.08 | 4,724.32 |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 8

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,369.00 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,369.00 | 0.00 | 0.000 | 0.009 | 0.00 | 0.00 | 0.00 |
| 7,369.25 | 0.00 | 0.002 | 0.009 | 0.00 | 0.00 | 1.09 |
| 7,369.50 | 0.00 | 0.004 | 0.009 | 0.00 | 0.00 | 2.18 |
| 7,370.00 | 0.12 | 0.009 | 0.009 | 0.00 | 0.12 | 4.47 |
| 7,370.50 | 0.23 | 0.023 | 0.054 | 0.00 | 0.23 | 11.44 |
| 7,371.00 | 0.35 | 0.069 | 0.137 | 0.00 | 0.35 | 33.85 |
| 7,371.50 | 0.47 | 0.166 | 0.257 | 0.00 | 0.47 | 80.81 |
| 7,372.00 | 0.58 | 0.332 | 0.415 | 0.00 | 0.58 | 161.47 |
| 7,372.50 | 0.69 | 0.566 | 0.522 | 0.00 | 0.69 | 274.74 |
| 7,373.00 | 0.81 | 0.857 | 0.642 | 0.00 | 0.81 | 415.47 |
| 7,373.50 | 0.92 | 1.210 | 0.774 | 0.00 | 0.92 | 586.62 |
| 7,374.00 | 1.04 | 1.633 | 0.918 | 0.00 | 1.04 | 791.20 |
| 7,374.50 | 1.15 | 2.120 | 1.031 | 0.00 | 1.15 | 1,027.05 |
| 7,374.75 | 1.21 | 2.385 | 1.091 | 0.00 | 1.21 | 1,155.47 |
| 7,375.00 | 7.17 | 2.665 | 1.151 | 0.00 | 7.17 | 1,297.03 |
| 7,375.50 | 32.24 | 3.272 | 1.278 | 0.00 | 32.24 | 1,615.90 |
| 7,376.00 | 68.01 | 3.944 | 1.411 | 0.00 | 68.01 | 1,976.89 |
| 7,376.50 | 112.00 | 4.661 | 1.456 | 0.00 | 112.00 | 2,367.74 |
| 7,377.00 | 162.75 | 5.400 | 1.501 | 0.00 | 162.75 | 2,776.25 |
| 7,377.50 | 219.40 | 6.162 | 1.547 | 0.00 | 219.40 | 3,201.72 |
| 7,378.00 | 254.44 | 6.947 | 1.594 | 0.00 | 254.44 | 3,616.84 |
| 7,378.50 | 266.12 | 7.756 | 1.641 | 0.00 | 266.12 | 4,020.00 |
| 7,379.00 | 277.33 | 8.589 | 1.690 | 0.00 | 277.33 | 4,434.25 |
| 7,379.50 | 288.06 | 9.446 | 1.738 | 0.00 | 288.06 | 4,859.76 |
| 7,380.00 | 298.45 | 10.327 | 1.788 | 0.00 | 298.45 | 5,296.84 |
| 7,380.50 | 308.47 | 11.236 | 1.848 | 0.00 | 308.47 | 5,746.74 |
| 7,381.00 | 318.15 | 12.175 | 1.908 | 0.00 | 318.15 | 6,210.82 |
| 7,381.50 | 327.59 | 13.144 | 1.970 | 0.00 | 327.59 | 6,689.43 |
| 7,382.00 | 336.74 | 14.145 | 2.032 | 0.00 | 336.74 | 7,182.75 |

Index

C

Colo Springs 2015 (Time-Depth Curve, 100 years)...10

F

FH North Pond 1 (Composite Rating Curve, 100 years)...15

FH North Pond 1 (Elevation-Area Volume Curve, 100 years)...11

FH North Pond 1 (Elevation-Volume-Flow Table (Pond), 100 years)...21

FH North Pond 12 (Composite Rating Curve, 100 years)...16

FH North Pond 12 (Elevation-Area Volume Curve, 100 years)...12

FH North Pond 12 (Elevation-Volume-Flow Table (Pond), 100 years)...22

FH North Pond 4 (Composite Rating Curve, 100 years)...17, 18

FH North Pond 4 (Elevation-Area Volume Curve, 100 years)...13

FH North Pond 4 (Elevation-Volume-Flow Table (Pond), 100 years)...23

FH North Pond 8 (Composite Rating Curve, 100 years)...19, 20

FH North Pond 8 (Elevation-Area Volume Curve, 100 years)...14

FH North Pond 8 (Elevation-Volume-Flow Table (Pond), 100 years)...24

M

Master Network Summary...2, 3, 4, 5, 6, 7, 8, 9

Project Summary

| | |
|----------|-----------------------------------|
| Title | Flying Horse North Filing No.1 |
| Engineer | MAW |
| Company | CCES |
| Date | 11/20/2017 |

| | |
|-------|------------------------|
| Notes | 2 Year (Filing 1 Only) |
|-------|------------------------|

Table of Contents

| | | |
|-------------------|---|---|
| | Master Network Summary | 2 |
| Colo Springs 2015 | Time-Depth Curve, 2 years | 4 |
| FH North Pond 8 | Elevation-Area Volume Curve, 2 years | 5 |
| FH North Pond 8 | Composite Rating Curve, 2 years | 6 |
| FH North Pond 8 | Elevation-Volume-Flow Table (Pond), 2 years | 8 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|--------|---------------------------------------|----------------------|---------------------------|----------------------|--------------------------------|
| BS-18 | Post-Development 2 YR (Filing 1 Only) | 2 | 0.494 | 12.100 | 3.42 |
| BS-19 | Post-Development 2 YR (Filing 1 Only) | 2 | 0.161 | 12.050 | 2.08 |
| BS-20 | Post-Development 2 YR (Filing 1 Only) | 2 | 0.532 | 14.350 | 1.14 |
| BS-21 | Post-Development 2 YR (Filing 1 Only) | 2 | 0.840 | 12.300 | 3.20 |
| BS-22 | Post-Development 2 YR (Filing 1 Only) | 2 | 0.207 | 12.100 | 1.05 |
| BS-23 | Post-Development 2 YR (Filing 1 Only) | 2 | 0.626 | 12.200 | 4.08 |
| BS-23A | Post-Development 2 YR (Filing 1 Only) | 2 | 0.174 | 12.250 | 0.64 |

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|---------------------------------------|----------------------|---------------------------|----------------------|--------------------------------|
| DP-16 | Post-Development 2 YR (Filing 1 Only) | 2 | 2.856 | 12.150 | 11.61 |
| DP-17 | Post-Development 2 YR (Filing 1 Only) | 2 | 0.989 | 24.000 | 1.13 |

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|---------------------------------------|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| FH North Pond 8 (IN) | Post-Development 2 YR (Filing 1 Only) | 2 | 3.026 | 12.200 | 12.12 | (N/A) | (N/A) |
| FH North Pond 8 (OUT) | Post-Development 2 YR (Filing 1 Only) | 2 | 0.989 | 24.000 | 1.13 | 7,374.42 | 2.034 |
| Golf Course Pond 6 (IN) | Post-Development 2 YR (Filing 1 Only) | 2 | 1.372 | 12.350 | 4.24 | (N/A) | (N/A) |
| Golf Course Pond 6 (OUT) | Post-Development 2 YR (Filing 1 Only) | 2 | 1.370 | 12.400 | 4.18 | 7,436.02 | 2.471 |

Subsection: Master Network Summary

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|---------------------------------------|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| Golf Course Pond 7 (IN) | Post-Development 2 YR (Filing 1 Only) | 2 | 1.738 | 12.350 | 5.39 | (N/A) | (N/A) |
| Golf Course Pond 7 (OUT) | Post-Development 2 YR (Filing 1 Only) | 2 | 1.738 | 12.350 | 5.35 | 7,424.03 | 1.453 |

Subsection: Time-Depth Curve
Label: Colo Springs 2015

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Time-Depth Curve: TYPE II 24 HOUR

| | |
|--------------|-----------------|
| Label | TYPE II 24 HOUR |
| Start Time | 0.000 hours |
| Increment | 0.250 hours |
| End Time | 24.000 hours |
| Return Event | 2 years |

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.250 hours

Time on left represents time for first value in each row.

| Time (hours) | Depth (in) | Depth (in) | Depth (in) | Depth (in) | Depth (in) |
|-----------------|---------------|---------------|---------------|---------------|---------------|
| 0.000 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1.250 | 0.0 | 0.0 | 0.0 | 0.0 | 0.1 |
| 2.500 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |
| 3.750 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |
| 5.000 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 |
| 6.250 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| 7.500 | 0.2 | 0.2 | 0.3 | 0.3 | 0.3 |
| 8.750 | 0.3 | 0.3 | 0.3 | 0.3 | 0.4 |
| 10.000 | 0.4 | 0.4 | 0.4 | 0.5 | 0.5 |
| 11.250 | 0.5 | 0.6 | 0.8 | 1.4 | 1.5 |
| 12.500 | 1.5 | 1.6 | 1.6 | 1.7 | 1.7 |
| 13.750 | 1.7 | 1.7 | 1.8 | 1.8 | 1.8 |
| 15.000 | 1.8 | 1.8 | 1.8 | 1.9 | 1.9 |
| 16.250 | 1.9 | 1.9 | 1.9 | 1.9 | 1.9 |
| 17.500 | 1.9 | 1.9 | 1.9 | 1.9 | 2.0 |
| 18.750 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| 20.000 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| 21.250 | 2.0 | 2.0 | 2.0 | 2.1 | 2.1 |
| 22.500 | 2.1 | 2.1 | 2.1 | 2.1 | 2.1 |
| 23.750 | 2.1 | 2.1 | (N/A) | (N/A) | (N/A) |

Subsection: Elevation-Area Volume Curve
Label: FH North Pond 8

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,369.50 | 0.000 | 0.009 | 0.000 | 0.000 | 0.000 |
| 7,370.00 | 0.000 | 0.009 | 0.027 | 0.004 | 0.004 |
| 7,372.00 | 0.000 | 0.415 | 0.485 | 0.323 | 0.328 |
| 7,374.00 | 0.000 | 0.918 | 1.950 | 1.300 | 1.628 |
| 7,376.00 | 0.000 | 1.411 | 3.467 | 2.311 | 3.939 |
| 7,378.00 | 0.000 | 1.594 | 4.505 | 3.003 | 6.943 |
| 7,380.00 | 0.000 | 1.788 | 5.070 | 3.380 | 10.323 |
| 7,382.00 | 0.000 | 2.032 | 5.726 | 3.817 | 14.140 |

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,369.50 | 0.00 | (N/A) | 0.00 |
| 7,370.00 | 0.12 | (N/A) | 0.00 |
| 7,370.50 | 0.23 | (N/A) | 0.00 |
| 7,371.00 | 0.35 | (N/A) | 0.00 |
| 7,371.50 | 0.47 | (N/A) | 0.00 |
| 7,372.00 | 0.58 | (N/A) | 0.00 |
| 7,372.50 | 0.69 | (N/A) | 0.00 |
| 7,373.00 | 0.81 | (N/A) | 0.00 |
| 7,373.50 | 0.92 | (N/A) | 0.00 |
| 7,374.00 | 1.04 | (N/A) | 0.00 |
| 7,374.50 | 1.15 | (N/A) | 0.00 |
| 7,374.75 | 1.21 | (N/A) | 0.00 |
| 7,375.00 | 7.17 | (N/A) | 0.00 |
| 7,375.50 | 32.24 | (N/A) | 0.00 |
| 7,376.00 | 68.01 | (N/A) | 0.00 |
| 7,376.50 | 112.00 | (N/A) | 0.00 |
| 7,377.00 | 162.75 | (N/A) | 0.00 |
| 7,377.50 | 219.40 | (N/A) | 0.00 |
| 7,378.00 | 254.44 | (N/A) | 0.00 |
| 7,378.50 | 266.12 | (N/A) | 0.00 |
| 7,379.00 | 277.33 | (N/A) | 0.00 |
| 7,379.50 | 288.06 | (N/A) | 0.00 |
| 7,380.00 | 298.45 | (N/A) | 0.00 |
| 7,380.50 | 308.47 | (N/A) | 0.00 |
| 7,381.00 | 318.15 | (N/A) | 0.00 |
| 7,381.50 | 327.59 | (N/A) | 0.00 |
| 7,382.00 | 336.74 | (N/A) | 0.00 |

Contributing Structures

(no Q: Riser - 1, Orifice - 1, Culvert - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Riser - 1, Orifice - 1, Culvert - 1
Riser - 1, Orifice - 1, Culvert - 1
Riser - 1, Orifice - 1, Culvert - 1
Riser - 1, Orifice - 1, Culvert - 1

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Contributing Structures |
|---|
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 8

Return Event: 2 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,369.50 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,369.50 | 0.00 | 0.000 | 0.009 | 0.00 | 0.00 | 0.00 |
| 7,370.00 | 0.12 | 0.004 | 0.009 | 0.00 | 0.12 | 2.30 |
| 7,370.50 | 0.23 | 0.019 | 0.054 | 0.00 | 0.23 | 9.26 |
| 7,371.00 | 0.35 | 0.065 | 0.137 | 0.00 | 0.35 | 31.67 |
| 7,371.50 | 0.47 | 0.162 | 0.257 | 0.00 | 0.47 | 78.63 |
| 7,372.00 | 0.58 | 0.328 | 0.415 | 0.00 | 0.58 | 159.29 |
| 7,372.50 | 0.69 | 0.562 | 0.522 | 0.00 | 0.69 | 272.56 |
| 7,373.00 | 0.81 | 0.852 | 0.642 | 0.00 | 0.81 | 413.29 |
| 7,373.50 | 0.92 | 1.206 | 0.774 | 0.00 | 0.92 | 584.45 |
| 7,374.00 | 1.04 | 1.628 | 0.918 | 0.00 | 1.04 | 789.02 |
| 7,374.50 | 1.15 | 2.115 | 1.031 | 0.00 | 1.15 | 1,024.87 |
| 7,374.75 | 1.21 | 2.380 | 1.091 | 0.00 | 1.21 | 1,153.29 |
| 7,375.00 | 7.17 | 2.661 | 1.151 | 0.00 | 7.17 | 1,294.86 |
| 7,375.50 | 32.24 | 3.268 | 1.278 | 0.00 | 32.24 | 1,613.72 |
| 7,376.00 | 68.01 | 3.939 | 1.411 | 0.00 | 68.01 | 1,974.71 |
| 7,376.50 | 112.00 | 4.656 | 1.456 | 0.00 | 112.00 | 2,365.56 |
| 7,377.00 | 162.75 | 5.395 | 1.501 | 0.00 | 162.75 | 2,774.07 |
| 7,377.50 | 219.40 | 6.157 | 1.547 | 0.00 | 219.40 | 3,199.55 |
| 7,378.00 | 254.44 | 6.943 | 1.594 | 0.00 | 254.44 | 3,614.66 |
| 7,378.50 | 266.12 | 7.751 | 1.641 | 0.00 | 266.12 | 4,017.82 |
| 7,379.00 | 277.33 | 8.584 | 1.690 | 0.00 | 277.33 | 4,432.07 |
| 7,379.50 | 288.06 | 9.441 | 1.738 | 0.00 | 288.06 | 4,857.58 |
| 7,380.00 | 298.45 | 10.323 | 1.788 | 0.00 | 298.45 | 5,294.67 |
| 7,380.50 | 308.47 | 11.232 | 1.848 | 0.00 | 308.47 | 5,744.56 |
| 7,381.00 | 318.15 | 12.170 | 1.908 | 0.00 | 318.15 | 6,208.65 |
| 7,381.50 | 327.59 | 13.140 | 1.970 | 0.00 | 327.59 | 6,687.26 |
| 7,382.00 | 336.74 | 14.140 | 2.032 | 0.00 | 336.74 | 7,180.58 |

Index

C

Colo Springs 2015 (Time-Depth Curve, 2 years)...4

F

FH North Pond 8 (Composite Rating Curve, 2 years)...6, 7

FH North Pond 8 (Elevation-Area Volume Curve, 2 years)...5

FH North Pond 8 (Elevation-Volume-Flow Table (Pond), 2 years)...8

M

Master Network Summary...2, 3

Project Summary

| | |
|----------|-----------------------------------|
| Title | Flying Horse North Filing No.1 |
| Engineer | MAW |
| Company | CCES |
| Date | 11/20/2017 |

| | |
|-------|------------------------|
| Notes | 5 Year (Filing 1 Only) |
|-------|------------------------|

Table of Contents

| | | |
|-------------------|---|---|
| | Master Network Summary | 2 |
| Colo Springs 2015 | Time-Depth Curve, 5 years | 4 |
| FH North Pond 8 | Elevation-Area Volume Curve, 5 years | 5 |
| FH North Pond 8 | Composite Rating Curve, 5 years | 6 |
| FH North Pond 8 | Elevation-Volume-Flow Table (Pond), 5 years | 8 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|--------|---------------------------------------|----------------------|---------------------------|----------------------|--------------------------------|
| BS-18 | Post-Development 5 YR (Filing 1 Only) | 5 | 1.112 | 12.100 | 12.24 |
| BS-19 | Post-Development 5 YR (Filing 1 Only) | 5 | 0.312 | 12.050 | 4.62 |
| BS-20 | Post-Development 5 YR (Filing 1 Only) | 5 | 1.513 | 12.150 | 9.35 |
| BS-21 | Post-Development 5 YR (Filing 1 Only) | 5 | 2.002 | 12.250 | 13.46 |
| BS-22 | Post-Development 5 YR (Filing 1 Only) | 5 | 0.502 | 12.100 | 5.15 |
| BS-23 | Post-Development 5 YR (Filing 1 Only) | 5 | 1.353 | 12.150 | 12.91 |
| BS-23A | Post-Development 5 YR (Filing 1 Only) | 5 | 0.432 | 12.150 | 3.28 |

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|---------------------------------------|----------------------|---------------------------|----------------------|--------------------------------|
| DP-16 | Post-Development 5 YR (Filing 1 Only) | 5 | 6.787 | 12.150 | 47.28 |
| DP-17 | Post-Development 5 YR (Filing 1 Only) | 5 | 4.742 | 13.600 | 10.89 |

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|---------------------------------------|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| FH North Pond 8 (IN) | Post-Development 5 YR (Filing 1 Only) | 5 | 7.213 | 12.200 | 49.73 | (N/A) | (N/A) |
| FH North Pond 8 (OUT) | Post-Development 5 YR (Filing 1 Only) | 5 | 4.742 | 13.600 | 10.89 | 7,375.07 | 2.747 |
| Golf Course Pond 6 (IN) | Post-Development 5 YR (Filing 1 Only) | 5 | 3.515 | 12.200 | 22.52 | (N/A) | (N/A) |
| Golf Course Pond 6 (OUT) | Post-Development 5 YR (Filing 1 Only) | 5 | 3.510 | 12.250 | 21.92 | 7,436.11 | 2.529 |

Subsection: Master Network Summary

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|---------------------------------------|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| Golf Course Pond 7 (IN) | Post-Development 5 YR (Filing 1 Only) | 5 | 4.324 | 12.200 | 26.09 | (N/A) | (N/A) |
| Golf Course Pond 7 (OUT) | Post-Development 5 YR (Filing 1 Only) | 5 | 4.325 | 12.250 | 26.02 | 7,424.14 | 1.493 |

Subsection: Time-Depth Curve
Label: Colo Springs 2015

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Time-Depth Curve: TYPE II 24 HOUR

| | |
|--------------|-----------------|
| Label | TYPE II 24 HOUR |
| Start Time | 0.000 hours |
| Increment | 0.250 hours |
| End Time | 24.000 hours |
| Return Event | 5 years |

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.250 hours

Time on left represents time for first value in each row.

| Time (hours) | Depth (in) | Depth (in) | Depth (in) | Depth (in) | Depth (in) |
|-----------------|---------------|---------------|---------------|---------------|---------------|
| 0.000 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 1.250 | 0.0 | 0.0 | 0.1 | 0.1 | 0.1 |
| 2.500 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |
| 3.750 | 0.1 | 0.1 | 0.1 | 0.2 | 0.2 |
| 5.000 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 |
| 6.250 | 0.2 | 0.2 | 0.3 | 0.3 | 0.3 |
| 7.500 | 0.3 | 0.3 | 0.3 | 0.3 | 0.4 |
| 8.750 | 0.4 | 0.4 | 0.4 | 0.4 | 0.5 |
| 10.000 | 0.5 | 0.5 | 0.5 | 0.6 | 0.6 |
| 11.250 | 0.7 | 0.8 | 1.0 | 1.8 | 1.9 |
| 12.500 | 2.0 | 2.0 | 2.1 | 2.1 | 2.2 |
| 13.750 | 2.2 | 2.2 | 2.3 | 2.3 | 2.3 |
| 15.000 | 2.3 | 2.3 | 2.3 | 2.4 | 2.4 |
| 16.250 | 2.4 | 2.4 | 2.4 | 2.4 | 2.5 |
| 17.500 | 2.5 | 2.5 | 2.5 | 2.5 | 2.5 |
| 18.750 | 2.5 | 2.5 | 2.5 | 2.6 | 2.6 |
| 20.000 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 |
| 21.250 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 |
| 22.500 | 2.7 | 2.7 | 2.7 | 2.7 | 2.7 |
| 23.750 | 2.7 | 2.7 | (N/A) | (N/A) | (N/A) |

Subsection: Elevation-Area Volume Curve
Label: FH North Pond 8

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1+A2+sqr (A1*A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|---------------------------------|-------------------|---------------------------|
| 7,369.50 | 0.000 | 0.009 | 0.000 | 0.000 | 0.000 |
| 7,370.00 | 0.000 | 0.009 | 0.027 | 0.004 | 0.004 |
| 7,372.00 | 0.000 | 0.415 | 0.485 | 0.323 | 0.328 |
| 7,374.00 | 0.000 | 0.918 | 1.950 | 1.300 | 1.628 |
| 7,376.00 | 0.000 | 1.411 | 3.467 | 2.311 | 3.939 |
| 7,378.00 | 0.000 | 1.594 | 4.505 | 3.003 | 6.943 |
| 7,380.00 | 0.000 | 1.788 | 5.070 | 3.380 | 10.323 |
| 7,382.00 | 0.000 | 2.032 | 5.726 | 3.817 | 14.140 |

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,369.50 | 0.00 | (N/A) | 0.00 |
| 7,370.00 | 0.12 | (N/A) | 0.00 |
| 7,370.50 | 0.23 | (N/A) | 0.00 |
| 7,371.00 | 0.35 | (N/A) | 0.00 |
| 7,371.50 | 0.47 | (N/A) | 0.00 |
| 7,372.00 | 0.58 | (N/A) | 0.00 |
| 7,372.50 | 0.69 | (N/A) | 0.00 |
| 7,373.00 | 0.81 | (N/A) | 0.00 |
| 7,373.50 | 0.92 | (N/A) | 0.00 |
| 7,374.00 | 1.04 | (N/A) | 0.00 |
| 7,374.50 | 1.15 | (N/A) | 0.00 |
| 7,374.75 | 1.21 | (N/A) | 0.00 |
| 7,375.00 | 7.17 | (N/A) | 0.00 |
| 7,375.50 | 32.24 | (N/A) | 0.00 |
| 7,376.00 | 68.01 | (N/A) | 0.00 |
| 7,376.50 | 112.00 | (N/A) | 0.00 |
| 7,377.00 | 162.75 | (N/A) | 0.00 |
| 7,377.50 | 219.40 | (N/A) | 0.00 |
| 7,378.00 | 254.44 | (N/A) | 0.00 |
| 7,378.50 | 266.12 | (N/A) | 0.00 |
| 7,379.00 | 277.33 | (N/A) | 0.00 |
| 7,379.50 | 288.06 | (N/A) | 0.00 |
| 7,380.00 | 298.45 | (N/A) | 0.00 |
| 7,380.50 | 308.47 | (N/A) | 0.00 |
| 7,381.00 | 318.15 | (N/A) | 0.00 |
| 7,381.50 | 327.59 | (N/A) | 0.00 |
| 7,382.00 | 336.74 | (N/A) | 0.00 |

Contributing Structures

(no Q: Riser - 1, Orifice - 1, Culvert - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Orifice - 1, Culvert - 1 (no Q: Riser - 1)
Riser - 1, Orifice - 1, Culvert - 1
Riser - 1, Orifice - 1, Culvert - 1
Riser - 1, Orifice - 1, Culvert - 1
Riser - 1, Orifice - 1, Culvert - 1

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Contributing Structures |
|---|
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Orifice - 1,Culvert - 1 |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1,Culvert - 1 (no Q: Orifice - 1) |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 8

Return Event: 5 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,369.50 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,369.50 | 0.00 | 0.000 | 0.009 | 0.00 | 0.00 | 0.00 |
| 7,370.00 | 0.12 | 0.004 | 0.009 | 0.00 | 0.12 | 2.30 |
| 7,370.50 | 0.23 | 0.019 | 0.054 | 0.00 | 0.23 | 9.26 |
| 7,371.00 | 0.35 | 0.065 | 0.137 | 0.00 | 0.35 | 31.67 |
| 7,371.50 | 0.47 | 0.162 | 0.257 | 0.00 | 0.47 | 78.63 |
| 7,372.00 | 0.58 | 0.328 | 0.415 | 0.00 | 0.58 | 159.29 |
| 7,372.50 | 0.69 | 0.562 | 0.522 | 0.00 | 0.69 | 272.56 |
| 7,373.00 | 0.81 | 0.852 | 0.642 | 0.00 | 0.81 | 413.29 |
| 7,373.50 | 0.92 | 1.206 | 0.774 | 0.00 | 0.92 | 584.45 |
| 7,374.00 | 1.04 | 1.628 | 0.918 | 0.00 | 1.04 | 789.02 |
| 7,374.50 | 1.15 | 2.115 | 1.031 | 0.00 | 1.15 | 1,024.87 |
| 7,374.75 | 1.21 | 2.380 | 1.091 | 0.00 | 1.21 | 1,153.29 |
| 7,375.00 | 7.17 | 2.661 | 1.151 | 0.00 | 7.17 | 1,294.86 |
| 7,375.50 | 32.24 | 3.268 | 1.278 | 0.00 | 32.24 | 1,613.72 |
| 7,376.00 | 68.01 | 3.939 | 1.411 | 0.00 | 68.01 | 1,974.71 |
| 7,376.50 | 112.00 | 4.656 | 1.456 | 0.00 | 112.00 | 2,365.56 |
| 7,377.00 | 162.75 | 5.395 | 1.501 | 0.00 | 162.75 | 2,774.07 |
| 7,377.50 | 219.40 | 6.157 | 1.547 | 0.00 | 219.40 | 3,199.55 |
| 7,378.00 | 254.44 | 6.943 | 1.594 | 0.00 | 254.44 | 3,614.66 |
| 7,378.50 | 266.12 | 7.751 | 1.641 | 0.00 | 266.12 | 4,017.82 |
| 7,379.00 | 277.33 | 8.584 | 1.690 | 0.00 | 277.33 | 4,432.07 |
| 7,379.50 | 288.06 | 9.441 | 1.738 | 0.00 | 288.06 | 4,857.58 |
| 7,380.00 | 298.45 | 10.323 | 1.788 | 0.00 | 298.45 | 5,294.67 |
| 7,380.50 | 308.47 | 11.232 | 1.848 | 0.00 | 308.47 | 5,744.56 |
| 7,381.00 | 318.15 | 12.170 | 1.908 | 0.00 | 318.15 | 6,208.65 |
| 7,381.50 | 327.59 | 13.140 | 1.970 | 0.00 | 327.59 | 6,687.26 |
| 7,382.00 | 336.74 | 14.140 | 2.032 | 0.00 | 336.74 | 7,180.58 |

Index

C

Colo Springs 2015 (Time-Depth Curve, 5 years)...4

F

FH North Pond 8 (Composite Rating Curve, 5 years)...6, 7

FH North Pond 8 (Elevation-Area Volume Curve, 5 years)...5

FH North Pond 8 (Elevation-Volume-Flow Table (Pond), 5 years)...8

M

Master Network Summary...2, 3

Project Summary

| | |
|----------|-----------------------------------|
| Title | Flying Horse North Filing No.1 |
| Engineer | MAW |
| Company | CCES |
| Date | 11/20/2017 |

| | |
|-------|--------------------------|
| Notes | 100 Year (Filing 1 Only) |
|-------|--------------------------|

Table of Contents

| | | |
|-------------------|---|---|
| | Master Network Summary | 2 |
| Colo Springs 2015 | Time-Depth Curve, 100 years | 4 |
| FH North Pond 8 | Elevation-Area Volume Curve, 100 years | 5 |
| FH North Pond 8 | Composite Rating Curve, 100 years | 6 |
| FH North Pond 8 | Elevation-Volume-Flow Table (Pond), 100 years | 8 |

Subsection: Master Network Summary

Catchments Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|--------|---|----------------------|---------------------------|----------------------|--------------------------------|
| BS-18 | Post-Development 100 YR (Filing 1 Only) | 100 | 4.033 | 12.050 | 55.75 |
| BS-19 | Post-Development 100 YR (Filing 1 Only) | 100 | 0.955 | 12.050 | 14.95 |
| BS-20 | Post-Development 100 YR (Filing 1 Only) | 100 | 6.797 | 12.100 | 76.94 |
| BS-21 | Post-Development 100 YR (Filing 1 Only) | 100 | 7.687 | 12.200 | 75.52 |
| BS-22 | Post-Development 100 YR (Filing 1 Only) | 100 | 1.962 | 12.050 | 27.95 |
| BS-23 | Post-Development 100 YR (Filing 1 Only) | 100 | 4.695 | 12.100 | 56.90 |
| BS-23A | Post-Development 100 YR (Filing 1 Only) | 100 | 1.722 | 12.100 | 19.56 |

Node Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) |
|-------|---|----------------------|---------------------------|----------------------|--------------------------------|
| DP-16 | Post-Development 100 YR (Filing 1 Only) | 100 | 26.105 | 12.100 | 278.35 |
| DP-17 | Post-Development 100 YR (Filing 1 Only) | 100 | 25.124 | 12.350 | 197.59 |

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|-----------------------|---|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| FH North Pond 8 (IN) | Post-Development 100 YR (Filing 1 Only) | 100 | 27.812 | 12.150 | 297.19 | (N/A) | (N/A) |
| FH North Pond 8 (OUT) | Post-Development 100 YR (Filing 1 Only) | 100 | 25.124 | 12.350 | 197.59 | 7,377.31 | 5.861 |

Subsection: Master Network Summary

Pond Summary

| Label | Scenario | Return Event (years) | Hydrograph Volume (ac-ft) | Time to Peak (hours) | Peak Flow (ft ³ /s) | Maximum Water Surface Elevation (ft) | Maximum Pond Storage (ac-ft) |
|--------------------------|---|----------------------|---------------------------|----------------------|--------------------------------|--------------------------------------|------------------------------|
| Golf Course Pond 6 (IN) | Post-Development 100 YR (Filing 1 Only) | 100 | 14.484 | 12.150 | 149.77 | (N/A) | (N/A) |
| Golf Course Pond 6 (OUT) | Post-Development 100 YR (Filing 1 Only) | 100 | 14.470 | 12.150 | 147.51 | 7,436.65 | 2.876 |
| Golf Course Pond 7 (IN) | Post-Development 100 YR (Filing 1 Only) | 100 | 17.387 | 12.150 | 176.39 | (N/A) | (N/A) |
| Golf Course Pond 7 (OUT) | Post-Development 100 YR (Filing 1 Only) | 100 | 17.388 | 12.150 | 177.48 | 7,424.73 | 1.731 |

Subsection: Time-Depth Curve
Label: Colo Springs 2015

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Time-Depth Curve: TYPE II 24 HOUR

| | |
|--------------|-----------------|
| Label | TYPE II 24 HOUR |
| Start Time | 0.000 hours |
| Increment | 0.250 hours |
| End Time | 24.000 hours |
| Return Event | 100 years |

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.250 hours

Time on left represents time for first value in each row.

| Time (hours) | Depth (in) | Depth (in) | Depth (in) | Depth (in) | Depth (in) |
|-----------------|---------------|---------------|---------------|---------------|---------------|
| 0.000 | 0.0 | 0.0 | 0.0 | 0.0 | 0.1 |
| 1.250 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |
| 2.500 | 0.1 | 0.1 | 0.2 | 0.2 | 0.2 |
| 3.750 | 0.2 | 0.2 | 0.2 | 0.3 | 0.3 |
| 5.000 | 0.3 | 0.3 | 0.3 | 0.3 | 0.4 |
| 6.250 | 0.4 | 0.4 | 0.4 | 0.5 | 0.5 |
| 7.500 | 0.5 | 0.5 | 0.6 | 0.6 | 0.6 |
| 8.750 | 0.6 | 0.7 | 0.7 | 0.7 | 0.8 |
| 10.000 | 0.8 | 0.9 | 0.9 | 1.0 | 1.1 |
| 11.250 | 1.2 | 1.3 | 1.8 | 3.0 | 3.3 |
| 12.500 | 3.4 | 3.5 | 3.6 | 3.6 | 3.7 |
| 13.750 | 3.7 | 3.8 | 3.8 | 3.9 | 3.9 |
| 15.000 | 3.9 | 4.0 | 4.0 | 4.0 | 4.1 |
| 16.250 | 4.1 | 4.1 | 4.1 | 4.2 | 4.2 |
| 17.500 | 4.2 | 4.2 | 4.2 | 4.3 | 4.3 |
| 18.750 | 4.3 | 4.3 | 4.3 | 4.4 | 4.4 |
| 20.000 | 4.4 | 4.4 | 4.4 | 4.4 | 4.4 |
| 21.250 | 4.5 | 4.5 | 4.5 | 4.5 | 4.5 |
| 22.500 | 4.5 | 4.5 | 4.5 | 4.6 | 4.6 |
| 23.750 | 4.6 | 4.6 | (N/A) | (N/A) | (N/A) |

Subsection: Elevation-Area Volume Curve
Label: FH North Pond 8

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

| Elevation (ft) | Planimeter (ft ²) | Area (acres) | A1 + A2 + sq (A1 * A2) (acres) | Volume (ac-ft) | Volume (Total) (ac-ft) |
|-------------------|----------------------------------|-----------------|--------------------------------------|-------------------|---------------------------|
| 7,369.50 | 0.000 | 0.009 | 0.000 | 0.000 | 0.000 |
| 7,370.00 | 0.000 | 0.009 | 0.027 | 0.004 | 0.004 |
| 7,372.00 | 0.000 | 0.415 | 0.485 | 0.323 | 0.328 |
| 7,374.00 | 0.000 | 0.918 | 1.950 | 1.300 | 1.628 |
| 7,376.00 | 0.000 | 1.411 | 3.467 | 2.311 | 3.939 |
| 7,378.00 | 0.000 | 1.594 | 4.505 | 3.003 | 6.943 |
| 7,380.00 | 0.000 | 1.788 | 5.070 | 3.380 | 10.323 |
| 7,382.00 | 0.000 | 2.032 | 5.726 | 3.817 | 14.140 |

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Water Surface Elevation (ft) | Flow (ft ³ /s) | Tailwater Elevation (ft) | Convergence Error (ft) |
|------------------------------------|------------------------------|-----------------------------|---------------------------|
| 7,369.50 | 0.00 | (N/A) | 0.00 |
| 7,370.00 | 0.12 | (N/A) | 0.00 |
| 7,370.50 | 0.23 | (N/A) | 0.00 |
| 7,371.00 | 0.35 | (N/A) | 0.00 |
| 7,371.50 | 0.47 | (N/A) | 0.00 |
| 7,372.00 | 0.58 | (N/A) | 0.00 |
| 7,372.50 | 0.69 | (N/A) | 0.00 |
| 7,373.00 | 0.81 | (N/A) | 0.00 |
| 7,373.50 | 0.92 | (N/A) | 0.00 |
| 7,374.00 | 1.04 | (N/A) | 0.00 |
| 7,374.50 | 1.15 | (N/A) | 0.00 |
| 7,374.75 | 1.21 | (N/A) | 0.00 |
| 7,375.00 | 7.17 | (N/A) | 0.00 |
| 7,375.50 | 32.24 | (N/A) | 0.00 |
| 7,376.00 | 68.01 | (N/A) | 0.00 |
| 7,376.50 | 112.00 | (N/A) | 0.00 |
| 7,377.00 | 162.75 | (N/A) | 0.00 |
| 7,377.50 | 219.40 | (N/A) | 0.00 |
| 7,378.00 | 254.44 | (N/A) | 0.00 |
| 7,378.50 | 266.12 | (N/A) | 0.00 |
| 7,379.00 | 277.33 | (N/A) | 0.00 |
| 7,379.50 | 288.06 | (N/A) | 0.00 |
| 7,380.00 | 298.45 | (N/A) | 0.00 |
| 7,380.50 | 308.47 | (N/A) | 0.00 |
| 7,381.00 | 318.15 | (N/A) | 0.00 |
| 7,381.50 | 327.59 | (N/A) | 0.00 |
| 7,382.00 | 336.74 | (N/A) | 0.00 |

Contributing Structures

(no Q: Riser - 1,Orifice - 1,Culvert - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Orifice - 1,Culvert - 1 (no Q: Riser - 1)
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Orifice - 1,Culvert - 1
Riser - 1,Orifice - 1,Culvert - 1

Subsection: Composite Rating Curve
Label: FH North Pond 8

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

Composite Outflow Summary

| Contributing Structures |
|--|
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Orifice - 1, Culvert - 1 |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |
| Riser - 1, Culvert - 1 (no Q: Orifice - 1) |

Subsection: Elevation-Volume-Flow Table (Pond)
Label: FH North Pond 8

Return Event: 100 years
Storm Event: TYPE II 24 HOUR

| Infiltration | |
|---------------------------------------|-------------------------|
| Infiltration Method (Computed) | No Infiltration |
| Initial Conditions | |
| Elevation (Water Surface, Initial) | 7,369.50 ft |
| Volume (Initial) | 0.000 ac-ft |
| Flow (Initial Outlet) | 0.00 ft ³ /s |
| Flow (Initial Infiltration) | 0.00 ft ³ /s |
| Flow (Initial, Total) | 0.00 ft ³ /s |
| Time Increment | 0.050 hours |

| Elevation (ft) | Outflow (ft ³ /s) | Storage (ac-ft) | Area (acres) | Infiltration (ft ³ /s) | Flow (Total) (ft ³ /s) | 2S/t + O (ft ³ /s) |
|-------------------|---------------------------------|--------------------|-----------------|--------------------------------------|--------------------------------------|----------------------------------|
| 7,369.50 | 0.00 | 0.000 | 0.009 | 0.00 | 0.00 | 0.00 |
| 7,370.00 | 0.12 | 0.004 | 0.009 | 0.00 | 0.12 | 2.30 |
| 7,370.50 | 0.23 | 0.019 | 0.054 | 0.00 | 0.23 | 9.26 |
| 7,371.00 | 0.35 | 0.065 | 0.137 | 0.00 | 0.35 | 31.67 |
| 7,371.50 | 0.47 | 0.162 | 0.257 | 0.00 | 0.47 | 78.63 |
| 7,372.00 | 0.58 | 0.328 | 0.415 | 0.00 | 0.58 | 159.29 |
| 7,372.50 | 0.69 | 0.562 | 0.522 | 0.00 | 0.69 | 272.56 |
| 7,373.00 | 0.81 | 0.852 | 0.642 | 0.00 | 0.81 | 413.29 |
| 7,373.50 | 0.92 | 1.206 | 0.774 | 0.00 | 0.92 | 584.45 |
| 7,374.00 | 1.04 | 1.628 | 0.918 | 0.00 | 1.04 | 789.02 |
| 7,374.50 | 1.15 | 2.115 | 1.031 | 0.00 | 1.15 | 1,024.87 |
| 7,374.75 | 1.21 | 2.380 | 1.091 | 0.00 | 1.21 | 1,153.29 |
| 7,375.00 | 7.17 | 2.661 | 1.151 | 0.00 | 7.17 | 1,294.86 |
| 7,375.50 | 32.24 | 3.268 | 1.278 | 0.00 | 32.24 | 1,613.72 |
| 7,376.00 | 68.01 | 3.939 | 1.411 | 0.00 | 68.01 | 1,974.71 |
| 7,376.50 | 112.00 | 4.656 | 1.456 | 0.00 | 112.00 | 2,365.56 |
| 7,377.00 | 162.75 | 5.395 | 1.501 | 0.00 | 162.75 | 2,774.07 |
| 7,377.50 | 219.40 | 6.157 | 1.547 | 0.00 | 219.40 | 3,199.55 |
| 7,378.00 | 254.44 | 6.943 | 1.594 | 0.00 | 254.44 | 3,614.66 |
| 7,378.50 | 266.12 | 7.751 | 1.641 | 0.00 | 266.12 | 4,017.82 |
| 7,379.00 | 277.33 | 8.584 | 1.690 | 0.00 | 277.33 | 4,432.07 |
| 7,379.50 | 288.06 | 9.441 | 1.738 | 0.00 | 288.06 | 4,857.58 |
| 7,380.00 | 298.45 | 10.323 | 1.788 | 0.00 | 298.45 | 5,294.67 |
| 7,380.50 | 308.47 | 11.232 | 1.848 | 0.00 | 308.47 | 5,744.56 |
| 7,381.00 | 318.15 | 12.170 | 1.908 | 0.00 | 318.15 | 6,208.65 |
| 7,381.50 | 327.59 | 13.140 | 1.970 | 0.00 | 327.59 | 6,687.26 |
| 7,382.00 | 336.74 | 14.140 | 2.032 | 0.00 | 336.74 | 7,180.58 |

Index

C

Colo Springs 2015 (Time-Depth Curve, 100 years)...4

F

FH North Pond 8 (Composite Rating Curve, 100 years)...6, 7

FH North Pond 8 (Elevation-Area Volume Curve, 100 years)...5

FH North Pond 8 (Elevation-Volume-Flow Table (Pond), 100 years)...8

M

Master Network Summary...2, 3

DRAINAGE MAPS

DESIGN POINTS SURFACE ROUTING SUMMARY - EXISTING CONDITIONS

| Design Point (feet) | Contributing Basins | Q 2 Yr. Q (cfs) | Q 5 Yr. Q (cfs) | Q 100 Yr. Q (cfs) |
|------------------------|---|-----------------------|-----------------------|-------------------------|
| DP-1 | BASIN EX-1, EX-13, HF DP 95 & 95, BASIN HF-000 | 1.18 | 8.01 | 84.65 |
| DP-2 | BASIN EX-2, BASIN EX-3 | 0.05 | 0.28 | 5.78 |
| DP-3 | BASIN EX-4, BASIN EX-5 | 1.14 | 6.82 | 142.58 |
| DP-4 | BASIN EX-6, BASIN EX-7 | 1.77 | 9.35 | 100.62 |
| DP-5 | BASIN EX-8, BASIN EX-9 | 0.70 | 4.18 | 86.05 |
| DP-6 | BASIN EX-10 | 0.13 | 0.80 | 18.95 |
| DP-7 | BASIN EX-11, HF POND 26 RELEASE | 3.61 | 18.28 | 192.76 |
| DP-8 | BASIN EX-12 | 0.01 | 0.07 | 1.40 |
| DP-9 | BASIN EX-13, BASIN EX-14, BASIN HF-V | 0.28 | 2.84 | 28.96 |
| DP-10 | BASIN EX-15 | 0.02 | 0.11 | 2.53 |
| DP-11 | BASIN EX-16, BASIN HF-U | 0.12 | 1.35 | 10.79 |
| DP-12 | BASIN EX-17, HF POND 26 RELEASE | 16.66 | 99.01 | 309.38 |
| DP-13 | BASIN EX-18, BASIN HF- AAAA | 0.13 | 1.01 | 13.18 |
| DP-14 | BASIN EX-20 | 0.05 | 0.36 | 17.63 |
| DP-15 | BASIN EX-21, BASIN EX-22, BASIN OS-2 | 8.10 | 31.14 | 210.21 |
| DP-16 | DP-15, BASIN EX-23 | 7.95 | 30.43 | 220.97 |
| DP-17 | BASIN EX-24 | 0.09 | 0.70 | 32.60 |
| DP-18 | BASIN EX-25, BASIN OS-3 | 4.38 | 16.83 | 101.67 |
| DP-19 | BASIN EX-26 | 0.02 | 0.18 | 9.75 |
| DP-20 | BASIN EX-27 | 0.01 | 0.06 | 4.21 |
| DP-21 | BASIN EX-28 | 0.04 | 0.34 | 16.19 |
| DP-22 | BASIN EX-29 | 0.02 | 0.16 | 8.06 |
| DP-23 | BASIN EX-30 | 0.01 | 0.11 | 5.78 |
| DP-24 | BASIN EX-31 | 0.01 | 0.06 | 3.23 |
| DP-25 | BASIN EX-32 | 0.02 | 0.11 | 6.53 |
| DP-26 | BASIN EX-33 | 0.02 | 0.12 | 6.31 |
| DP-27 | BASIN EX-34, BASIN OS-4, OS-2 & OS-3 | 0.84 | 3.38 | 34.71 |
| DP-28 | DP-27, BASIN EX-35, BASIN OS-4 & OS-3 | 1.57 | 6.06 | 71.01 |
| DP-29 | BASIN EX-36 | 0.01 | 0.06 | 3.27 |
| HF-20 | FROM HF RANCH DRAINAGE | 3.59 | 17.35 | 134.23 |
| HF-22 | FROM HF RANCH DRAINAGE | 0.22 | 2.43 | 18.79 |
| HF-21 | FROM HF RANCH DRAINAGE | 0.11 | 1.28 | 9.47 |
| HF-17 | FROM HF RANCH DRAINAGE | 0.96 | 9.08 | 80.95 |
| HF-16 | FROM HF RANCH DRAINAGE | 15.61 | 54.33 | 281.26 |
| HF-80 | FROM HF RANCH DRAINAGE | 0.15 | 1.51 | 12.37 |
| HF-79 | FROM HF RANCH DRAINAGE | 0.08 | 0.86 | 6.81 |
| HF-68 | FROM HF RANCH DRAINAGE | 0.44 | 3.59 | 31.91 |
| HF-67 | FROM HF RANCH DRAINAGE | 0.07 | 0.77 | 5.71 |
| HF-66 | FROM HF RANCH DRAINAGE | 0.34 | 3.46 | 29.19 |

BASIN SUMMARY - EXISTING CONDITIONS

| BASIN (label) | TOTAL BASIN AREA (acres) | WEIGHTED CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|------------------|-----------------------------------|----------------|------------------------------|---------------------|---------------------|-----------------------|
| EX-1 | 70.55 | 56.0 | 0.49 | 0.34 | 2.01 | 38.39 |
| EX-2 | 16.26 | 51.0 | 0.39 | 0.16 | 0.76 | 3.76 |
| EX-3 | 3.80 | 56.0 | 0.40 | 0.02 | 0.11 | 2.37 |
| EX-4 | 2.60 | 56.0 | 0.38 | 0.01 | 0.08 | 1.68 |
| EX-5 | 109.00 | 56.0 | 0.42 | 0.54 | 3.23 | 66.05 |
| EX-6 | 12.95 | 56.0 | 0.33 | 0.07 | 0.40 | 8.94 |
| EX-7 | 98.00 | 56.0 | 0.43 | 0.49 | 2.89 | 56.39 |
| EX-8 | 101.00 | 56.0 | 0.14 | 0.51 | 3.02 | 62.11 |
| EX-9 | 39.50 | 56.0 | 0.42 | 0.20 | 1.17 | 23.94 |
| EX-10 | 23.10 | 56.0 | 0.26 | 0.13 | 0.80 | 16.95 |
| EX-11 | 32.42 | 56.0 | 0.18 | 0.16 | 0.93 | 18.79 |
| EX-12 | 1.32 | 56.0 | 0.13 | 0.03 | 0.07 | 1.40 |
| EX-13 | 5.93 | 56.0 | 0.15 | 0.04 | 0.28 | 6.18 |
| EX-14 | 3.83 | 56.0 | 0.15 | 0.02 | 0.18 | 3.99 |
| EX-15 | 2.43 | 56.0 | 0.15 | 0.05 | 0.30 | 6.96 |
| EX-16 | 1.25 | 56.0 | 0.13 | 0.01 | 0.06 | 1.32 |
| EX-17 | 8.43 | 56.0 | 0.11 | 0.05 | 0.50 | 9.36 |
| EX-18 | 6.70 | 56.0 | 0.27 | 0.05 | 0.30 | 6.96 |
| EX-19 | 6.62 | 56.0 | 0.23 | 0.04 | 0.25 | 5.61 |
| EX-20 | 26.50 | 22.5 | 0.46 | 0.05 | 0.36 | 17.93 |
| EX-21 | 140.00 | 51.0 | 0.54 | 0.12 | 0.90 | 39.97 |
| EX-22 | 80.00 | 51.0 | 0.55 | 0.07 | 0.51 | 22.84 |
| EX-23 | 42.65 | 51.0 | 0.49 | 0.04 | 0.28 | 12.93 |
| EX-24 | 159.00 | 51.0 | 0.50 | 0.08 | 0.70 | 32.90 |
| EX-25 | 54.00 | 51.0 | 0.47 | 0.05 | 0.35 | 16.82 |
| EX-26 | 27.50 | 51.0 | 0.39 | 0.02 | 0.18 | 9.75 |
| EX-27 | 10.90 | 51.0 | 0.30 | 0.01 | 0.08 | 4.21 |
| EX-28 | 52.00 | 51.0 | 0.47 | 0.04 | 0.34 | 16.19 |
| EX-29 | 24.90 | 51.0 | 0.45 | 0.02 | 0.16 | 8.06 |
| EX-30 | 16.26 | 51.0 | 0.39 | 0.01 | 0.11 | 5.78 |
| EX-31 | 9.12 | 51.0 | 0.39 | 0.01 | 0.06 | 3.23 |
| EX-32 | 17.50 | 51.0 | 0.36 | 0.02 | 0.11 | 6.53 |
| EX-33 | 19.30 | 51.0 | 0.44 | 0.02 | 0.12 | 6.31 |
| EX-34 | 108.00 | 51.0 | 0.53 | 0.09 | 0.69 | 31.42 |
| EX-35 | 103.00 | 51.0 | 0.51 | 0.09 | 0.66 | 30.61 |
| EX-36 | 10.90 | 51.0 | 0.44 | 0.01 | 0.06 | 3.27 |
| OS-1 | 28.75 | 65.0 | 0.44 | 1.77 | 6.71 | 34.84 |
| OS-2 | 131.00 | 65.0 | 0.40 | 8.10 | 31.14 | 161.89 |
| OS-3 | 70.80 | 65.0 | 0.40 | 4.38 | 16.83 | 87.49 |
| OS-4 | 11.00 | 65.0 | 0.22 | 0.99 | 3.76 | 18.32 |
| OS-5 | 6.00 | 65.0 | 0.22 | 0.54 | 2.05 | 9.99 |
| OS-6 | 3.00 | 65.0 | 0.17 | 0.31 | 1.12 | 5.39 |
| OS-7 | 2.00 | 65.0 | 0.14 | 0.24 | 0.86 | 3.73 |
| OS-8 | 3.00 | 65.0 | 0.12 | 0.40 | 1.33 | 5.87 |
| FROM HF POND 26 | 0.00 | 0.0 | 0.00 | 3.59 | 17.35 | 134.23 |
| HF-V | 13.70 | 60.0 | 0.16 | 0.22 | 2.43 | 18.80 |
| HF-U | 6.80 | 60.0 | 0.15 | 0.11 | 1.26 | 9.44 |
| FROM HF DP 17 | 61.20 | 60.0 | 0.19 | 0.96 | 6.68 | 80.95 |
| FROM HF POND 16 | 0.00 | 0.0 | 0.00 | 15.61 | 54.33 | 281.26 |
| HF-BBBB | 9.20 | 60.0 | 0.17 | 0.15 | 1.51 | 12.37 |
| HF-AAAA | 5.00 | 60.0 | 0.16 | 0.08 | 0.86 | 6.81 |
| FROM HF DP 68 | 30.25 | 60.0 | 0.30 | 0.44 | 3.59 | 31.91 |
| HF-000 | 4.10 | 60.0 | 0.15 | 0.07 | 0.77 | 5.71 |
| FROM HF DP 66 | 21.80 | 60.0 | 0.18 | 0.34 | 3.46 | 29.19 |

| DESCRIPTION | SYMBOL |
|----------------------------------|------------|
| EXISTING GROUND CONTOUR | 6910 |
| PROPOSED FINISHED CONTOUR | 6910 |
| BASIN BOUNDARY EAST CHERRY CREEK | --- |
| MAJOR BASIN BOUNDARY | --- |
| BASIN BOUNDARY BLACK SQUIRREL | --- |
| DESIGN POINT | 3 |
| BASIN IDENTIFIER | 86 10.0 |
| EXISTING DIRECTION OF FLOW | → |
| PROPOSED DIRECTION OF FLOW | → |
| STORM SEWER | --- |

FARRAR DR


RESIDENTIAL
2-3 DU/AC
47 ACEAGLE CREST
ESTATESSOUTH PLATTE RIVER
BASIN (EAST CHERRY
CREEK)

COUNTRY VIEW ESTATES

PALMER DIVIDE SUB

KETTLE CREEK
DRAINAGE
BASIN

APACHE WOODS



CLASSIC
CONSULTING
ENGINEERS & SURVEYORS


619 N. Cascade Avenue, Suite 200
Colorado Springs, Colorado 80903

(719) 785-0790
(719) 785-0799 (fax)

FLYING HORSE NORTH
PRELIMINARY/FINAL DRAINAGE REPORT
PRE-DEVELOPMENT DRAINAGE MAP

| | | | | |
|-------------|-----|---------------|---------|---------|
| DESIGNED BY | MAW | SCALE | DATE | 3-16-18 |
| DRAWN BY | MAW | (H) 1" = 500' | SHEET | 1 OF 1 |
| CHECKED BY | (V) | 1" = N/A | JOB NO. | 1096.11 |

CLASSIC
CONSULTING
ENGINEERS & SURVEYORS




BASIN SUMMARY - DEVELOPED CONDITIONS

| BASIN (label) | AREA (acres) | COMPOSITE CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|--------------------|-----------------|-----------------|------------------------------|---------------------|---------------------|-----------------------|
| OS-1A | 4.40 | 61.0 | 0.20 | 0.4 | 1.6 | 7.7 |
| OS-1B | 5.60 | 61.0 | 0.21 | 0.5 | 1.9 | 9.4 |
| EX-DP-3 (Pre-Dev.) | 36.00 | 60.0 | 0.25 | 0.5 | 4.8 | 41.3 |
| OS-2 | 2.90 | 61.0 | 0.20 | 0.1 | 0.6 | 4.0 |
| OS-3 | 10.20 | 65.0 | 0.19 | 1.0 | 3.8 | 17.9 |
| OS-4 | 32.90 | 65.0 | 0.23 | 2.8 | 11.2 | 53.6 |
| OS-5 | 29.70 | 65.0 | 0.39 | 1.9 | 7.1 | 37.0 |
| OS-6 | 9.20 | 65.0 | 0.21 | 0.9 | 3.2 | 15.5 |
| OS-7 | 5.00 | 65.0 | 0.18 | 0.5 | 2.0 | 9.0 |
| | | | | | | |
| BS-1A | 3.50 | 65.0 | 0.17 | 0.4 | 1.4 | 6.3 |
| BS-1B | 8.90 | 65.0 | 0.20 | 0.4 | 2.4 | 13.8 |
| BS-2 | 1.90 | 89.0 | 0.35 | 2.9 | 4.2 | 8.4 |
| BS-2A | 0.80 | 89.0 | 0.13 | 1.2 | 1.8 | 3.5 |
| BS-2B | 0.90 | 89.0 | 0.12 | 1.4 | 2.0 | 4.0 |
| BS-3 | 6.20 | 65.0 | 0.20 | 0.6 | 2.3 | 10.8 |
| BS-4 | 13.00 | 67.0 | 0.23 | 1.9 | 5.5 | 23.6 |
| BS-5 | 11.20 | 65.0 | 0.18 | 1.1 | 4.4 | 20.1 |
| BS-6 | 1.20 | 89.0 | 0.09 | 1.9 | 2.8 | 5.4 |
| BS-7 | 2.90 | 65.0 | 0.13 | 4.4 | 6.4 | 12.8 |
| BS-8 | 1.00 | 89.0 | 0.12 | 1.6 | 2.2 | 4.5 |
| BS-9 | 1.50 | 89.0 | 0.13 | 2.3 | 3.3 | 6.6 |
| BS-10 | 4.50 | 65.0 | 0.24 | 6.0 | 8.7 | 17.5 |
| BS-11 | 0.90 | 89.0 | 0.08 | 1.5 | 2.1 | 4.1 |
| BS-12 | 7.70 | 65.0 | 0.19 | 0.8 | 3.0 | 13.8 |


DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS

| Design Point (label) | Contributing Basins | Q 2 Yr. Q (cfs) | Q 5 Yr. Q (cfs) | Q 100 Yr. Q (cfs) |
|---|--|-----------------------|-----------------------|-------------------------|
| DP-1 DEV | OS-1A, BS-2B | 1.6 | 3.4 | 11 |
| DP-2 DEV | DP-1, BS-4 | 3.2 | 8.8 | 35 |
| TOTAL INFLOW TO POND 1 (UD Detention hydrograph) | DP-1, DP-2, BS-1A | 4 | 7 | 38 |
| DP-3 DEV (Pond Pack routing) | OS-2, BS-3, BS-1B, Release from FHN Pond 1 | 1 | 6 | 39 |
| DP-4 DEV | BS-2 | 2.9 | 4.2 | 8 |
| DP-5 DEV | OS-1B, BS-2A | 1.5 | 3.5 | 13 |
| DP-6 DEV | OS-2, BS-3 | 0.6 | 2.8 | 15 |
| DP-7 DEV | OS-3, BS-5 | 2.1 | 8.2 | 38 |
| DP-8 DEV | OS-4, OS-5, OS-6, BS-7, BS-10, Release from Exist. HFR Pond 16 | 20.9 | 70.4 | 284 |
| DP-9 DEV | OS-7, BS-12 | 1.3 | 5.0 | 23 |



MATCH LINE - SEE SHEET 1

MATCH LINE - SEE SHEET 3



BASIN SUMMARY - DEVELOPED CONDITIONS


| BASIN | AREA | COMPOSITE | TOTAL | Q | Q | Q |
|-----------------|---------|-----------|----------|-------|-------|---------|
| (Label) | (Acres) | CN | LAG TIME | 2 Yr. | 5 Yr. | 100 Yr. |
| (in) | | | (Hours) | (cfs) | (cfs) | (cfs) |
| OS-8 | 14.20 | 65.0 | 0.27 | 2.1 | 6.2 | 24.7 |
| OS-9 | 9.80 | 60.0 | 0.37 | 0.1 | 1.0 | 9.1 |
| OS-10 | 4.10 | 65.0 | 0.17 | 0.7 | 2.1 | 8.2 |
| OS-11 | 28.00 | 65.0 | 0.35 | 2.4 | 8.2 | 38.7 |
| OS-12 | 68.10 | 62.7 | 0.37 | 2.2 | 11.9 | 75.8 |
| OS-13 | 36.90 | 63.0 | 0.33 | 1.4 | 7.4 | 45.0 |
| OS-14 | 26.40 | 62.0 | 0.31 | 0.7 | 4.6 | 31.0 |
| OS-15 | 70.80 | 63.9 | 0.38 | 3.3 | 14.8 | 84.2 |
| OS-16 | 4.50 | 65.0 | 0.24 | 0.4 | 1.5 | 7.2 |
| OS-17 | 15.80 | 65.0 | 0.19 | 1.6 | 5.9 | 27.7 |
| OS-18 | 13.00 | 65.0 | 0.20 | 1.3 | 4.7 | 22.6 |
| BS-13 | 25.60 | 65.0 | 0.23 | 3.7 | 10.2 | 40.7 |
| BS-14 | 13.40 | 65.0 | 0.23 | 2.6 | 6.8 | 26.5 |
| BS-15 | 5.30 | 65.0 | 0.18 | 1.6 | 3.7 | 12.2 |
| BS-16 | 21.60 | 65.0 | 0.34 | 4.6 | 11.8 | 44.1 |
| BS-17 | 12.10 | 65.0 | 0.21 | 3.1 | 7.7 | 28.7 |
| BS-18 | 33.80 | 63.6 | 0.41 | 3.5 | 12.4 | 56.0 |
| BS-19 | 4.30 | 65.0 | 0.18 | 2.1 | 4.6 | 15.0 |
| BS-20 | 73.90 | 63.4 | 0.31 | 7.4 | 24.6 | 112.4 |
| BS-21 | 69.50 | 64.3 | 0.35 | 7.8 | 23.9 | 103.0 |
| BS-22 | 18.10 | 64.4 | 0.22 | 3.7 | 9.6 | 36.5 |
| BS-23 | 37.10 | 63.3 | 0.33 | 4.5 | 13.6 | 58.2 |
| BS-23A | 16.30 | 64.4 | 0.29 | 5.5 | 12.0 | 38.5 |
| BS-24 | 10.90 | 63.0 | 0.17 | 0.6 | 3.3 | 17.6 |
| EX-24 (Pre-Dev) | 13.20 | 60.0 | 0.17 | 0.2 | 2.2 | 17.8 |
| BS-25 | 12.70 | 63.0 | 0.23 | 0.4 | 2.7 | 17.3 |
| BS-26 | 2.50 | 60.0 | 0.18 | 0.0 | 0.4 | 3.4 |
| BS-27 | 23.30 | 65.0 | 0.22 | 2.1 | 8.0 | 38.8 |
| BS-28 | 36.90 | 64.4 | 0.32 | 2.2 | 9.3 | 49.4 |
| BS-29 | 27.70 | 64.0 | 0.33 | 1.4 | 6.5 | 35.9 |
| BS-30 | 4.70 | 65.0 | 0.20 | 0.7 | 2.4 | 11.7 |
| BS-31 | 8.40 | 62.5 | 0.23 | 0.3 | 1.9 | 11.8 |
| BS-32 | 6.20 | 62.6 | 0.20 | 0.3 | 1.6 | 9.4 |
| BS-33 | 8.90 | 64.7 | 0.19 | 0.8 | 3.2 | 15.3 |
| CC-1A | 9.80 | 65.0 | 0.23 | 0.8 | 3.3 | 16.0 |
| CC-1B | 12.60 | 64.8 | 0.25 | 1.0 | 4.0 | 19.4 |
| CC-2A | 11.00 | 65.0 | 0.22 | 1.0 | 3.8 | 18.3 |
| CC-2B | 20.80 | 65.0 | 0.22 | 1.9 | 7.1 | 34.6 |
| CC-2C | 4.40 | 65.0 | 0.18 | 0.7 | 2.5 | 11.5 |
| CC-3 | 52.50 | 63.1 | 0.43 | 1.8 | 8.8 | 54.5 |
| CC-4A | 108.70 | 62.6 | 0.44 | 15.4 | 39.0 | 156.0 |
| CC-4B | 8.10 | 78.1 | 0.26 | 4.0 | 7.3 | 20.6 |
| CC-4C (Pre-Dev) | 7.40 | 61.0 | 0.13 | 0.2 | 1.8 | 11.2 |
| CC-5 | 22.40 | 65.0 | 0.26 | 1.8 | 7.1 | 34.3 |
| CC-6 | 27.80 | 65.0 | 0.25 | 2.3 | 9.1 | 43.2 |
| CC-7 | 18.40 | 65.0 | 0.29 | 1.4 | 5.4 | 27.0 |

DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS

| Design Point | Contributing Basins | Q | Q | Q |
|---|--|---------|---------|---------|
| (Label) | | 2 Yr. | 5 Yr. | 100 Yr. |
| (in) | | Q (cfs) | Q (cfs) | Q (cfs) |
| DP-10 DEV | OS-8, OS-10, OS-11, BS-13, BS-14 | 10.7 | 32.0 | 143 |
| DP-11 DEV | BS-16 | 4.6 | 11.8 | 36 |
| DP-12 DEV | DP-11, BS-15 | 4.0 | 11.0 | 44 |
| TOTAL INFLOW TO POND 4 (UD Detention hydrograph) | DP-10, DP-12, BS-17, OS-9 | 10 | 16 | 217 |
| DP-13 DEV | Release from FHN Pond 4 | 0.3 | 0.3 | 142 |
| DP-14 DEV | BS-18 | 3.5 | 12.4 | 56 |
| DP-15 DEV | BS-19 | 2.1 | 4.6 | 15 |
| DP-16 DEV | DP-14, DP-15, BS-20, BS-21, BS-22, BS-23 | 25.0 | 78.0 | 362 |
| TOTAL INFLOW TO FHN POND 8 (Full Build-out) (UD Detention hydrograph) | DP-10, DP-12, BS-17, OS-9 | 24 | 37 | 390 |
| DP-17 DEV (Full Build-out) | Release from FHN Pond 8 | 0.8 | 1.0 | 253 |
| TOTAL INFLOW TO FHN POND 8 (Filling 1 Only) (UD Detention hydrograph) | DP-10, DP-12, BS-17, OS-9 | 9 | 14 | 301 |
| DP-17 DEV (Filling 1 Only) | Release from FHN Pond 8 | 0.4 | 0.5 | 219 |
| DP-18 DEV | BS-28, BS-29, BS-30, OS-18 | 5.0 | 21.6 | 115 |
| DP-19 DEV | BS-27, OS-17, Release from DP-18 | 3.8 | 16.8 | 126 |
| DP-20 DEV | CC-1A, OS-12 | 3.2 | 14.3 | 88 |
| DP-21 DEV | CC-2A, OS-13 | 2.1 | 10.5 | 62 |
| DP-22 DEV | CC-2B, Release from DP-21 | 3.7 | 16.6 | 92 |
| DP-23 DEV | CC-3, OS-14 | 2.5 | 13.0 | 84 |
| DP-24 DEV | CC-4C (Pre-Dev), CC-5 | 1.9 | 8.4 | 45 |
| TOTAL INFLOW TO POND 12 (UD Detention hydrograph) | CC-4C, CC-5, CC-6 | 4 | 17 | 86 |
| DP-25 DEV | Release from FHN Pond 12 | 0.2 | 0.3 | 45 |

LEGEND

| DESCRIPTION | SYMBOL |
|-----------------------------------|--------|
| EXISTING GROUND CONTOUR | 6910 |
| PROPOSED FINISHED CONTOUR | 6910 |
| BASIN BOUNDARY EAST CHERRY CREEK | --- |
| MAJOR BASIN BOUNDARY | --- |
| BASIN BOUNDARY BLACK SQUIRREL | --- |
| DESIGN POINT | 3 |
| LOTS WITH CULVERT DESIGN REQUIRED | * |
| BASIN IDENTIFIER | BB |
| AREA IN ACRES | 10.0 |
| EXISTING DIRECTION OF FLOW | → |
| PROPOSED DIRECTION OF FLOW | → |
| STORM SEWER | --- |
| FILING NO. 1 PLAT AREA | --- |



FLYING HORSE NORTH
PRELIMINARY/FINAL DRAINAGE REPORT
FILING NO. 1 DRAINAGE MAP

| | | | | |
|-------------|--------------|---------------|--------|----------|
| DESIGNED BY | MAW | SCALE | DATE | 10-25-17 |
| DRAWN BY | MAW | (H) 1" = 200' | SHEET | 2 OF 4 |
| CHECKED BY | (V) 1" = N/A | JOB NO. | 109611 | |

619 N. Cascade Avenue, Suite 200
Colorado Springs, Colorado 80903

(719)785-0790
(719)785-0799 (Fax)

CLASSIC
CONSULTING
ENGINEERS & SURVEYORS

MATCH LINE - SEE SHEET 4

BASIN SUMMARY - DEVELOPED CONDITIONS


| BASIN (label) | AREA (acres) | COMPOSITE CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|-----------------|--------------|--------------|------------------------|---------------|---------------|-----------------|
| OS-8 | 14.20 | 65.0 | 0.27 | 2.1 | 6.2 | 24.7 |
| OS-9 | 9.80 | 60.0 | 0.37 | 0.1 | 1.0 | 9.1 |
| OS-10 | 4.10 | 65.0 | 0.17 | 0.7 | 2.1 | 8.2 |
| OS-11 | 28.00 | 65.0 | 0.35 | 2.4 | 8.2 | 38.7 |
| OS-12 | 68.10 | 62.7 | 0.37 | 2.2 | 11.9 | 75.8 |
| OS-13 | 36.90 | 63.0 | 0.33 | 1.4 | 7.4 | 45.0 |
| OS-14 | 26.40 | 62.0 | 0.31 | 0.7 | 4.6 | 31.0 |
| OS-15 | 70.80 | 63.9 | 0.38 | 3.3 | 14.8 | 84.2 |
| OS-16 | 4.50 | 65.0 | 0.24 | 0.4 | 1.5 | 7.2 |
| OS-17 | 15.80 | 65.0 | 0.19 | 1.6 | 5.9 | 27.7 |
| OS-18 | 13.00 | 65.0 | 0.20 | 1.3 | 4.7 | 22.6 |
| CC-1A | 9.80 | 65.0 | 0.23 | 0.8 | 3.3 | 16.0 |
| CC-1B | 12.60 | 64.8 | 0.25 | 1.0 | 4.0 | 19.4 |
| CC-2A | 11.00 | 65.0 | 0.22 | 1.0 | 3.8 | 18.3 |
| CC-2B | 20.80 | 65.0 | 0.22 | 1.9 | 7.1 | 34.6 |
| CC-2C | 6.40 | 65.0 | 0.18 | 0.7 | 2.5 | 11.5 |
| CC-3 | 52.50 | 63.1 | 0.43 | 1.8 | 8.8 | 54.5 |
| CC-4A | 108.70 | 62.6 | 0.44 | 15.4 | 39.0 | 156.0 |
| CC-4B | 8.10 | 76.1 | 0.26 | 4.0 | 7.3 | 20.6 |
| CC-4C (Pre-Dev) | 7.40 | 61.0 | 0.13 | 0.2 | 1.8 | 11.2 |
| CC-5 | 22.40 | 65.0 | 0.26 | 1.8 | 7.1 | 34.3 |
| CC-6 | 27.80 | 65.0 | 0.25 | 2.3 | 9.1 | 43.2 |
| CC-7 | 18.40 | 65.0 | 0.29 | 1.4 | 5.4 | 27.0 |
| CC-8 | 7.70 | 65.0 | 0.25 | 0.4 | 1.5 | 7.2 |
| CC-9 | 5.60 | 65.0 | 0.19 | 0.6 | 2.1 | 9.8 |
| CC-10 | 85.60 | 62.6 | 0.39 | 2.6 | 14.1 | 91.9 |
| CC-11 | 18.60 | 63.1 | 0.21 | 0.9 | 5.0 | 28.1 |
| CC-12 | 12.20 | 65.0 | 0.26 | 1.0 | 3.9 | 18.7 |
| CC-13A | 19.30 | 65.0 | 0.31 | 1.4 | 5.4 | 27.3 |
| CC-13B | 25.50 | 65.0 | 0.31 | 1.8 | 7.2 | 36.1 |
| CC-13C | 9.90 | 65.0 | 0.22 | 0.9 | 3.4 | 16.5 |
| CC-13D | 18.80 | 65.0 | 0.25 | 1.5 | 6.2 | 29.2 |
| CC-14 | 4.60 | 65.0 | 0.21 | 0.4 | 1.6 | 7.5 |
| CC-15 | 12.80 | 65.0 | 0.24 | 1.1 | 4.3 | 20.4 |
| CC-16 | 16.30 | 65.0 | 0.30 | 1.2 | 4.6 | 23.6 |
| CC-17 | 22.00 | 65.0 | 0.35 | 1.7 | 6.5 | 32.8 |
| CC-18 | 6.20 | 66.5 | 0.30 | 0.7 | 2.2 | 9.7 |
| CC-19 | 3.70 | 65.0 | 0.25 | 0.3 | 1.2 | 5.8 |
| CC-20 | 39.30 | 65.0 | 0.25 | 3.2 | 12.9 | 61.0 |
| CC-21 | 6.20 | 61.0 | 0.20 | 0.1 | 1.2 | 8.5 |
| CC-22 | 13.80 | 65.0 | 0.25 | 1.1 | 4.5 | 21.4 |
| CC-23 | 5.70 | 64.7 | 0.33 | 0.4 | 1.5 | 7.7 |
| CC-24 | 39.60 | 65.0 | 0.25 | 3.3 | 13.0 | 61.5 |
| CC-25 | 3.50 | 65.0 | 0.23 | 0.3 | 1.2 | 5.7 |
| CC-26 | 10.70 | 65.0 | 0.26 | 1.4 | 5.3 | 26.6 |
| CC-27 | 18.90 | 64.4 | 0.31 | 1.2 | 4.9 | 25.8 |
| CC-28 | 154.80 | 64.4 | 0.63 | 6.5 | 24.7 | 136.3 |

DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS

| Design Point (label) | Contributing Basins | Q 2 Yr. Q (cfs) | Q 5 Yr. Q (cfs) | Q 100 Yr. Q (cfs) |
|---|--|-----------------|-----------------|-------------------|
| DP-20 DEV | CC-1A, OS-12 | 3.2 | 14.3 | 88 |
| DP-21 DEV | CC-2A, OS-13 | 2.1 | 10.5 | 62 |
| DP-22 DEV | CC-2B, Release from DP-21 | 3.7 | 16.6 | 92 |
| DP-23 DEV | CC-3, OS-14 | 2.5 | 13.0 | 84 |
| DP-24 DEV | CC-4C (Pre-Dev), CC-5 | 1.9 | 8.4 | 45 |
| TOTAL INFLOW TO POND 12 (UD Detention hydrograph) | CC-4C, CC-5, CC-6 | 6 | 9 | 85 |
| DP-25 DEV | Release from FHN Pond 12 | 0.2 | 0.3 | 45 |
| DP-26 DEV | CC-8, CC-10 | 3.0 | 15.9 | 102 |
| DP-27 DEV | CC-15, CC-20 | 4.3 | 17.2 | 81 |
| DP-28 DEV | CC-13A, OS-15 | 4.6 | 19.8 | 110 |
| DP-29 DEV | CC-13B, CC-13C, Release from DP-28 | 5.8 | 26.6 | 155 |
| DP-30 DEV | CC-18 | 0.7 | 2.2 | 10 |
| DP-31 DEV | CC-19, Release from DP-30 | 0.9 | 3.2 | 15 |
| DP-32 DEV | CC-17, OS-16 | 2.0 | 7.8 | 40 |
| DP-33 DEV | CC-23, CC-24 | 3.6 | 14.4 | 69 |
| DP-34 DEV | CC-26, CC-27, CC-28 and Release from CC-16 & DP-32 | 6.0 | 23.5 | 168 |

LEGEND

| DESCRIPTION | SYMBOL |
|----------------------------------|---------|
| EXISTING GROUND CONTOUR | 6910 |
| PROPOSED FINISHED CONTOUR | 6910 |
| BASIN BOUNDARY EAST CHERRY CREEK | --- |
| MAJOR BASIN BOUNDARY | --- |
| DESIGN POINT | 3 |
| BASIN IDENTIFIER | BB 10.0 |
| AREA IN ACRES | |
| EXISTING DIRECTION OF FLOW | → |
| PROPOSED DIRECTION OF FLOW | → |
| STORM SEWER | --- |
| FILING NO. 1 PLAT AREA | |



SCALE: 1" = 200'



FLYING HORSE NORTH
PRELIMINARY/FINAL DRAINAGE REPORT
FILING NO. 1 AND
PRELIMINARY PLAN DRAINAGE MAP

| | | | | |
|-------------|---------|---------------|---------|----------|
| DESIGNED BY | MAW | SCALE | DATE | 10-25-17 |
| DRAWN BY | MAW | (H) 1" = 200' | SHEET | 3 OF 4 |
| CHECKED BY | (V) N/A | JOB NO. | 1096.11 | |


619 N. Cascade Avenue, Suite 200
Colorado Springs, Colorado 80903

(719) 785-0790
(719) 785-0799 (Fax)



MATCH LINE - SEE SHEET 2

MATCH LINE - SEE SHEET 2



BASIN SUMMARY - DEVELOPED CONDITIONS

| BASIN (label) | AREA (acres) | COMPOSITE CN | TOTAL LAG TIME (hours) | Q 2 Yr. (cfs) | Q 5 Yr. (cfs) | Q 100 Yr. (cfs) |
|---------------|--------------|--------------|------------------------|---------------|---------------|-----------------|
| OS-16 | 4.50 | 65.0 | 0.24 | 0.4 | 1.5 | 7.2 |
| OS-17 | 15.80 | 65.0 | 0.19 | 1.6 | 5.9 | 27.7 |
| OS-18 | 13.00 | 65.0 | 0.20 | 1.3 | 4.7 | 22.6 |
| CC-11 | 18.60 | 63.1 | 0.21 | 0.9 | 5.0 | 28.1 |
| CC-12 | 12.20 | 65.0 | 0.26 | 1.0 | 3.9 | 18.7 |
| CC-13A | 19.30 | 65.0 | 0.31 | 1.4 | 5.4 | 27.3 |
| CC-13B | 25.50 | 65.0 | 0.31 | 1.8 | 7.2 | 36.1 |
| CC-13C | 9.90 | 65.0 | 0.22 | 0.9 | 3.4 | 16.5 |
| CC-13D | 18.80 | 65.0 | 0.25 | 1.5 | 6.2 | 29.2 |
| CC-14 | 4.60 | 65.0 | 0.21 | 0.4 | 1.6 | 7.8 |
| CC-15 | 12.80 | 65.0 | 0.24 | 1.1 | 4.3 | 20.4 |
| CC-16 | 16.30 | 65.0 | 0.30 | 1.2 | 4.6 | 23.6 |
| CC-17 | 25.00 | 65.0 | 0.35 | 1.7 | 6.5 | 32.8 |
| CC-18 | 6.20 | 66.5 | 0.30 | 0.7 | 2.2 | 9.7 |
| CC-19 | 3.70 | 65.0 | 0.25 | 0.3 | 1.2 | 5.8 |
| CC-20 | 39.30 | 65.0 | 0.25 | 3.2 | 12.9 | 61.0 |
| CC-21 | 6.20 | 61.0 | 0.20 | 0.1 | 1.2 | 8.5 |
| CC-22 | 13.80 | 65.0 | 0.25 | 1.1 | 4.5 | 21.4 |
| CC-23 | 5.70 | 64.7 | 0.33 | 0.4 | 1.5 | 7.7 |
| CC-24 | 39.60 | 65.0 | 0.25 | 3.3 | 13.0 | 61.5 |
| CC-25 | 3.50 | 65.0 | 0.23 | 0.3 | 1.2 | 5.7 |
| CC-26 | 16.70 | 65.0 | 0.26 | 1.4 | 5.3 | 25.6 |
| CC-27 | 18.90 | 64.4 | 0.31 | 1.2 | 4.9 | 25.8 |
| CC-28 | 154.80 | 64.4 | 0.63 | 6.5 | 24.7 | 136.3 |

DESIGN POINTS SURFACE ROUTING SUMMARY - DEVELOPED CONDITIONS

| Design Point (label) | Contributing Basins | Q 2 Yr. Q (cfs) | Q 5 Yr. Q (cfs) | Q 100 Yr. Q (cfs) |
|----------------------|--|-----------------|-----------------|-------------------|
| DP-27 DEV | CC-15, CC-20 | 4.3 | 17.2 | 81 |
| DP-28 DEV | CC-13A, OS-15 | 4.6 | 19.8 | 110 |
| DP-29 DEV | CC-13B, CC-13C, Release from DP-28 | 5.8 | 26.6 | 155 |
| DP-30 DEV | CC-18 | 0.7 | 2.2 | 10 |
| DP-31 DEV | CC-19, Release from DP-30 | 0.9 | 3.2 | 15 |
| DP-32 DEV | CC-17, OS-16 | 2.0 | 7.8 | 40 |
| DP-33 DEV | CC-23, CC-24 | 3.6 | 14.4 | 69 |
| DP-34 DEV | CC-26, CC-27, CC-28 and Release from CC-16 & DP-32 | 6.0 | 23.5 | 168 |

LEGEND

DESCRIPTION

SYMBOL

EXISTING GROUND CONTOUR

6910

PROPOSED FINISHED CONTOUR

6910

BASIN BOUNDARY EAST CHERRY CREEK

MAJOR BASIN BOUNDARY

BASIN BOUNDARY BLACK SQUIRREL

DESIGN POINT

BASIN IDENTIFIER

AREA IN ACRES

EXISTING DIRECTION OF FLOW

PROPOSED DIRECTION OF FLOW

STORM SEWER

FILING NO. 1 PLAT AREA

200 100 0 200 400

SCALE: 1" = 200'

CLASSIC CONSULTING ENGINEERS & SURVEYORS

619 N. Cascade Avenue, Suite 200
Colorado Springs, Colorado 80903

(719)785-0790
(719)785-0799 (Fax)

FLYING HORSE NORTH PRELIMINARY/FINAL DRAINAGE REPORT

FILING NO. 1 AND PRELIMINARY PLAN DRAINAGE MAP

DESIGNED BY: MAW SCALE: DATE: 10-17-17

DRAWN BY: MAW (H) 1"= 200' SHEET 4 OF 4

CHECKED BY: (V) 1"= N/A JOB NO. 1096.11

CLASSIC CONSULTING ENGINEERS & SURVEYORS