



September 11, 2019


To whom it may concern,

Mountain View Electric Association has reviewed the plans and specifications for **6.8 kW A.C. Photovoltaic** system to be installed by Home Owner at 7480 Shoup Rd (Moore,J). The design **(1)**, and equipment meet the installation requirements of MVEA's Interconnection Policy. **The application will be good for 1 year from the date of this letter.**

We have instructed the member/contractor to obtain all necessary permits, including electrical, prior to starting this installation. We have requested the owner/installer to notify MVEA with the electrical permit number and projected completion date, so we can track the process.

The proposed Qualifying Facility will not be interconnected to the Association's system until it has established, to the satisfaction of the Association, that it complies with and has met all applicable rules set forth in the Qualifying Facilities Policy.

Respectfully Submitted,



(MVEA)



(Owner/Contractor)

Released for Permit
08/24/2020 7:55:40 AM



shelby
ELECTRICAL

- (1)** - Includes an A/C Safety Switch/Mechanical Disconnect, with a visual open mechanism and externally operated handle, Square D, DU221RB Safety Switch Safety Switch, 240VAC, General Duty, 2-Pole or equal, located Outside, S.E. side of house. (Cannot be behind fence, obstructions, etc.) And must be accessible. MVEA has no additional metering requirements