

ENTECH
ENGINEERING, INC.

505 ELKTON DRIVE
COLORADO SPRINGS, CO 80907
PHONE (719) 531-5599
FAX (719) 531-5238

April 16, 2018

Classic Communities
6385 Corporate Drive, Suite 200
Colorado Springs, CO 80919

Attn: Benny Bustos

Re: Moisture Density Relation Curve
Forest Lakes Filing 2, Phase 2B
Colorado Springs, Colorado
Proctor No. 3

Dear Mr. Buston:

As requested, personnel of Entech Engineering, Inc. have performed moisture density relation testing at the above referenced site.

Moisture density relation testing on this site was performed on April 12, 2018. Results of the moisture density relation curve are enclosed with this letter.

We trust that this has provided you with the information you require. Should you have any questions or need further information, please do not hesitate to contact us.

Respectfully Submitted,


ENTECH ENGINEERING, INC.

MH Hauschild
Mark H. Hauschild, P.E.
Senior Engineer

MHH/sif


Encl.

Entech Job No. 152314
F:\AA projects\2015\152314\152314mc3.doc



PROJECT	FOREST LAKES, F-2B	CLIENT	CLASSIC COMMUNITIES
SAMPLE LOCATION	LOT 18, LAKES EDGE	JOB NO.	152314
SOIL DESCRIPTION	SAND, SILTY, BROWN	DATE	04/12/18

IDENTIFICATION	SM	PROCTOR TEST #	3
TEST DESIGNATION / METHOD	ASTM D-1557-A	TEST BY	DC
MAXIMUM DRY DENSITY (PCF)	134.1	OPTIMUM MOISTURE	6.9%




ENTECH
ENGINEERING, INC.
505 ELKTON DRIVE
COLORADO SPRINGS, COLORADO 80907

MOISTURE DENSITY RELATION

DRAWN:	DATE:	CHECKED:	DATE:
--------	-------	----------	-------

JOB NO.:

FIG NO.: