



ENTECH
ENGINEERING, INC.

505 ELKTON DRIVE
COLORADO SPRINGS, CO 80907
PHONE (719) 531-5599
FAX (719) 531-5238

February 8, 2018

Classic Communities
6385 Corporate Drive #200
Colorado Springs, CO 80919

Attn: Mark Sherwood

Re: Moisture Density Relation Curve
Forest Lakes, Filing 2B-1
Colorado Springs, Colorado
Proctor No. 2

Dear Mr. Sherwood :

As requested, personnel of Entech Engineering, Inc. have performed moisture density relation testing at the above referenced site.

Moisture density relation testing on this site was performed on January 19, 2018. Results of the moisture density relation curve are enclosed with this letter.

We trust that this has provided you with the information you require. Should you have any questions or need further information, please do not hesitate to contact us.

Respectfully Submitted,


ENTECH ENGINEERING, INC.

Mark H. Hauschild
Mark H. Hauschild, P.E.
Senior Engineer

MHH/slf


Encl.

Entech Job No. 171427
F:\AA projects\2017\171427\171427mcl2.doc



PROJECT	FOREST LAKES, FILING 2B	CLIENT	CLASSIC COMMUNITIES
SAMPLE LOCATION	LAKE RIDGE, LOT 13	JOB NO.	171427
SOIL DESCRIPTION	SAND, SILTY, CLAYEY, BROWN	DATE	01/19/18

IDENTIFICATION	SM-SC	PROCTOR TEST #	2
TEST DESIGNATION / METHOD	ASTM D-1557-A	TEST BY	AS
MAXIMUM DRY DENSITY (PCF)	127.6	OPTIMUM MOISTURE	7.5%



ENTECH
ENGINEERING, INC.

505 ELKTON DRIVE
COLORADO SPRINGS, COLORADO 80907

MOISTURE DENSITY RELATION

DRAWN:

DATE:

CHECKED:

DATE:

JOB NO.:

171427

FIG NO.: