



**ENTECH**  
ENGINEERING, INC.

505 ELKTON DRIVE  
COLORADO SPRINGS, CO 80907  
PHONE (719) 531-5599  
FAX (719) 531-5238

April 4, 2018

Classic Communities  
6385 Corporate Drive, Suite 200  
Colorado Springs, Colorado 80919

Attn: Benny Bustos

Re: Density Testing – Curb and Gutter  
Forest Lakes, Filing 2, Phase 2B  
Colorado Springs, Colorado  
Report No. 2, Tests 14 – 17

Dear Mr. Bustos:

As requested, personnel of Entech Engineering, Inc. have performed density testing at the above referenced site.

Density testing on this site was performed on April 3, 2018. The density testing indicates that the materials have been adequately compacted at the depths and in the locations noted. Results of the density tests are enclosed with this letter.

We trust that this has provided you with the information you require. Should you have any questions or need further information, please do not hesitate to contact us.

Respectfully Submitted,


ENTECH ENGINEERING, INC.

*MH Hauschild*  
Mark H. Hauschild, P.E.  
Senior Engineer

MHH/slf

Enclosure

Entech Job No. 152314  
F:\AA projects\2015\152314\152314.6cl2.doc



<b>Client:</b> Classic Communities	<b>Entech Job #:</b> 152314.6	<b>Proctor Value Key:</b> M = modified, ASTM D-1557
<b>Project:</b> Forest Lakes Filing 2, Phase 2B	<b>Tested By:</b> S. Reardanz	S = standard, ASTM D-698
<b>Subject:</b> Curb and Gutter	<b>Report Date:</b> 04-04-2018	T = AASHTO, T-180

Test #	Test Location	Testing Date	Percent Compaction	Percent Required	Percent Moisture	Soil Type	Proctor Type/Value	Pass/Fail
14	Lake Mist Drive, 15' west off property line of lots 2 & 3, at grade.	4/3/18	96	95	8.3	SM	M - 130.9 @ 8.2	<input type="checkbox"/>
15	Lake Mist Drive, 5' east off property line of lots 26 & 27, at grade.	4/3/18	100	95	8.6	SM	M - 130.9 @ 8.2	<input type="checkbox"/>
16	Lake Mist Drive, property line of lots 23 & 24, at grade.	4/3/18	97	95	8.0	SM	M - 130.9 @ 8.2	<input type="checkbox"/>
17	Lakes Edge Drive, 10' north off property line of lots 13 & 14, at grade.	4/3/18	96	95	7.9	SM	M - 130.9 @ 8.2	<input type="checkbox"/>

**Comments:**

Scope of Observation: PERIODIC; CONTRACTOR'S OR CLIENT'S REPRESENTATIVE ADVISED

All dimensions are approximate. Cl. = Centerline



**ENTECH**  
ENGINEERING, INC.  
505 Elkton Drive  
Colorado Springs, CO 80907  
(719) 531-5599 • (719) 531-5238 (fax)

FIELD DENSITY RESULTS

*Mark H. Hauschild*  
Mark H. Hauschild, P.E.