



**ENTECH**  
ENGINEERING, INC.

505 ELKTON DRIVE  
COLORADO SPRINGS, CO 80907  
PHONE (719) 531-5599  
FAX (719) 531-5238

February 1, 2018

Classic Communities  
6385 Corporate Drive #200  
Colorado Springs, CO 80919

Attn: Mark Sherwood

Re: Density Testing – Overlot  
Forest Lakes, Filing 2B-1  
Colorado Springs, Colorado  
Report No. 6, Tests 63 – 74

Dear Mr. Sherwood,

As requested, personnel of Entech Engineering, Inc. have performed density testing at the above referenced site.

Density testing on this site was performed on January 17 – 19, and 24 - 25, 2018. The density testing indicates that the materials have been adequately compacted at the depths and in the locations noted. Results of the density tests are enclosed with this letter.

We trust that this has provided you with the information you require. Should you have any questions or need further information, please do not hesitate to contact us.

Respectfully Submitted,

ENTECH ENGINEERING, INC.


*Mark H. Hauschild*  
Mark H. Hauschild, P.E.  
Senior Engineer

MHH/slf

Enclosure

Entech Job No. 171427

F:\AA projects\2017\171427\171427.1ci7.doc4



<b>Client:</b> Classic Communities	<b>Entech Job #:</b> 171427.1	<b>Proctor Value Key:</b> M = modified, ASTM D-1557
<b>Project:</b> Forest Lakes, Filing 2B-1	<b>Tested By:</b> S, Reardanz	S = standard, ASTM D-698
<b>Subject:</b> Overlot	<b>Report Date:</b> 02-01-2018	T = AASHTO, T-180

Test #	Test Location	Testing Date	Percent Compaction	Percent Required	Percent Moisture	Soil Type	Proctor Type/Value	Pass/Fail
63	Lot #9, center of lot, Lakes Edge Drive, at grade.	1/17/18	98	95	8.5	SM	M - 127.0 @ 9.9	<input type="checkbox"/>
64	Lot #10, center of lot, Lakes Edge Drive, at grade.	1/17/18	98	95	9.2	SM	M - 127.0 @ 9.9	<input type="checkbox"/>
65	Lot #12, center of lot, Lakes Edge Drive, at grade.	1/17/18	99	95	9.6	SM	M - 127.0 @ 9.9	<input type="checkbox"/>
66	Lot #13, Lakes Edge Drive, west side of lot, 4' below grade.	1/18/18	97	95	8.8	SM	M - 127.0 @ 9.9	<input type="checkbox"/>
67	Lot #13, Lakes Edge Drive, west side of lot, 2' below grade.	1/18/18	98	95	9.3	SM	M - 127.0 @ 9.9	<input type="checkbox"/>
68	Lot #13, Lakes Edge Drive, west side of lot, at grade.	1/18/18	97	95	8.9	SM	M - 127.0 @ 9.9	<input type="checkbox"/>
69	Lot #8, Long Valley Drive, east side of lot, 9' below grade.	1/19/18	97	95	7.9	SM/SC	M - 127.6 @ 7.5	<input type="checkbox"/>
70	Lot #7, Long Valley Drive, east side of lot, 9' below grade.	1/19/18	98	95	7.7	SM/SC	M - 127.6 @ 7.5	<input type="checkbox"/>
71	Lot #8, Long Valley Drive, east side of lot, 7' below grade.	1/24/18	97	95	8.9	SM	M - 127.0 @ 9.9	<input type="checkbox"/>
72	Lot #7, Long Valley Drive, east side of lot, 7' below grade.	1/24/18	97	95	9.1	SM	M - 127.0 @ 9.9	<input type="checkbox"/>

**Comments:**

Scope of Observation: PERIODIC; CONTRACTOR'S OR CLIENT'S REPRESENTATIVE ADVISED

All dimensions are approximate. Cl. = Centerline

 <p><b>ENTECH ENGINEERING, INC.</b> 505 Elkton Drive Colorado Springs, CO 80907 (719) 531-5599 • (719) 531-5238 (fax)</p>	<p><b>FIELD DENSITY RESULTS</b></p>	<p><i>Mark H. Hauschild</i> Mark H. Hauschild, P.E.</p>
--	-------------------------------------	---

<b>Client:</b> Classic Communities	<b>Entech Job #:</b> 171427.1	<b>Proctor Value Key:</b> M = modified, ASTM D-1557
<b>Project:</b> Forest Lakes, Filing 2B-1	<b>Tested By:</b> S, Reardanz	S = standard, ASTM D-698
<b>Subject:</b> Overlot	<b>Report Date:</b> 02-01-2018	T = AASHTO, T-180

Test #	Test Location	Testing Date	Percent Compaction	Percent Required	Percent Moisture	Soil Type	Proctor Type/Value	Proctor	Pass/Fail
73	Lot #8, Long Valley Drive, east side of lot, 5' below grade.	1/25/18	99	95	9.5	SM	M - 127.0 @ 9.9		<input type="checkbox"/>
74	Lot #7, Long Valley Drive, east side of lot, 5' below grade.	1/25/18	97	95	9.0	SM	M - 127.0 @ 9.9		<input type="checkbox"/>

**Comments:**

Scope of Observation: PERIODIC; CONTRACTOR'S OR CLIENT'S REPRESENTATIVE ADVISED

All dimensions are approximate. Cl. = Centerline



**ENTECH**  
**ENGINEERING, INC.**  
 505 Elkton Drive  
 Colorado Springs, CO 80907  
 (719) 531-5599 • (719) 531-5238 (fax)

**FIELD DENSITY RESULTS**

*Mark H. Hauschild*  
 Mark H. Hauschild, P.E.