



October 28, 2020

Lindsay Darden  
Project Manager  
El Paso County Dev Services Department  
2880 International Circle  
Colorado Springs, CO 80910-6107

Dear Ms. Darden:

Mountain View Electric Association, Inc. (MVEA) has these comments about the following:

**Project Name: Crossroads SBC New Building**

**Project Number: PPR 2039**

**Description:** Addition of new building and paved parking to support number of seats in existing sanctuary at Crossroads Chapel. Existing modular building will be removed after new building is occupiable. This proposed addition is located at 840 Northgate Blvd in Section 05, Township 12 South, Range 66 West.

This area is within MVEA certificated service area. MVEA will continue to serve this lot according to our extension policy. Information concerning connection requirements, fees and upgrades under MVEA line extension policy can be obtained by contacting the Engineering Department of MVEA.

MVEA has existing facilities within this parcel of land. If there is any removal or relocation of facilities it will be at the expense of the applicant. MVEA requests no trees or shrubs be planted, or placing of sound barrier walls/fences within ten (10) feet of any existing or newly constructed electrical facilities.

If additional information is required, please contact our office at (719) 495-2283.

Sincerely,

Cathy Hansen-Lee  
Engineering Administrative Assistant

This Association is an equal opportunity provider and employer.

