



Concrete Test

Client:**Project:**

Classic Communities
2138 Flying Horse Club Drive
Colorado Springs, CO 80921

202751
Hannah Ridge F5
Hannah Ridge F5
Colorado Springs, CO

Entech Engineering
505 Elkton Dr
Colorado Springs, CO 80907
Phone: 719-531-5599

Set #: 1 **Sample #:** 310 **Placement Date:** 02/20/2024 **Technician:** Devin Brady **Weather Conditions:** Sunny **Air Temp (°F):** 57

Contractor: PPC Construction **Supplier:** Pete Lien **Mix Design:** 90DJ50 **Specified Strength (psi):** 4500

Placement Location: Sidewalk **Location Details:** 20' E. and 15' S. off the NE corner of house @ 2754 Equine Ct. **Lat/Long:** 38.87247741 / -104.68891099

PLACEMENT DATA

Set #	Truck # Ticket #	Load Vol (yd³)	Slump (in)	Air Content (%)	Unit Weight (lb/ft³)	Concrete Temp (°F)	Air Temp (°F)
1	20-00318 63116	5.00	Slump: Spec: 3 - 5	Result: 5 Spec.: 5 - 8	141.8	66	57

STRENGTH DATA

Set / Test	Age (days)	Test Date	Strength (psi)	Remark	Fracture Pattern
1 / 109 1	7	02/27/2024	3580		Type 2

03/12/2024

Reviewed by: Dylan Gassmann, PE