



CDR21013-R1-GEC.pdf Markup Summary

1 (5)




Subject: Contractor
Page Index: 1
Date: 10/6/2021 7:29:11 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 1

Add: CDR2113




Subject: Contractor
Page Index: 1
Date: 10/6/2021 7:59:53 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 1

Volumes 1 and 2




Subject: Contractor
Page Index: 1
Date: 10/6/2021 8:03:38 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 1

Revise to checklist item "ff"



Subject: Contractor
Page Index: 1
Date: 10/6/2021 8:03:50 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 1


Revise to checklist item "hh"



Subject: Contractor
Page Index: 1
Date: 10/6/2021 8:35:22 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 1


please label a couple more streets to make it more clear where exactly this project (more similar to the vicinity map that is on the cover sheet of the CD's)

2 (14)




Subject: Contractor
Page Index: 2
Date: 10/6/2021 8:22:32 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

Linetype is missing for limits of grading on Legend and plans.




Subject: Contractor
Page Index: 2
Date: 10/6/2021 9:05:50 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

- Checklist Item "b" - label some of the streets and subdivisions shown on this sheet.
- Checklist Item "p" - delineate areas of cut/fill. A summarizing note is acceptable.




Subject: Contractor
Page Index: 2
Date: 10/6/2021 8:20:45 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

add drainage flow arrows to Legend




Subject: Contractor
Page Index: 2
Date: 10/6/2021 8:26:36 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

- If there is no VTC here (per Note 5 on this sheet), remove this bubble.
- Same for the CWA and SSA bubbles (per Note 1 on this sheet)




Subject: Contractor
Page Index: 2
Date: 10/6/2021 8:59:39 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

label grade of steep slopes. And if 3:1 or greater, label with ECB bubble. Otherwise, if no ECB is to be used here, consider the need for other BMPs like silt fence or sediment control logs.




Subject: Polygon
Page Index: 2
Date: 10/6/2021 9:00:35 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

connect proposed contours to existing.




Subject: Contractor
Page Index: 2
Date: 10/6/2021 9:01:02 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2




Subject: Contractor
Page Index: 2
Date: 10/6/2021 9:02:00 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

connect proposed contours to existing.




Subject: Contractor
Page Index: 2
Date: 10/6/2021 9:02:54 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

label where this is located on the plans or remove if not applicable to this project.




Subject: Contractor
Page Index: 2
Date: 10/6/2021 9:03:18 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

label pond




Subject: Contractor
Page Index: 2
Date: 10/6/2021 9:32:35 AM
Author: EPC Stormwater - Glenn Reese
Color: ■
Layer:
Space:
Page Label: 2

Show locations of SCL and IP on plans.



Subject: Cloud+
Page Index: 2
Date: 10/21/2021 12:08:08 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 2

Show proposed reseeding, blanketing, etc. in the graded channel bottom area



Subject: Callout
Page Index: 2
Date: 10/21/2021 12:08:20 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 2

Show riprap

