



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**11130 Burgess Lane AQL, AL-24-13**

Please accept the following comments from El Paso County Public Health for the project referenced above:

- **Water service for both dwellings is unknown and not specified in the submittal. Likely by private well(s).**
- **Wastewater services for the dwellings was not specified; however, a 1979 OWTS diagram was included and is likely the OWTS of the original dwelling.**
- **The new livable structure would require either a new individual OWTS to support the structure or will need to go through the OWTS verification process to determine if the existing OWTS supporting the current structure could be sufficient for the additional flow.**
- **OWTS systems are designed permitted and approved based on the number of bedrooms within the structure – once approved the approval remains in effect until, they either remodel the structure, add a structure, or the system itself requires repair. At which time the system as existing would need to come into compliance with current regulations for the change occurring.**

**Mike McCarthy**  
**El Paso County Public Health**  
**719-332-5771**  
**[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)**  
**30August2024**