



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Woodmen Hills Regional Water Reclamation (Updated Comments),
PPR-17-027

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- **The wastewater treatment facility has been shown to be in compliance with the Design Criteria of the Colorado Department of Public Health and Environment, Water Quality Control Division.**
- **Earthmoving activity greater than 1 acre will require a Construction Activity Permit from El Paso County Public Health. Go to <http://www.elpasocountyhealth.org/service/air-quality> for more information.**

Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
04Aug2017