



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**2104 LLC, PPR-19-052**

Please accept the following comments from El Paso County Public Health regarding the sand mining expansion project referenced above:

- Water service is proposed to be provided to the two full time onsite employees by bottled water.
- Wastewater service is proposed to be provided by a sealed holding vault and a contracted service company. The holding vault requires a New Onsite Wastewater Treatment System (OWTS) Permit from El Paso County Public Health. The OWTS must be designed by a Colorado Registered Professional Engineer because the operation is commercial.
- The property is within the Garden Valley Water and Sanitation District boundaries. Verification that connecting to the District's wastewater collection system is not feasible is required in order for El Paso County Public Health to issue a permit for the proposed holding vault.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information. Earthmoving activities greater than 25 acres require a Construction Activity Permit from the Colorado Department of Public Health and Environment, Air Pollution Control Division. Go to: <https://www.colorado.gov/pacific/cdphe/general-air-permits>

Mike McCarthy  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
09Feb2020