



Planning and Community
Development Department
2880 International Circle
Colorado Springs, Colorado 80910
Phone: 719.520.6300
Fax: 719.520.6695
Website www.elpasoco.com

DEVIATION REQUEST AND DECISION FORM

Updated: 6/26/2019

PROJECT INFORMATION – NON-STANDARD FSD FACILITY

Project Name : Mayberry, Colorado Springs Filing No. 1
Schedule No.(s) : 34000-00-259, -260, -349, -350, -356, -362
Legal Description : Mayberry, Colorado Springs Filing No. 1

APPLICANT INFORMATION

Company : Colorado Springs Mayberry, LLC
Name : Rick Scott
☒ Owner ☐ Consultant ☐ Contractor
Mailing Address : 32823 Temecula Parkway
Temecula, CA 92592

Phone Number : 951-296-5070
FAX Number : 951-296-5071
Email Address : rick@cormanleigh.com

ENGINEER INFORMATION

Company : JPS Engineering, Inc.
Name : John P. Schwab, P.E. Colorado P.E. Number : 29891
Mailing Address : 19 E. Willamette Avenue
Colorado Springs, CO 80903

Phone Number : 719-477-9429
FAX Number : 719-471-0766
Email Address : john@jpsengr.com

OWNER, APPLICANT, AND ENGINEER DECLARATION

To the best of my knowledge, the information on this application and all additional or supplemental documentation is true, factual and complete. I am fully aware that any misrepresentation of any information on this application may be grounds for denial. I have familiarized myself with the rules, regulations and procedures with respect to preparing and filing this application. I also understand that an incorrect submittal will be cause to have the project removed from the agenda of the Planning Commission, Board of County Commissioners and/or Board of Adjustment or delay review until corrections are made, and that any approval of this application is based on the representations made in the application and may be revoked on any breach of representation or condition(s) of approval.

Signature of owner (or authorized representative)

Date

Engineer's Seal, Signature
And Date of Signature



DEVIATION REQUEST (Attach diagrams, figures, and other documentation to clarify request)

A deviation from the standards of or in Section **1.7.3** of the Engineering Criteria Manual (ECM) is requested.

Identify the specific ECM standard which a deviation is requested:

Appendix I - Stormwater Quality Policy & Procedures

Section 1.7.3 - Stormwater Detention Basins

This deviation request accounts for non-standard design aspects of the proposed Temporary Detention Basin C2.8. This detention basin has been designed as a temporary full-spectrum detention basin which will mitigate developed drainage impacts from parts of Filing No. 1 and No. 2 during the initial phases of development. Once the downstream Detention Basin D is constructed during future phases of development, this temporary detention basin will no longer be needed. Based on the temporary nature of this interim detention pond, the design does not include a forebay that would be included in a permanent detention pond, but a concrete trickle channel will be provided. The non-standard design components are justified by the temporary nature of this detention basin.

State the reason for the requested deviation:

Temporary Detention Basin C2.8 has been designed as an interim full-spectrum detention basin which will mitigate developed drainage impacts from parts of Filing No. 1 and No. 2 during the initial phases of development. Once the downstream Detention Basin D is constructed during future phases of development, this temporary detention basin will no longer be needed. The non-standard design components are justified by the temporary nature of this detention basin.

Explain the proposed alternative and compare to the ECM standards (May provide applicable regional or national standards used as basis):

Based on the temporary nature of this interim detention pond, the design does not include a forebay that would be included in a permanent detention pond, but a concrete trickle channel will be provided. The non-standard design components are justified by the temporary nature of this detention basin.

LIMITS OF CONSIDERATION

(At least one of the conditions listed below must be met for this deviation request to be considered.)

- ☒ The ECM standard is inapplicable to the particular situation.
- ☐ Topography, right-of-way, or other geographical conditions or impediments impose an undue hardship and an equivalent alternative that can accomplish the same design objective is available and does not compromise public safety or accessibility.
- ☐ A change to a standard is required to address a specific design or construction problem, and if not modified, the standard will impose an undue hardship on the applicant with little or no material benefit to the public.

Provide justification:

Forebays are standard requirements for permanent detention basins, but construction of these features would be wasteful for an interim detention basin, which will ultimately be removed when the larger downstream detention pond is constructed. The proposed temporary detention basin will include a concrete trickle channel, standard FSD outlet structure, and associated discharge facilities to properly mitigate drainage impacts from the applicable development area.

CRITERIA FOR APPROVAL

Per ECM section 5.8.7 the request for a deviation may be considered if the request is **not based exclusively on financial considerations**. The deviation must not be detrimental to public safety or surrounding property. The applicant must include supporting information demonstrating compliance with **all of the following criteria**:

The deviation will achieve the intended result with a comparable or superior design and quality of improvement.

The proposed temporary detention basin will include a concrete trickle channel, standard FSD outlet structure, and associated discharge facilities to properly mitigate developed drainage impacts from the applicable development area.

The deviation will not adversely affect safety or operations.

The requested deviation will not adversely affect safety or operations.

The deviation will not adversely affect maintenance and its associated cost.

The proposed stormwater detention facilities will be privately owned and maintained by the metropolitan district. The proposed deviation will have no impact on County maintenance.

The deviation will not adversely affect aesthetic appearance.

Aesthetic appearance will not be adversely affected based on the proposed deviation.

The deviation meets the design intent and purpose of the ECM standards.

The proposed deviation meets the design intent and purpose of the ECM standards by providing appropriate stormwater detention and water quality facilities. No deviations are proposed to the pond outlet structure and discharge facilities.

The deviation meets the control measure requirements of Part I.E.3 and Part I.E.4 of the County's MS4 permit, as applicable.

The proposed deviation meets applicable control measure requirements.

REVIEW AND RECOMMENDATION:

Approved by the ECM Administrator

This request has been determined to have met the criteria for approval. A deviation from Section _____ of the ECM is hereby granted based on the justification provided.

┌

┐

└

┘

Denied by the ECM Administrator

This request has been determined not to have met criteria for approval. A deviation from Section _____ of the ECM is hereby denied.

┌

┐

└

┘

ECM ADMINISTRATOR COMMENTS/CONDITIONS:

--

1.1. PURPOSE

The purpose of this resource is to provide a form for documenting the findings and decision by the ECM Administrator concerning a deviation request. The form is used to document the review and decision concerning a requested deviation. The request and decision concerning each deviation from a specific section of the ECM shall be recorded on a separate form.

1.2. BACKGROUND

A deviation is a critical aspect of the review process and needs to be documented to ensure that the deviations granted are applied to a specific development application in conformance with the criteria for approval and that the action is documented as such requests can point to potential needed revisions to the ECM.

1.3. APPLICABLE STATUTES AND REGULATIONS

Section 5.8 of the ECM establishes a mechanism whereby an engineering design standard can be modified when if strictly adhered to, would cause unnecessary hardship or unsafe design because of topographical or other conditions particular to the site, and that a departure may be made without destroying the intent of such provision.

1.4. APPLICABILITY

All provisions of the ECM are subject to deviation by the ECM Administrator provided that one of the following conditions is met:

- The ECM standard is inapplicable to a particular situation.
- Topography, right-of-way, or other geographical conditions or impediments impose an undue hardship on the applicant, and an equivalent alternative that can accomplish the same design objective is available and does not compromise public safety or accessibility.
- A change to a standard is required to address a specific design or construction problem, and if not modified, the standard will impose an undue hardship on the applicant with little or no material benefit to the public.

1.5. TECHNICAL GUIDANCE


The review shall ensure all criteria for approval are adequately considered and that justification for the deviation is properly documented.

1.6. LIMITS OF APPROVAL



Whether a request for deviation is approved as proposed or with conditions, the approval is for project-specific use and shall not constitute a precedent or general deviation from these Standards.

1.7. REVIEW FEES

A Deviation Review Fee shall be paid in full at the time of submission of a request for deviation. The fee for Deviation Review shall be as determined by resolution of the BoCC.



C:\Users\Owner\Dropbox\ipsprojects\090001.EllicottTC\dwg\Civil\GEC\C1.6.dwg Apr 23 2020 - 8:55am



revise to match
calculations?

NTS



NOT TO SCALE

**CALL UTILITY NOTIFICATION
CENTER OF COLORADO
1-800-922-1987**

**CALL 2-BUSINESS DAYS IN ADVANCE
BEFORE YOU DIG, GRADE, OR EXCAVATE
FOR THE MARKING OF UNDERGROUND
MEMBER UTILITIES.**

POND C2.8 PLAN & DETAILS

C1.6