



19 E. Willamette Ave.
Colorado Springs, CO 80903
(719)-477-9429
www.jpsegr.com

September 6, 2019

CDOT Region 2 Access
Attn: Arthur Gonzales, R2 - Access Manager
5615 Wills Blvd.
Pueblo, CO 81008

**SUBJECT: Ellicott Town Center
JPS Responses to CDOT Drainage Review Comments**

Dear Art:

This letter is intended to provide a response to the CDOT review comments pertaining to our Final Drainage Report in your letter dated June 20, 2019. These drainage review comments have been addressed as follows:

- The proposed berm on the south side of the CDOT ROW is not intended to block any drainage flow. A drainage swale will flow easterly along the north side of the berm, and the existing ditch along the south side of SH94 will continue to flow easterly to the existing culvert crossings. The existing 30" CMP culverts crossing SH94 will be extended as required based on roadway widening for highway access improvements. Details for extension of existing culverts and associated erosion control measures will be included in the Highway Access Improvement Plans.
- Details for any required extension of the easterly existing 30" CMP culverts will also be included in the Highway Access Improvement Plans. The existing drainage channels flowing southeast from the culverts crossing SH94 will be preserved and/or improved as detailed in the subdivision construction drawings.
- Notes regarding maintenance of highway ditch drainage patterns and extension of existing highway culverts have been added to Sh. D1.01 in the updated Final Drainage Report.

Please contact me if you have any questions or need any additional information.

Sincerely,
JPS Engineering, Inc.

John P. Schwab, P.E.