



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Flying Horse North Golf Course Temporary Grill, PPR-20-43 (Revised)

Please accept the following comments from El Paso County Public Health for the temporary clubhouse request referenced above:

- Water service for the temporary clubhouse is planned to be provided by an existing onsite well and an underground water cistern. Please be aware the water from this well cannot be used for anything but flushing toilets. Water for handwashing must be from an approved water source as handsink water is often used to re-fill personal water bottles.
- Wastewater service for the clubhouse is planned to be an El Paso County Public Health (EPCPH) permitted and approved holding vault complying with all installation regulations. Approval of the holding vault is contingent upon submittal of the following to EPCPH:
 - An application for a New Onsite Wastewater Treatment System (OWTS) Permit, a site plan showing the vault and clubhouse locations and a letter from a Professional Engineer explaining the use of the vault.
 - A letter regarding the planned annexation process and the timing when the process is expected to be completed must be submitted with the OWTS application.
 - The holding vault is only permitted for temporary use until such time the future clubhouse can connect to a central wastewater mainline.
- The letter of intent indicates there will be no formal food preparation. Food preparation of any kind requires water to be obtained from an approved source.

Mike McCarthy
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
24Mar2021