

**Flying Horse North Golf Course Temporary Grill,**  
**PPR-20-43 (Second Revision)**

Please accept the following comments from El Paso County Public Health for the temporary clubhouse request referenced above:

- Water service for the temporary clubhouse is planned to be provided by an existing onsite well and an underground water cistern. Please be aware the raw water from this well can only be used for flushing toilets. Water for handwashing must be from an approved water source as handsink water is often used to re-fill personal water bottles.
- Wastewater service for the clubhouse is planned to be an El Paso County Public Health (EPCPH) permitted and approved holding vault complying with all installation regulations. Approval of the holding vault is contingent upon submittal of the following to EPCPH:
  - An application for a New Onsite Wastewater Treatment System (OWTS) Permit, a site plan showing the vault and clubhouse locations and a letter from a Professional Engineer explaining the use of the vault. Please be aware a vault must comply with Section 8.12.C.1-10. of the Regulations of the El Paso County Board of Health, Chapter 8, On-Site Wastewater Treatment Systems.
  - Documentation of the planned annexation process and the proposed timing when annexation is expected.
  - The holding vault will be permitted for temporary use only and must be abandoned upon connection of the new clubhouse to a central wastewater mainline.
- The letter of intent indicates there will be no formal food preparation. Food preparation requires water to be obtained from an approved source. Also, an approved Variance according to the OWTS Regulations is required to allow any food preparation wastewater, or any wastewater other than from the restrooms to go to the holding vault.

Mike McCarthy, El Paso County Public Health  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
28Apr2021