



**ENTECH**  
 ENGINEERING, INC.  
 505 Elkton Drive  
 Colorado Springs, CO 80907  
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #7
Project:	Forest Lakes Development, Filing 7
Entech Job #	220622

**CONCRETE TEST**

**J. Barnhart**

Test #: **9**

Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
6/10/2022	4	4500	11:15 AM	24	6/11/2022

<b>Specimen Type</b>	<b>Test Type</b>	<b>Type of Cure</b>
----------------------	------------------	---------------------

<b>Cylinders 4x8</b>	<b>Field</b>	<b>Lab</b>
----------------------	--------------	------------

Contractor:	Supplier:	Mix Design Number
PPC Construction	Pete Lien	90DJ50

Truck Number	Ticket Number	Batch Time:
2277	764776	10.0

Location:  
 48" Wing Wall, West Pond Structure.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
4.0	8.0	136.8	80	77

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3620				
Average:	Average:	Average:	Average:	Average:
3620				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
6/17/2022	7/8/2022			

Remarks:  
 7 Day Results

Specifications:	Break Sequence:
4500 PSI, 4" Max Slump, 5-8% Air	1@7, 3@28

Summary Comments:  
 PPC Construction, Pete Lien

Reviewed By: *PPC*