



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #7
Project:	Forest Lakes Development, Filing 7
Entech Job #	220622

CONCRETE TEST

J. Brunk Test #: 2

Date: 5/19/2022	# of Specimens: 4	Specified Strength (psi): 4500	Time of Test: 8:10 AM	Hours Field Cured: 24	Lab Receive Date: 5/20/2022
-----------------	-------------------	--------------------------------	-----------------------	-----------------------	-----------------------------

Specimen Type	Test Type	Type of Cure
----------------------	------------------	---------------------

Cylinders 4x8	Field	Lab
----------------------	--------------	------------

Contractor: PPC Construction	Supplier: Pete Lien	Mix Design Number: 90DJ50
------------------------------	---------------------	---------------------------

Truck Number: 990	Ticket Number: 763682	Batch Time: 7:02 AM
-------------------	-----------------------	---------------------

Location:
 Inlet Floor; GPS Coordinates: (39.05797° N, 104.91086° W)

Slump (in.): 4.0	Air (%): 7.5	Unit Weight (PCF): 138.8	Concrete Temp (°F): 70	Air Temp (°F): 62
------------------	--------------	--------------------------	------------------------	-------------------

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3530				
Average: 3530	Average:	Average:	Average:	Average:
Break Date: 5/26/2022	Break Date: 6/16/2022	Break Date:	Break Date:	Break Date:

Remarks:
 7 Day Results

Specifications: 4500 PSI, 4" Max Slump, 5-8% Air	Break Sequence: 1@7, 3@28
--	---------------------------

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: