



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #7
Project:	Forest Lakes Development, Filing 7
Entech Job #	220622

CONCRETE TEST

CGM			Test #:		
			10		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
6/13/2022	4	4500	2:10 PM	24	6/14/2022
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Lab	
Contractor:		Supplier:		Mix Design Number	
PPC Construction		Pete Lien		90DJ50	
Truck Number		Ticket Number		Batch Time:	
307		764891		12:57 AM	

Location:
 Inlet; GPS Coordinates: (39.058580° N, 104.908557° W)

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
2.0	6.2	141.2	86	89

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
4020				
Average:	Average:	Average:	Average:	Average:
4020				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
6/20/2022	7/11/2022			

Remarks:
 7 Day Results

Specifications: 4500 PSI, 4" Max Slump, 5-8% Air	Break Sequence: 1@7, 3@28
---	------------------------------

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: *[Signature]*