



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #7
Project:	Forest Lakes Development, Filing 7
Entech Job #	220622

CONCRETE TEST

J. Barnhart			Test #: 11		
Date: 6/15/2022	# of Specimens: 4	Specified Strength (psi): 4500	Time of Test: 3:30 PM	Hours Field Cured: 24	Lab Receive Date: 6/16/2022
Specimen Type		Test Type		Type of Cure	
Cylinders 4x8		Field		Lab	
Contractor: PPC Construction		Supplier: Pete Lien		Mix Design Number: 90DJ50	
Truck Number: 317		Ticket Number: 722805		Batch Time: 1:07 PM	

Location:
 Pond Wing Wall; GPS Coordinates: (39.057640° N, 104.911974° W)

Slump (in.): 3.0	Air (%): 7.5	Unit Weight (PCF): 136.5	Concrete Temp (°F): 81	Air Temp (°F): 77
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3200				
Average: 3200	Average:	Average:	Average:	Average:
Break Date: 6/22/2022	Break Date: 7/13/2022	Break Date:	Break Date:	Break Date:

Remarks:
 7 Day Results

Specifications: 4500 PSI, 4" Max Slump, 5-8% Air	Break Sequence: 1@7, 3@28
-----------------------------------------------------	------------------------------

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: *[Signature]*