



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #7
Project:	Forest Lakes Development, Filing 7
Entech Job #	220622

CONCRETE TEST

IT			Test #: 7		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
6/3/2022	4	4500	11:30 AM	24	6/4/2022

Specimen Type	Test Type	Type of Cure
----------------------	------------------	---------------------

Cylinders 4x8	Field	Lab
----------------------	--------------	------------

Contractor:	Supplier:	Mix Design Number
PPC Construction	Pete Lien	90DJ50

Truck Number	Ticket Number	Batch Time:
317	764346	10:19 AM

Location:
 Inlet; STA 7 + 35 on Mesa Top Road.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
4.0	7.0	138.8	67	50

<i>7-Day Strength</i>	<i>28-Day Strength</i>	<i>-Day Strength</i>	<i>56-Day Strength</i>	<i>-Day Strength</i>
-----------------------	------------------------	----------------------	------------------------	----------------------

3910				
------	--	--	--	--

--	--	--	--	--

--	--	--	--	--

Average:	Average:	Average:	Average:	Average:
3910				

Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
6/10/2022	7/1/2022			

Remarks:
 7 Day Results

Specifications: 4500 PSI, 4" Max Slump, 5-8% Air	Break Sequence: 1@7, 3@28
---	------------------------------

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: