



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #7
Project:	Forest Lakes Development, Filing 7
Entech Job #	220622

CONCRETE TEST

CGM			Test #:	4		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:	
5/26/2022	4	4500	2:15 PM	24	5/27/2022	
Specimen Type		Test Type		Type of Cure		
Cylinders 4x8		Field		Lab		
Contractor:		Supplier:		Mix Design Number		
PPC Construction		Pete Lien		90DJ50		
Truck Number		Ticket Number		Batch Time:		
996		764001		12:56 PM		

Location:
 Pond Structure; GPS Coordinates: (39.057974° N, 104.910647° W)

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
3.75	6.0	140.7	74	75
7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
4190				
Average:	Average:	Average:	Average:	Average:
4190				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
6/2/2022	6/23/2022			

Remarks:
 7 Day Results

Specifications: 4500 PSI, 4" Max Slump, 5-8% Air	Break Sequence: 1@7, 3@28
---	------------------------------

Summary Comments:
 PPC Construction, Pete Lien

Reviewed By: *[Signature]*