



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Glen at Widefield, Filing No. 11, SF-20-4

Please accept the following updated comments from El Paso County Public Health (EPCPH) regarding the 45-acre, 103 residential lot development project with 4 Tracts referenced above:

- Water service will be provided by Widefield Water and Sanitation District (WWSD) PWSID# CO0121900. There is a finding for sufficiency in terms of water quality for water provided by Widefield Water and Sanitation District. A Letter of Commitment dated 05August2021 from WWSD to serve both water and wastewater services was submitted, reviewed, and approved.
- Wastewater service will be provided by Widefield Water and Sanitation District (WWSD). The WWSD has sufficient treatment capacity for the proposed 45-acre, 103 residential lot developments hydraulic load.
- El Paso County Public Health encourages planned walkability of residential communities. Please consider appropriate connections to commercial areas through the use of sidewalks, and bike trails. Walkability features help reduce obesity and associated heart diseases.
- The water quality detention basins must have mosquito control responsibilities included as a part of the maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.
- Earthmoving activities greater than 25 acres require a Construction Activity Permit from the Colorado Department of Public Health and Environment, Air Pollution Control Division. Go to:
<https://www.colorado.gov/pacific/cdphe/general-air-permits>

Mike McCarthy
El Paso County Public Health
mikemccarthy@elpasoco.com
719-575-8602
12November 2021