

David Mijares

From: Olson - DNR, Jacob <jacob.olson@state.co.us> on behalf of Olson - DNR, Jacob
Sent: Tuesday, June 6, 2023 9:31 AM
To: David Mijares
Cc: Jessica Wodiuk - DNR
Subject: Re: Villas at Claremont Ranch NOI Application

David,

Unfortunately it has not been approved yet. I did my review and it is waiting on our Division Engineer's approval. She has a backlog of things she's trying to get caught up on, including these NOI applications. I do not have a timeline on when this will get approved.

Apologies for the inconvenience, but we appreciate your patience.

Thank you,

Jacob Olson
North Regional Team Leader
Districts 10, 14, and 15



P 719.227.5291 | C 719.338.2012
4255 Sinton Rd., Colorado Springs, CO 80907
jacob.olson@state.co.us | dwr.colorado.gov

Please complete our new [DWR User Experience Survey](#) on our [DWR Homepage](#) to express your opinions of our service. Your complete satisfaction is important to us!

On Tue, Jun 6, 2023 at 9:28 AM David Mijares <david@catamounteng.com> wrote:

Jacob/Jessica-

I am just looking for an update, so I can get a response into El Paso County on this. Let me know when I can anticipate.

Thank you,

David Mijares, PE

CATAMOUNT ENGINEERING

321 W. Henrietta Ave Suite 'A'

PO BOX 221

Woodland Park, CO 80866

(719)426-2124

From: David Mijares <david@catamounteng.com>
Sent: Friday, May 26, 2023 7:23 AM
To: 'Olson - DNR, Jacob' <jacob.olson@state.co.us>
Cc: 'Jessica Wodiuk - DNR' <jessica.wodiuk@state.co.us>
Subject: RE: Villas at Claremont Ranch NOI Application

Jacob,

Thank you for the quick response. Attached is revised SDI data.

David Mijares, PE

CATAMOUNT ENGINEERING

321 W. Henrietta Ave Suite 'A'

PO BOX 221

Woodland Park, CO 80866

(719)426-2124

From: Olson - DNR, Jacob <jacob.olson@state.co.us>
Sent: Thursday, May 25, 2023 2:58 PM
To: david@catamounteng.com
Cc: Jessica Wodiuk - DNR <jessica.wodiuk@state.co.us>
Subject: Villas at Claremont Ranch NOI Application

Hi David,

We are in receipt of your NOI application for the structure at the Villas at Claremont Ranch in El Paso County and I see that you have included the SDI data, but it seems incomplete. I need to see that the structure will drain 97% of the inflow volume from a 5 year storm event within 72 hours. Could you please update SDI data when you get a chance?

Thank you,

Jacob Olson

**North Regional Team Leader
Districts 10, 14, and 15**



P 719.227.5291 | C 719.338.2012

4255 Sinton Rd., Colorado Springs, CO 80907

jacob.olson@state.co.us | dwr.colorado.gov

Please complete our new [DWR User Experience Survey](#) on our [DWR Homepage](#) to express your opinions of our service. Your complete satisfaction is important to us!