

EL PASO COUNTY DEPARTMENT OF HEALTH AND ENVIRONMENT  
INDIVIDUAL SEWAGE DISPOSAL SYSTEM INSPECTION FORM

Permit # 96.14 P  
Date 11/30/95

APPROVED: YES  NO  # 4135000004 ENVIRONMENTALIST Mydlowski, S

Address 16150 Murphy Road Owner John E. TARA Olson

Legal Description SSE4 S104 Sec 35-11-64  
Residence  # of bedrooms 3; Commercial ; System Installer Quartz



**SEPTIC TANK:**  
Commercial  Noncommercial  L         , W         , WD           
Construction Material 40 Cast Concrete, capacity 1250 gallons.

**DISPOSAL FIELD:**  
**Rock Systems:**  
Trench: depth         , width         , total length         , sq. feet           
Bed: depth         , length         , width         , sq. feet           
Rock type         , depth         , under PVC         , over PVC           
Seepage Pits: # of pits         , total # of rings         , working depth(s)           
size of pit(s) L X W         , lining material         , total sq. feet         

**Rockless Systems:**  
Chamber: Type 1 Chamber, number of chambers 24, bed         , trench   
sq. ft./section 184 sq. ft., reduction allowed 50 %, sq. ft required 714 sq. ft.  
total sq. ft. installed 184 sq. ft. equivalent, depth of installation 16-18"

Engineer Design Y or N, Designing Engineer           
Approval letter provided? Y or N           
Well 50 feet from tank  or N 100 feet from leach field  or N           
Well installed at time of septic system inspection  or N          Public Water           
\*Approval will be revoked if in the future the well is found to be within 50 feet of the septic tank and/or 100 feet of the disposal field.

NOTES: No Home on property at time of inspection.



*[Handwritten signature]*

Acres 40

**EL PASO COUNTY • DEPARTMENT OF HEALTH AND ENVIRONMENT**

301 South Union Blvd. • Colorado Springs, Colorado • 578-3125

Water Supply well

Permit 9614

**PERMIT**

**TO CONSTRUCT, ALTER, REPAIR OR MODIFY ANY INDIVIDUAL SEWAGE DISPOSAL SYSTEM**

Receipt No. \_\_\_\_\_

Issued to JOHN & TARA KOLSON

Date 10-27-95

Address of Property 16150 MURPHY ROAD, SSE4, SW4, SEC, 35-11-64

Phone 593-8840 X302

(Permit valid at this address only)

Sewage-Disposal System work to be performed by \_\_\_\_\_ Phone \_\_\_\_\_

This Permit is issued in accordance with 25-10-106 Colorado Revised Statutes 1973, as amended. PERMIT EXPIRES upon completion-installation of sewage-disposal system or at the end of twelve (12) months from date of issue- whichever occurs first-(unless work is in progress). This permit is revokable if all stated requirements are not met.

**-THIS PERMIT DOES NOT DENOTE APPROVAL OF ZONING AND ACREAGE REQUIREMENTS-**

\$150.00

PERMIT FEE (NOT REFUNDABLE)

10-27-96

DATE OF EXPIRATION

*[Signature]*  
DIRECTOR, DEPARTMENT OF HEALTH AND ENVIRONMENT  
*[Signature]*  
ENVIRONMENTALIST

**NOTE: LEAVE ENTIRE SEWAGE-DISPOSAL SYSTEM UNCOVERED FOR FINAL INSPECTION. 48 HOUR ADVANCE NOTICE REQUIRED.**

SEPTIC TANK:  1250 gallons	TRENCH SYSTEM: total square feet <u>714</u> ____ ft. of trench _____ inches wide ____ ft. of trench _____ inches wide	BED SYSTEM:  total square feet _____	SEEPAGE PIT SYSTEM: total square feet _____  rings or _____ diam.x _____ w/d
-------------------------------------	--	--	---

**NOTES: SYSTEM TO BE INSTALLED PER REGULATIONS. GROUND WATER PRESENT AT 66 INCHES - SYSTEM TO BE INSTALLED NO DEEPER THAN 18 INCHES.**

The Health Office shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative. Free access to the property shall be authorized at reasonable time for the purpose of making such inspections as are necessary to determine compliance with requirements of this law.

EL PASO COUNTY DEPARTMENT OF HEALTH AND ENVIRONMENT

301 South Union Boulevard

Colorado Springs, CO 80910-3123

APPLICATION FOR A PERMIT TO CONSTRUCT, REMODEL, OR INSTALL A SEWAGE DISPOSAL SYSTEM

Name of Owner John & Tara Kolson Daytime Phone 719-593-8840

Address of Property 16156 Murphy Rd Peyton, CO 80831 Date 10-20-95

Legal Description of Property SE 4 SW 4 35-11-641 County

Tax Schedule Number 41350-00-004 Septic Contractor/Phone -

Type of House Construction trailer mobile Source of Water well

Size of Lot 40 ac. Basement (Y or (N)) Percolation Test Attached ((Y) or N)

MAXIMUM POTENTIAL NUMBER OF BEDROOMS 3

I have supplied a plot plan as described on the back of this form. I acknowledge the completeness of the application is conditional upon such further mandatory & additional tests & reports as may be required by the Department to be made & furnished by the applicant for purposes of evaluating the application, & issuance of the permit is subject to such terms & conditions as deemed necessary to ensure compliance with rules & regulations adopted pursuant to C.R.S. 1973, 10-25-101 et. seq. I hereby certify all statements made, information and reports submitted by me are or will be represented to be true & correct to the best of my knowledge & belief, & are designed to be relied on by the El Paso County Department of Health in evaluating the same for purposes of issuing the permit applied for herein. I further understand any falsification or misrepresentation may result in the denial of the application or revocation of any permit granted based upon said application & in legal action for perjury as provided by law.

OWNER'S SIGNATURE Tara Kolson

\*\*\*\*\*

DEPARTMENT OF HEALTH USE ONLY

Absorption Area 714 sq ft Tank Capacity 1250 gal Date/Site Inspection Oct 26, 95

Remarks: System to be installed per regulations  
Ground water present at 66" inches - system to  
be installed no deeper than 18" inches.

Application is (  approved ( ) denied

Environmentalist Hydowski, D Date October 24, 95

\*\*\*\*\*

Permit # 9614 Receipt # \_\_\_\_\_ Date to Planning Dept 10-20-95

attached

**PROPERTY AND PERC HOLES MUST BE CLEARLY MARKED/POSTED**

The following information must be on your plot plan.  
Please check ( ) the items that apply.

- ( ) Property Lines
- ( ) Property Dimensions
- (✓) Proposed Septic System Site
- ( ) Well(s)
- ( ) Adjacent Well(s)
- ( ) Building(s)
- (✓) Proposed Building(s)
- ( ) Water Line
- ( ) Cistern
- ( ) Subsoil Drain(s)

Are any of these within 100 feet of your proposed septic system (including adjoining property)? Also draw on the plot plan.

Spring(s) no  
Lake(s) no  
Pond(s) no  
Stream(s) no  
Dry Gulch(s) no  
Natural Drainage Course(s) no

---

Give complete directions to the property from a main highway.

~~How~~ Hwy 24 <sup>east</sup> to Elbert highway left on  
Elbert Hwy to Murphy Rd right on  
Murphy 3/4 mile on left.