







# V11\_GEC Plans.pdf Markup Summary

---

## Callout (1)

---



**Subject:** Callout  
**Page Label:** [1] 8 GRADING & EROSION CONTROL PLAN  
**Author:** CDurham  
**Date:** 2/15/2024 11:48:31 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Silt fence can not be used to direct flows.  
Reconsider location or type of BMP needed here.

---

## SW - Textbox with Arrow (3)

---




**Subject:** SW - Textbox with Arrow  
**Page Label:** [1] 6 GRADING & EROSION CONTROL PLAN  
**Author:** Glenn Reese - EPC Stormwater  
**Date:** 2/15/2024 8:04:22 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Why is the swale not in line with the culvert? How will culvert flows be conveyed to the swale?



**Subject:** SW - Textbox with Arrow  
**Page Label:** [1] 8 GRADING & EROSION CONTROL PLAN  
**Author:** Glenn Reese - EPC Stormwater  
**Date:** 2/15/2024 12:31:06 PM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Riprap is shown in this swale on Sht G2.1 but not on this plan. Revise to remove discrepancy and to provide adequate erosion protection.



**Subject:** SW - Textbox with Arrow  
**Page Label:** [1] 8 GRADING & EROSION CONTROL PLAN  
**Author:** Glenn Reese - EPC Stormwater  
**Date:** 2/15/2024 12:30:47 PM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Consider need for riprap apron here or other means of outfall protection. Silt fence is not a suitable temp BMP for the outfall of a swale.