


V11_GEC Plans.pdf Markup Summary

Callout (1)



Subject: Callout
Page Label: [1] 8 GRADING & EROSION CONTROL PLAN
Author: CDurham
Date: 2/15/2024 11:48:31 AM
Status:
Color: ■
Layer:
Space:


Silt fence can not be used to direct flows.
Reconsider location or type of BMP needed here.

SW - Textbox with Arrow (3)



Subject: SW - Textbox with Arrow
Page Label: [1] 6 GRADING & EROSION CONTROL PLAN
Author: Glenn Reese - EPC Stormwater
Date: 2/15/2024 8:04:22 AM
Status:
Color: ■
Layer:
Space:

Why is the swale not in line with the culvert? How will culvert flows be conveyed to the swale?



Subject: SW - Textbox with Arrow
Page Label: [1] 8 GRADING & EROSION CONTROL PLAN
Author: Glenn Reese - EPC Stormwater
Date: 2/15/2024 12:31:06 PM
Status:
Color: ■
Layer:
Space:

Riprap is shown in this swale on Sht G2.1 but not on this plan. Revise to remove discrepancy and to provide adequate erosion protection.



Subject: SW - Textbox with Arrow
Page Label: [1] 8 GRADING & EROSION CONTROL PLAN
Author: Glenn Reese - EPC Stormwater
Date: 2/15/2024 12:30:47 PM
Status:
Color: ■
Layer:
Space:

Consider need for riprap apron here or other means of outfall protection. Silt fence is not a suitable temp BMP for the outfall of a swale.