



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Chipotle, Falcon Market Place, PPR-22-49

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- Water service will be provided by Woodmen Hills Metropolitan District (WHMD). The water system is assigned the PWSID# CO0121930 by the Colorado Department of Public Health and Environment.
- Wastewater service to be provided by Woodmen Hills Metropolitan District.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.
- Interior finish plans for all El Paso County Public Health regulated facilities must be submitted to El Paso County Public Health for review and approval prior to commencement of the project. Contact El Paso County Public Health at 719-578-3199, option 3.
- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
21October2022