



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Fox Run Nature Center SDP, PPR-23-49

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- **Water service will be provided by Donala Water and Sanitation District. The water system is assigned the PWSID #CO0121175 from the Colorado Department of Public Health and Environment. There is a finding for sufficiency in terms of water quality for water from the Donala Water and Sanitation District.**
- **Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.**
- **Radon resistant construction techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.**
- **The water quality basins must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.**
- **Wastewater service was not addressed with this project but appears to be by an onsite wastewater treatment system (OWTS). The OWTS must be sized and designed by a Colorado Registered Professional Engineer and approved by El Paso County Public Health or the Colorado Department of Public Health and Environment, Water Quality Control Division depending on the wastewater flow and strength.**

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
10January2025