

From: [Keith Curtis](#)
To: [Tina Brazil](#)
Cc: [Jennifer Kraus](#); [Kari Parsons](#)
Subject: RE: Grazing Yak Solar Project
Date: Wednesday, April 3, 2019 4:38:20 PM
Attachments: [image002.png](#)

Tina,

We do not need a floodplain permit for subterranean utility work that will have no permanent impact on the floodplain.

Thank you for checking.

Keith Curtis, PE, CFM

Floodplain Administrator

Pikes Peak Regional Building Department

2880 International Circle

Colorado Springs CO, 80910

O: 719-327-2898 E: keith@pprbd.org W: pprbd.org



CONFIDENTIALITY NOTICE: This e-mail and any attached files contain information belonging to the sender and recipient listed above that may be confidential and/or legally privileged. This information is intended only for the use of the person to whom the e-mail was sent as listed above. If you are not the intended recipient, any disclosure, copying, distribution, or action taken in reliance on the contents of the information contained in this e-mail is strictly prohibited. If you have received this e-mail in error, please reply to Keith@pprbd.org to give notice of the error, and delete this message from your computer and network system. Thank you.

-

From: Tina Brazil <brazil@corecivil.com>
Sent: Wednesday, April 3, 2019 4:32 PM
To: Keith Curtis <keith@pprbd.org>
Cc: Jennifer Kraus <kraus@corecivil.com>
Subject: Grazing Yak Solar Project

Hi Keith,

As discussed via phone, the collection line installation for the Grazing Yak Solar Project will require trenching across the Horse Creek Zone A floodplain resulting in temporary impacts to the existing contours of the drainage, but contours of Horse Creek will be returned to their pre-construction condition and elevation at the completion of the collection line installation. GESC, SWMP, and SPCC plans will be developed to manage on-site pollutants during construction and as needed for operations. Recontouring and reseeding would occur immediately following installation of the collection lines. Attached is a preliminary site plan map of the collection lines where they cross the Horse Creek Zone A floodplain, and a Zoning Map that shows the relative location of the Project site

. Can you please confirm that no permits are required from PPRBD for the project work in the Horse Creek Zone A floodplain? Thank you Keith.

Tina Brazil
Environmental Consultant
O 303.730.5987
M 215.280.2370



1950 W Littleton Blvd Suite 109
Littleton CO 80120
303.703.4444
CoreCivil.com