



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Hyatt Extended Family, AL-19-026

Please accept the following comments from El Paso County Public Health for the special use project referenced above:

- Water service for the existing home and the extended dwelling is by an existing individual private well.
- Wastewater services for the project are provided by 2 separate onsite wastewater treatment systems (OWTS). The OWTS for the original house was installed and approved in 1994 and upgraded in 2015. The extended dwelling OWTS was installed and approved for 6-bedrooms in 2017.
- It is recommended that gravity fed OWTS's be inspected by an OWTS professional at least every 4 years.
- No public health issues noted.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
03Jan2020