Stormwater Detention and Infiltration Design Data Sheet

SDI-Design Data v2.00, Released January 2020

Stormwater Facility Name: **Sterling Ranch East Filing No. 1 - Pond 14A**

Facility Location & Jurisdiction: Sterling Ranch Metropolitan District - Private Facility

User Input: Watershed Characteristics

C. Input: Trateronea enanactoriotico							
Extend	ded Detention Basin (EDB)	EDB					
	Watershed Area =	156.85	acres				
	Watershed Length =	2,650	ft				
	Watershed Length to Centroid =	1,200	ft				
	Watershed Slope =	0.025	ft/ft				
	Watershed Imperviousness =	48.8%	percent				
Р	ercentage Hydrologic Soil Group A =	100.0%	percent				
Р	ercentage Hydrologic Soil Group B =	0.0%	percent				
Perc	entage Hydrologic Soil Groups C/D =	0.0%	percent				
	Target WQCV Drain Time =	40.0	hours				
Location for 1-hr Rainfall Depths (use dropdown):							
	User Input	•					

After providing required inputs above including 1-hour rainfall depths, click 'Run CUHP' to generate runoff hydrographs using the embedded Colorado Urban Hydrograph Procedure.

Once CUHP has been run and the Stage-Area-Discharge information has been provided, click 'Process Data' to interpolate the Stage-Area-Volume-Discharge data and generate summary results in the table below. Once this is complete, click 'Print to PDF'.

User Defined	User Defined	User Defined	User Defined
Stage [ft]	Area [ft^2]	Stage [ft]	Discharge [cfs]
0.00	1,070	0.00	0.00
0.50	1,070	0.50	0.14
1.00	1,835	1.00	0.20
2.00	15,728	2.00	0.28
3.00	47,089	3.00	0.83
5.00	103,984	5.00	1.90
7.00	129,654	7.00	12.36
9.00	144,608	9.00	123.85
11.00	160,255	11.00	1889.70
12.00	168,321	12.00	3597.60

After completing and printing this worksheet to a pdf, go to: https://maperture.digitaldataservices.com/gvh/?viewer=cswdif Create a new stormwater facility, and attach the PDF of this worksheet to that record.

Routed Hydrograph Results

acca mydrograph resours								
Design Storm Return Period =	WQCV	2 Year	5 Year	10 Year	50 Year	100 Year		
One-Hour Rainfall Depth =	N/A	1.19	1.50	1.75	2.25	2.52	in	
CUHP Runoff Volume =	2.653	6.608	8.791	10.519	16.062	19.552	acre-ft	
Inflow Hydrograph Volume =	N/A	6.608	8.791	10.519	16.062	19.552	acre-ft	
Time to Drain 97% of Inflow Volume =	40.8	56.2	56.5	56.4	53.2	51.2	hours	
Time to Drain 99% of Inflow Volume =	43.7	62.5	64.4	65.3	63.8	62.3	hours	
Maximum Ponding Depth =	4.18	5.65	6.32	6.81	7.76	8.39	ft	
Maximum Ponded Area =	1.85	2.58	2.77	2.92	3.10	3.21	acres	
Maximum Volume Stored =	2.671	6.029	7.781	9.208	12.055	14.060	acre-ft	



