



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

14925 Basin Drive, AL-25-13

Please accept the following comments from El Paso County Public Health (EPCPH) for the project referenced above:

- **Water service for the existing house is by an individual private well.**
 - **Wastewater service for the existing house is an onsite wastewater treatment system (OWTS) permitted, installed and approved for a 4-bedroom house in 2009. The proposed new accessory living quarters (ALQ) must have the existing OWTS evaluated and approved through the Verification process to be considered for connection.**
- **The existing water line must meet the setback to the new wastewater line or the wastewater line must be properly encased as specified in the OWTS Regulations.**

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
14July2025