


# Storm Construction Plan Redlines.pdf Markup Summary

CDurham (2)




**Subject:** Callout  
**Page Label:** C6.13  
**Author:** CDurham  
**Date:** 4/15/2026 3:32:24 PM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Label Manhole



**Subject:** Re: Callout  
**Page Label:** C6.13  
**Author:** Rich  
**Date:** 4/28/2026 8:20:55 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

MANHOLE HAS BEEN LABELED IN PROFILE VIEW



**Subject:** Callout  
**Page Label:** C6.31  
**Author:** CDurham  
**Date:** 4/15/2026 4:03:24 PM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Remove 18" lateral since it's no longer needed according to the drainage report



**Subject:** Re: Callout  
**Page Label:** C6.31  
**Author:** Rich  
**Date:** 4/28/2026 8:21:24 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

THE 18" STORM LATERAL HAS BEEN REMOVED FROM THE PROFILE VIEW MANHOLE

Jalal Saleh (1)



**Subject:** Text Box  
**Page Label:** C1.1  
**Author:** Jalal Saleh  
**Date:** 4/14/2026 12:42:59 PM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Easement Agreement / document number 217152003; show all easements as it relates to this project on all plans, provide width and label them. Typical comment to all plan sets

Please provide a whole sheet for the entire storm sewer system and show all storm sewer easements on it, make sure they are labeled and indicate the width of each storm sewer easement (It is hard to follow the individual segments).



**Subject:** Re: Text Box  
**Page Label:** C1.1  
**Author:** Rich  
**Date:** 4/28/2026 8:22:43 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

AN OVERALL STORM SEWER SHEET IS ADDED. THE OVERALL SHEET SHOWS ALL EXISTING EASEMENTS AND ALL PROPOSED EASEMENTS/WIDTHS. MOST OF THE STORM SEWER IS IN TRACTS WHICH THE ENTIRE TRACT IS A DRAINAGE/UTILITY EASEMENT.