



KENNETH R. HODGES, COUNTY ATTORNEY

Nathan J. Whitney, First Assistant County Attorney | Steven A. Klaffky, Chief Deputy County Attorney

June 19, 2026

PUDSP-25-5 Antelope Ridge at Bull Hill Phase 1

Reviewed by: Lori Seago, Senior Assistant County Attorney
April Willie, Paralegal

WATER SUPPLY REVIEW AND RECOMMENDATIONS

Project Description

1. This is a proposal by Eagle Development Company (“Applicant”), to subdivide an approximately 164.586 +/- acre parcel into 471 lots. The property is zoned PUD (Planned Unit Development).

Estimated Water Demand

2. Pursuant to the *Water Supply Information Summary* (“WSIS”), the Applicant estimated its annual water needs to serve this subdivision at 167.67 acre-feet/year, which equates to 0.35 acre-feet per year per lot and is comprised of 164.85 annual acre-feet for household use and 2.82 annual acre-feet for irrigation. Based on these figures, the Applicant must provide a supply of 50,301 acre-feet of water (167.67 acre-feet/year x 300 years) to meet the County’s 300-year water supply requirement for the subdivision.

Proposed Water Supply

3. The Applicant has provided for the source of water to derive from the Widefield Water and Sanitation District (“District”). As described in the *Water Resources Report* (“*Report*”), the District has a current developed physical water supply of 5,271 acre-feet of water per year, and the three year average actual use is 2,898 acre-feet per year. The District’s water is sourced from a number of groundwater and surface water sources. The *Report* indicates that the district “has an excess capacity in their existing water supply system to serve this subdivision.”

4. The District provided a letter of commitment for Antelope Ridge at Bull Hill Phase 1 dated March 12, 2026, in which the District committed to providing water service for the 471 lots plus irrigation, for an annual water requirement of 167.67 acre-feet.¹

State Engineer's Office Opinion

5. In a letter dated June 3, 2026, the State Engineer reviewed the application to subdivide the 165 +/- acres into 471 lots. The State Engineer stated that "[i]nformation in our files indicates the district has approximately 278 acre-feet per year of water available for additional commitments." Further, the State Engineer stated that "...pursuant to Section 30-28-136(1)(h)(I) and 30-28-136(1)(h)(II), C.R.S., it is our opinion that the proposed water supply is adequate and can be provided without causing injury to decreed water rights."

Recommended Findings

6. Quantity and Dependability. Applicant's water demand for Antelope Ridge at Bull Hill Phase 1 is 167.67 acre-feet per year for a total demand of 50,301 acre-feet for the subdivision for 300 years, to be supplied by Widefield Water and Sanitation District. **Based on the District's commitment to serve this subdivision and the State Engineer's conclusion that the District has sufficient water to provide such service, the County Attorney's Office recommends a finding of sufficient water quantity and dependability for Antelope Ridge at Bull Hill Phase 1.**

7. Quality. The water quality requirements of Section 8.4.7.B.10 of the Code must be satisfied. Section 8.4.7.B.10.g. of the Code allows for the presumption of acceptable water quality for projects such as this where water is supplied by an existing Community Water Supply operating in conformance with Colorado Primary Drinking Water Regulations unless there is evidence to the contrary.

8. Basis. The County Attorney's Office reviewed the following documents in preparing this review: the *Water Supply Information Summary*, the *Water Resources Report* dated February 2026 the *Widefield Water and Sanitation District* letter dated March 12, 2026, and the *State Engineer Office's Opinion* dated June 3, 2026. The recommendations herein are based on the information contained in such documents and on compliance with the requirements set forth below. ***Should the information relied upon be found to be incorrect, or should the below requirements not be met, the County Attorney's Office reserves the right to amend or withdraw its recommendations.***

REQUIREMENTS:

- A. Applicant and all future owners of lots within this filing shall be advised of, and comply with, the conditions, rules, regulations, limitations, and specifications set by the District.

cc: Kylie Bagley, Project Manager, Planner

¹ This letter is attached as an appendix to the Water Resource Report. There is also a letter dated April 30, 2025 in the project file, which was superseded by the 2026 letter.