



Environmental Health Division

1675 W. Garden of the Gods Rd., Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Prevent • Promote • Protect

8140, 8150 Cessna Drive, Condo Plat, SF-24-14

Please accept the following condo plat comments below from El Paso County Public Health:

- **A finding for sufficiency in terms of water quality for these proposed commercial hanger condo plats has not been required historically. The water provided is for restroom use only and does not meet the definition of either a transient or non-transient non-community water system.**
- **The onsite wastewater treatment system (OWTS) for this project was designed by a Colorado Registered Professional Engineer, and the OWTS was properly permitted and the installation was approved by El Paso County Public Health. The primary and secondary soil treatment areas are encouraged by El Paso County Public Health to be located and protected from possible compaction by aircraft and vehicle parking.**

Mike McCarthy, 719-332-5771
El Paso County Public Health,
mikemccarthy@elpasoco.com
10September2024