



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Tender Care, PPR-18-039

Please accept the following comments from El Paso County Public Health (EPCPH) for the project referenced above:

- The .98-acre lot will be provided water and wastewater services by Woodmen Hills Metropolitan District.
- There is a finding for sufficiency in terms of water quality for drinking water obtained from this Colorado Department of Public Health and Environment, Water Quality Control Division, regulated public water system. PWSID # CO0121930.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area, have potentially higher radon levels than other areas of the country.

Mike McCarthy, R.E.H.S.
El Paso County Public Health
719.575.8602
mikemccarthy@elpasocountyhealth.org
04Oct2018