

Gary & Darlene Hammann
Ohana Acres
17825 Jones Road
Peyton, CO 80831
gary.hsquared@gmail.com
719-650-5952

Mike McCarthy
El Paso County Health Department
C/o El Paso County Planning and Development

March 14, 2024

Dear Mr. McCarthy,

Attached are the water test results for the new well at 17825 Jones Road. The well is 750 feet into the Arapahoe Water Basin and is representative of future wells to be drill on all the lots as far as depth and aquifer.

Sincerely,

 04-03-2024

Gary Hammann
Ohana Acres SF-21-41

STANDARD BACTERIOLOGICAL WATER TEST METHOD:SM-9223B

El Paso County Public Health Laboratory EPA ID# CO00025

1675 West Garden of the Gods Road, Suite 2044, Colorado Springs, CO 80907 - (719) 578-3120

PWSID

- Raw
- Finished
- LT2
- Quantitative

Sample Point ID: RTOR

Sample Taken Date: 03/05/2024 Time: 0730

Address where sample was taken: 17825 Jones Road Peyton CO 80831

Sample site location: **Bathtub**

Collector Name: Gary

Chlorine: mg/L

- Well
- City
- Recreational
- Surface/Spring
- Cistern
- Wastewater

Results to: Gary Hammann

Phone:

Mailing address: 17825 JONES RD

City/State/Zip: , CO

Fax/Email: gary.hsquared@gmail.com

Comments:

Date 03/05/2024 Time 0859 Rcd 743

Date 03/05/2024 Time 1229 Tested 860

Date 03/06/2024 Time 0800 Comp 860

Lab Sample # 16311

Coliart Results Per 100ml

- Absence: Absence of coliform bacteria
- Presence: Presence of coliform bacteria & non-compliance with drinking water standards.

MPN/100 ml:

- Absence: E. Coli: Escherichia coli bacteria
- Presence: E. Coli: Escherichia coli bacteria

MPN/100 ml:



REPORTING FORM FOR INORGANIC ANIONS IN WATER
 EPA ID # CO00025

PWSID# -		RESULTS TO: Gary Hammann			
SAMPLE INFORMATION: 17825 Jones Road Peyton, CO 80831		PHONE: (719) 650-5952			
		FAX/EMAIL: gary.hsquared@gmail.com			
		COLLECTED BY: Gary			
		SAMPLE COLLECTION DATE: 03/05/2024			
SITE DESCRIPTION: <input type="checkbox"/> Public System <input type="checkbox"/> Private <input type="checkbox"/> Surface <input type="checkbox"/> Stream <input type="checkbox"/> GWUDI <input type="checkbox"/> Other		SAMPLE COLLECTION TIME: 0730			
		MATRIX: Groundwater			
		RESIDUAL CHLORINE:			
CUSTOMER: Gary Hammann 17825 JONES RD , CO		SAMPLE RECEIVED DATE: 03/05/2024			
		RECEIVED TIME: 0859 TECH: 743			
		RECEIVED TEMP: 13.9 °C			
		DILUTIONS: 1:1, 1:10			
COMMENTS:					
TESTED		COMPLETED		TECH	
DATE: 03/05/2024		DATE: 03/05/2024			
TIME: 0912		TIME: 2016		ID: 850	
LAB SAMPLE #: 16311		SAMPLE POINT NAME:			
SAMPLE POINT ID: RTOR		FACILITY TYPE:			
FACILITY ID: DS001		FACILITY NAME:			

ANALYTE	RESULTS	MCL	MSL	STANDARD	LAB MRL
Nitrate	BDL mg/L	10.0		300.0	0.2

BDL - Below Detection Limit
 MRL - Minimum Reporting Limit

MCL - Maximum Contamination Unit per EPA
 MSL - Maximum Secondary Unit per EPA
 Q - Quality Control Limit Exceeded

H - Holding Time Exceeded
 NT - No Test



Analysis Report


Workorder: 4568532 METALS, 200.7 and 200.8

Client: Over-the-Counter Customers
Profile: METALS, 200.7 and 200.8
Sampled By: GARY L HAMMANN

Report To: GARY L HAMMANN
17825 JONES RD
Peyton, CO 80831

Sample Summary

Lab ID	Sample ID	Sample Type	Method	Date Collected	Date Received	Analyses Reported
2403060063	066-02	Water	EPA 200.7	03/05/2024 07:00	03/06/2024 07:49	11
2403060063	066-02	Water	EPA 200.8	03/05/2024 07:00	03/06/2024 07:49	7



E Travantv, PhD

Scientific Director

Note: The samples were tested as received from the customer and the results in this report relate only to the samples tested.

MRL = Minimum Reporting Limit; BDL = Below Detection Limit; * = Comment applied

*GL = Guideline Value; *

mg/L - milligrams per liter (ppm); ug/L micrograms per liter (ppb)

"If you have any questions about how your results may impact your health, please contact Toxcall at 303-692-2606 or cdphe_toxcall@state.co.us"





Analysis Report

Workorder: 4568532 METALS, 200.7 and 200.8

Sample Results

Lab ID: 2403060063 **Sample ID:** 066-02 **Sample Type:** Water
Date Collected: 03/05/2024 07:00 **Collection Site:** HALL BATH 17825 JONES RD PEYTON CO 80831
Date Received: 03/06/2024 07:49 **Site Description:**
Description: HALL BATH 17825 JONES RD PEYTON CO 80831

Parameter	Results	Units	MRL	GL	DF	Prepared	Analyzed	Qual
ICP Total Water Metals (EPA 200.7)								
Iron	0.145	mg/L	0.002	.3	1	03/20/2024 09:05	03/20/2024 13:47	
Magnesium	0.0531	mg/L	0.02		1	03/20/2024 09:05	03/20/2024 13:47	
Manganese	0.00620	mg/L	0.002	.05	1	03/20/2024 09:05	03/20/2024 13:47	
Molybdenum	0.00440	mg/L	0.002		1	03/20/2024 09:05	03/20/2024 13:47	
Nickel	<0.002	mg/L	0.002		1	03/20/2024 09:05	03/20/2024 13:47	
Sodium	102	mg/L	0.1		1	03/20/2024 09:05	03/20/2024 13:47	
Barium	0.00300	mg/L	0.001	2	1	03/20/2024 09:05	03/20/2024 13:47	
Chromium	<0.001	mg/L	0.001	.1	1	03/20/2024 09:05	03/20/2024 13:47	
Copper	0.0169	mg/L	0.004	1.3	1	03/20/2024 09:05	03/20/2024 13:47	
Zinc	4.65	mg/L	0.01	5	1	03/20/2024 09:05	03/20/2024 13:47	
Calcium	2.14	mg/L	0.01		1	03/20/2024 09:05	03/20/2024 13:47	
ICP-MS Total Water Metals (EPA 200.8)								
Lead	<1	ug/L	1	15	1	03/15/2024 09:14	03/15/2024 13:10	
Silver	<0.001	mg/L	0.001	.1	1	03/15/2024 09:14	03/15/2024 13:10	
Arsenic	<0.001	mg/L	0.001	.01	1	03/15/2024 09:14	03/15/2024 13:10	
Beryllium	<0.001	mg/L	0.001	.004	1	03/15/2024 09:14	03/15/2024 13:10	
Cadmium	<0.001	mg/L	0.001	.005	1	03/15/2024 09:14	03/15/2024 13:10	
Uranium	<0.001	mg/L	0.001	.03	1	03/15/2024 09:14	03/15/2024 13:10	
Selenium	<0.001	mg/L	0.001	.05	1	03/15/2024 09:14	03/15/2024 13:10	

Additional Information

NON-SDWIS

Free Chlorine (mg/L)
 Total Chlorine (mg/L)
 Collection Temp (C)
 Water Type

DRINKING

MRL = Minimum Reporting Limit; BDL = Below Detection Limit; * = Comment applied
 "GL = Guideline Value; "

mg/L - milligrams per liter (ppm); ug/L micrograms per liter (ppb)

"If you have any questions about how your results may impact your health, please contact Toxcall at 303-692-2606 or cdphe_toxcall@state.co.us"

