



Department of Veterans Affairs
Center for Verification and Evaluation
Service Disabled Veteran Owned Small Business

21 May 2020

Mr. Michael Couture
ABC Landscaping

Re: Drainage for Plat 7111300002

To whom it may concern:

The purpose of this letter is to address the drainage requirement for the site plan for ABC Landscaping.

I have reviewed the existing site conditions and the proposed plans for this property.

The existing drainage swale will remain adequate with the proposed 36" culvert under the access drive. Flared end sections with riprap on either end is appropriate.

The opinions rendered herein were based on a visual observation of the referenced property and no attempt was made to review components not readily viewable or accessible or the remaining portions of the property. When performing certain reviews of a building or its components, it is required to make certain assumptions regarding existing conditions. These assumptions may not be verifiable without expending additional sums of money or destroying adequate portions of the building.

Respectfully,



Andrea L. Keough, PE
Vice President of Operations