



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Crystal Park Site S-229(R), CP-22-2

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- **Crystal Park Site S-229(R), 439 Ponderosa Road, is an undeveloped residential site that will be served water by an individual private well and wastewater through an on-site wastewater treatment system (OWTS).**
- **Construction activity for the house could cause compaction of the proposed soil treatment areas (STA). The STA's must be located and protected from compaction.**
- **The onsite wastewater treatment system must comply with all El Paso County Public Health rules and regulations for OWTS's.**

Mike McCarthy
El Paso County Public Health
719.575.8602 (O)
mikemccarthy@elpasoco.com
19Jan2022