

Prevent • Promote • Protect

Environmental Health Division 1675 W. Garden of the Gods Road Suite 2044 Colorado Springs, CO 80907 (719) 578-3199 phone (719) 578-3188 fax www.elpasocountyhealth.org

## 7695 Ponca Road, Turf Master, LLC., VA-24-8

Please accept the following comments from El Paso County Public Health (EPCPH) for the variance request referenced above:

- Water service for the existing house is an existing individual private well.
- Wastewater service for existing house is an existing onsite wastewater treatment system (OWTS) permitted and approved by El Paso County Public Health (EPCPH) in 1975.
- All components of the OWTS (septic tank and soil treatment area)
  must be located and protected from compaction by vehicles and the
  business operation. Adequate area for replacement of the existing soil
  treatment area, should it be necessary, must also be protected from
  compaction.

Mike McCarthy El Paso County Public Health 719-332-5771 mikemccarthy@elpasoco.com 03January2025