



Markup Summary

dspdparsons (11)




Subject: Callout
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:32:28 AM
Color: ■

15' distance from Prop line required to avoid IES Type II or Type III




Subject: Cloud+
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:33:46 AM
Color: ■




Subject: Callout
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:38:50 AM
Color: ■

entry lighting location not parking




Subject: Cloud+
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:18:45 AM
Color: ■




Subject: Cloud+
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:33:53 AM
Color: ■

0.1 is the allowance at the property lines




Subject: Callout
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:33:33 AM
Color: ■

20 foot candles is the maximum allowed under canopy. page 6-18




Subject: Callout
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:37:27 AM
Color: ■

what is height of the wall lighting? 10' is max height




Subject: Callout
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:30:48 AM
Color: ■

Maximum on site lighting should not exceed 10 foot candles, except for loading areas where it page 6-17



Subject: Callout
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:35:01 AM
Color: ■

15' is the max height unless in parking lot.



Subject: Cloud+
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:19:21 AM
Color: ■

Areas of concern from visual impact



Subject: Callout
Page Label: 1
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdparsons
Date: 12/18/2017 11:34:10 AM
Color: ■

Identify all property lines and show lumens at all prop lines. 0.1 is the allowance for max foot candles in the Code. Adjust the light fixtures to achieve this Code standard. Page 6-17