



**Planning and Community
Development Department**
2880 International Circle
Colorado Springs, Colorado 80910
Phone: 719.520.6300
Fax: 719.520.6695
Website www.elpasoco.com

DEVIATION REQUEST AND DECISION FORM

Updated: 6/26/2019

PROJECT INFORMATION

Project Name : Falcon Marketplace
Schedule No.(s) : 5300000589
Legal Description : SE4SE4 SEC 1-13-65 INCLUDING THAT PART OF BLK 1 FALCON LY WITHIN THE SE4SE4 SEC 1-13-65, EX PT CONV TO R/W BY REC #204062427 & WOODMEN METRO BY REC # 207116129

APPLICANT INFORMATION

Company : LG HI Falcon, LLC.
Name : Steve Meier
 Owner Consultant Contractor
Mailing Address : 3953 Maple Ave, #290
Dallas, TX 75219

Phone Number : 214-416-9820
FAX Number : 214-416-9824
Email Address : steve@hummelinvestment.com

ENGINEER INFORMATION

Company : Drexel, Barrell & Co.
Name : Tim McConnell Colorado P.E. Number : 33797
Mailing Address : 3 South 7th Street
Colorado Springs, CO 80905

Phone Number : 719-260-0887
FAX Number :
Email Address : tmconnell@drexelbarrell.com

OWNER, APPLICANT, AND ENGINEER DECLARATION

To the best of my knowledge, the information on this application and all additional or supplemental documentation is true, factual and complete. I am fully aware that any misrepresentation of any information on this application may be grounds for denial. I have familiarized myself with the rules, regulations and procedures with respect to preparing and filing this application. I also understand that an incorrect submittal will be cause to have the project removed from the agenda of the Planning Commission, Board of County Commissioners and/or Board of Adjustment or delay review until corrections are made, and that any approval of this application is based on the representations made in the application and may be revoked on any breach of representation or condition(s) of approval.


B.A.P.

12-18-19

Signature of owner (or authorized representative)

Date

Engineer's Seal, Signature
And Date of Signature



DEVIATION REQUEST (Attach diagrams, figures, and other documentation to clarify request)

A deviation from the standards of or in Section **Appendix 1 Stormwater Quality & Procedures** of the Engineering Criteria Manual (ECM) is requested.

Identify the specific ECM standard which a deviation is requested:

Appendix I.7.4 Separate Presedimentation Facilities

State the reason for the requested deviation:

This deviation is a request for approval of non-standard forebays with impact structures for onsite water quality facilities Pond 2 and Pond 3.

Explain the proposed alternative and compare to the ECM standards (May provide applicable regional or national standards used as basis):

Explain the proposed alternative and compare to the ECM standards (May provide applicable regional or national standards used as basis):

Refer to the construction documents plan sheets C7.15 and C7.17 for specific design details. The forebay sizing provided is consistent with criteria at 3% WQCV, however horizontal placement is rotated given topographical restraints. Energy dissipating impact structures are proposed to reduce velocities.

LIMITS OF CONSIDERATION

(At least one of the conditions listed below must be met for this deviation request to be considered.)

- The ECM standard is inapplicable to the particular situation.
- Topography, right-of-way, or other geographical conditions or impediments impose an undue hardship and an equivalent alternative that can accomplish the same design objective is available and does not compromise public safety or accessibility.
- A change to a standard is required to address a specific design or construction problem, and if not modified, the standard will impose an undue hardship on the applicant with little or no material benefit to the public.

Provide justification:

The non-standard forebays for Ponds 2 and 3 are proposed due to topographic limitations and required pond volumes. These two conditions have dictated the current forebay design. The forebays will function as intended, reducing flow velocities and allowing sediment to settle before flows continue on through the detention facility.

CRITERIA FOR APPROVAL

Per ECM section 5.8.7 the request for a deviation may be considered if the request is **not based exclusively on financial considerations**. The deviation must not be detrimental to public safety or surrounding property. The applicant must include supporting information demonstrating compliance with **all of the following criteria**:

The deviation will achieve the intended result with a comparable or superior design and quality of improvement.

Volume design of the forebays is consistent with criteria and as such results in a comparable design.

The deviation will not adversely affect safety or operations.

No impact to safety or operations is anticipated by this design.

The deviation will not adversely affect maintenance and its associated cost.

This deviation will not adversely maintenance – forebay sizing is adequate for maintenance access.

The deviation will not adversely affect aesthetic appearance.

Volume design of the forebays is consistent with criteria and as such results in a comparable appearance.

The deviation meets the design intent and purpose of the ECM standards.

The forebay sizing provided is consistent with criteria at 3% WQCV, however horizontal placement is rotated given topographical restraints. Energy dissipating impact structures are proposed to reduce velocities. All meeting the intent and purpose of the ECM.

The deviation meets the control measure requirements of Part I.E.3 and Part I.E.4 of the County's MS4 permit, as applicable.

Development of these offsite areas will be subject to the same Stormwater Management Plan as the onsite work, which meets Part I.E.3 and I.E.4 of the MS4 permit.

REVIEW AND RECOMMENDATION:

Approved by the ECM Administrator

This request has been determined to have met the criteria for approval. A deviation from Section appendix I-7.4 of the ECM is hereby granted based on the justification provided.



Denied by the ECM Administrator

This request has been determined not to have met criteria for approval. A deviation from Section _____ of the ECM is hereby denied.



ECM ADMINISTRATOR COMMENTS/CONDITIONS:

1.1. PURPOSE

The purpose of this resource is to provide a form for documenting the findings and decision by the ECM Administrator concerning a deviation request. The form is used to document the review and decision concerning a requested deviation. The request and decision concerning each deviation from a specific section of the ECM shall be recorded on a separate form.

1.2. BACKGROUND

A deviation is a critical aspect of the review process and needs to be documented to ensure that the deviations granted are applied to a specific development application in conformance with the criteria for approval and that the action is documented as such requests can point to potential needed revisions to the ECM.

1.3. APPLICABLE STATUTES AND REGULATIONS

Section 5.8 of the ECM establishes a mechanism whereby an engineering design standard can be modified when if strictly adhered to, would cause unnecessary hardship or unsafe design because of topographical or other conditions particular to the site, and that a departure may be made without destroying the intent of such provision.

1.4. APPLICABILITY

All provisions of the ECM are subject to deviation by the ECM Administrator provided that one of the following conditions is met:

- The ECM standard is inapplicable to a particular situation.
- Topography, right-of-way, or other geographical conditions or impediments impose an undue hardship on the applicant, and an equivalent alternative that can accomplish the same design objective is available and does not compromise public safety or accessibility.
- A change to a standard is required to address a specific design or construction problem, and if not modified, the standard will impose an undue hardship on the applicant with little or no material benefit to the public.

1.5. TECHNICAL GUIDANCE

The review shall ensure all criteria for approval are adequately considered and that justification for the deviation is properly documented.

1.6. LIMITS OF APPROVAL

Whether a request for deviation is approved as proposed or with conditions, the approval is for project-specific use and shall not constitute a precedent or general deviation from these Standards.

1.7. REVIEW FEES

A Deviation Review Fee shall be paid in full at the time of submission of a request for deviation. The fee for Deviation Review shall be as determined by resolution of the BoCC.