



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Nelson Winery, AL-17-027

Please accept the following comments from El Paso County Public Health for project referenced above:

- **The proposed winery will require full compliance with the El Paso County Public Health, Onsite Wastewater Treatment System (OWTS) Regulations. The existing engineer designed OWTS must be evaluated by a registered professional engineer for the proposed change in use.**
- **The water system may meet the definition of a community water system at some point based on the proposed operational plan outlined in the letter of intent. Contact El Paso County Public Health for information.**
- **Plans for the food and wine preparation areas must be submitted to El Paso County Public Health for review and approval. A Retail Food Establishment License may be required depending on the extent of food preparation at the site. Contact El Paso County Public Health for information.**

**Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575-8602
mikemccarthy@elpasoco.com
12Dec2017**