



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

### **Widefield PK-8 School, PPR-18-026**

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the project referenced above:

- The 25 acre school site requires Letters of Intent to serve from the water/wastewater district(s).
- A finding for sufficiency in terms of water quality for drinking water cannot be made at this time. The Consumer Confidence Report from the district providing water to the school is adequate for this determination.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area, have potentially higher radon levels than other areas of the country.
- The interior finish plans must be submitted to El Paso County Public Health for review and approval prior to commencement of construction.
- A Construction Activity Permit is required for dust control on the site. Please go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> information.
- The proposed detention pond must be included in a maintenance plan for mosquito control measures and the protection of public health from mosquito borne diseases.

Mike McCarthy, R.E.H.S.  
El Paso County Public Health  
719.575.8602  
[mikemccarthy@elpasocountyhealth.org](mailto:mikemccarthy@elpasocountyhealth.org)  
21June2018