



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Cherokee Metropolitan District Lift Station LS1B, PPR-22-54

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- The proposed new lift station must meet the permitting requirements and the design criteria for lift stations of the Colorado Department of Public Health and Environment (CDPHE), Water Quality Control Division (WQCD).
- Please verify if the new lift station requires or has previously received approval of the Site Application Review Committee (SARC), the Water Quality Management Committee (WQMC) and the Pikes Peak Area Council of Governments (PPACG).
- Contact El Paso County Public Health (EPCPH) if the abandoned Chlorination Building and Outlet Structure building associated with the project will be raised. Demolition permits may be required.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719-332-5771
mikemccarthy@elpasoco.com
03February2023